

New Nominal 44 MW Cogeneration Project
Massachusetts Institute of Technology
Prevention of Significant Deterioration Application (40 CFR 52.21)

Submitted to:

Department of Environmental Protection
Northeast Regional Office
205B Lowell Street
Wilmington, MA 01887

Prepared for:

MIT Department of Facilities
Building NW23
195 Albany Street
Cambridge, MA 02139

Prepared by:

Epsilon Associates, Inc.
3 Clock Tower Place, Suite 250
Maynard, MA 01754

December, 2016

Table of Contents

TABLE OF CONTENTS

1.0	INTRODUCTION	1-1
1.1	Project Overview – Combustion Turbine Expansion	1-1
1.2	Project Overview – Other Proposed Changes	1-2
1.3	Project Benefits	1-3
1.4	Outline of Application	1-4
2.0	PROJECT DESCRIPTION AND EMISSIONS	2-1
2.1	Description of Project Site	2-1
2.2	Project Description	2-3
2.3	Source Emissions Discussion	2-4
2.4	Exhaust Design Configurations	2-6
2.5	Project Schedule	2-7
3.0	PSD APPLICABILITY	3-1
4.0	BEST AVAILABLE CONTROL TECHNOLOGY (BACT) ANALYSIS	4-1
4.1	PSD BACT Applicability	4-1
4.2	PSD BACT	4-2
4.3	Particulate Matter BACT for the CTGs and HRSGs	4-3
4.3.1	BACT Applicability	4-4
4.3.2	Step 1-Identify All Control Technologies	4-4
4.3.3	Step 2-Eliminate Technically Infeasible Options	4-6
4.3.4	Step 3-Rank Remaining Control Technologies By Control Effectiveness	4-9
4.3.5	Steps 4 & 5-Select BACT	4-11
4.4	Greenhouse Gas BACT	4-11
4.4.1	BACT Applicability	4-12
4.4.2	Step 1-Identify All Control Technologies	4-12
4.4.3	Step 2-Eliminate Technically Infeasible Options	4-13
4.4.4	Step 3-Rank Remaining Control Technologies By Control Effectiveness	4-16
4.4.5	Steps 4 & 5-Select BACT	4-19
4.5	Proposed CTG & HRSG Emission Limits	4-20
4.6	BACT for Cold-Start Engine	4-22
4.6.1	Particulate Matter	4-22
4.6.2	Greenhouse Gas (GHG) Emissions	4-23
5.0	PSD COMPLIANCE	5-1
5.1	NSR Workshop Manual Guidance	5-1
5.2	PSD Program Delegation Agreement	5-2
5.2.1	Environmental Justice conclusions	5-3
5.2.2	The Impacts: Not Disproportionately High	5-5
5.2.3.	Impacts Will Not Be Adverse	5-7
5.2.4	The Public will Continue to be Informed of the Project	5-9

List of Appendices

Appendix A	Air Quality Dispersion Modeling Analysis
Appendix B	Supplemental Information
Appendix C	Supporting Calculations
Appendix D	Technical Information

List of Figures

Figure 2-1	Aerial Locus Map
Figure 4-1	Potential CO ₂ Sequestration Sites
Figure 5-1	Mapped Environmental Justice Areas
Figure 5-2	Reduction in PM _{2.5} Impacts

List of Tables

Table 2-1	Key Existing Equipment at the MIT Plant
Table 2-2	Proposed Emission Rates for CTGs
Table 2-3	Proposed Project Potential Emissions in Tons Per Year [From Table C-10 of Appendix C]
Table 3-1	Comparison of Project Emissions to PSD Triggers
Table 4-1	Summary of Available Data on PM CTG Emission Limits
Table 4-2	Summary of PM Effectiveness of Clean Fuels (Natural Gas with ULSD Backup) & Efficient Combustion
Table 4-3	Summary of CO _{2e} Effectiveness of Clean Fuels (Natural Gas with ULSD Backup) & Efficient Combustion
Table 4-4	Comparison of CHP Configurations
Table 4-5	Proposed Short-Term Emission Limits Per CHP Unit [Table C-1/C-2 of Appendix C]
Table 4-6	Proposed Long-Term Emission Limits for the CTGs and HRSGs
Table 5-1	Expected Actual Air Quality Improvement in EJ Areas
Table 5-2	Population-weighted Predicted Impacts
Table 5-3	Population-weighted Predicted Impacts

Section 1.0

Introduction

1.0 INTRODUCTION

1.1 Project Overview – Combustion Turbine Expansion

The Massachusetts Institute of Technology (MIT) is located on 168 acres along the Cambridge side of the Charles River Basin. As part of its mission, MIT is determined to support its research and other world-changing activities with efficient, reliable power and utilities. MIT is committed to achieving this while reducing its greenhouse gas (GHG) emissions at least 32% by 2030. To this end, MIT is proposing to upgrade its on-campus power plant—a key step in developing an energy strategy that makes climate change mitigation a top priority.

The MIT Central Utilities Plant (CUP) currently provides electricity, heat, and chilled water to more than 100 MIT buildings through a combined heat and power (CHP) process, also known as cogeneration—a highly efficient method of generating electrical and thermal power simultaneously. The heat and electrical power it generates is used to maintain critical research facilities, laboratories, classrooms, and dormitories.

A cogeneration system has significant efficiency and environmental advantages, as described by the Massachusetts Department of Environmental Protection (MassDEP)¹:

“In a combined heat and power (CHP) system, the engine or combustion turbine is connected to an electrical generator for electrical power production. The hot exhaust gasses from the engine or combustion turbine are directed through a heat recovery system, such as a boiler, to recover thermal energy for use in heating, cooling, or other uses. This approach eliminates the need for a second combustion unit and therefore eliminates the emissions such a combustion unit would produce. CHP systems make more efficient use of fuel, such as natural gas or fuel oil, than two, separate stand alone, combustion units, one for electricity and one for thermal energy such as steam thus reducing the net emissions of greenhouse gas and other air contaminants.”

Since 1995, the CUP has consisted of a Siemens (ABB) GT10A Combustion Turbine Generator (CTG), a heat recovery steam generator (HRSG), an electric generator rated at approximately 21 Megawatt (MW), and ancillary equipment, all located in Building 42. The CUP also houses five boilers, designated as Boilers Nos. 3, 4, 5, 7 and 9, an emergency generator, and a number of cooling towers. Currently, the cogeneration system meets about 60% of campus electricity needs, and the steam generated from waste heat is used for campus heating and cooling (through steam-driven chillers).

¹ Proposed Amendments to 310 CMR 7.00, March 2008

MIT's proposed project would enable its power plant to meet nearly 100% of anticipated campus electric and thermal needs using cogeneration, enhancing on-campus power reliability in the event of a utility outage while also reducing MIT's GHG emissions by approximately 10%. The project involves retiring the plant's existing CTG (now reaching the end of its useful life) and installing two nominal 22 MW CTGs and two dedicated HRSGs designed with natural gas-fired duct burners. In addition, as part of this project, MIT will eliminate the burning of No. 6 fuel oil in existing boilers, significantly lowering nitrogen oxides (NO_x) and regulated pollutant emissions.

Each of the new CTGs will fire natural gas purchased and delivered to the CUP under a firm gas contract. In the event that the natural gas supply is interrupted by the supplier or is otherwise unavailable to be combusted in the equipment, each CTG will be able to operate using ultra-low sulfur diesel (ULSD) as a backup fuel. Each CTG will exhaust to a HRSG. This system will be cleaner and more efficient overall when compared with the existing system. For example, the system's state-of-the-art emissions controls will include selective catalytic reduction (SCR) for NO_x control and an oxidation catalyst for the control of carbon monoxide (CO) and volatile organics (VOC). These controls are expected to reduce NO_x by 90% as compared to the existing CTG, which is not equipped with this technology.

Additional public and environmental benefits of MIT's proposed system are detailed in Section 1.3 (Project Benefits) below.

1.2 Project Overview – Other Proposed Changes

In addition to installing two new CTGs, MIT proposes the following other changes:

- ◆ Addition of a 2 MW ULSD-fired cold-start engine unit to provide emergency power to start the CTGs when grid electricity is unavailable.
- ◆ As mentioned above, existing Boilers Nos. 3, 4, and 5 will cease burning No. 6 fuel oil and will only burn natural gas, with ULSD as a backup fuel for up to the equivalent heat input of 48 hours per year for testing and up to the equivalent heat input of 168 hours per year including testing and periods when natural gas is unavailable.

This fuel changeover will occur within 12 months of the startup of the new CTGs. This will allow for adequate time to finish construction and remove the existing No. 6 fuel oil tanks. The boilers will not fire No. 6 fuel oil after initial startup (first fire) of the new CTGs.

- ◆ Existing Boilers Nos. 7 and 9 will fire natural gas only, with ULSD as a backup fuel for up to the equivalent heat input of 48 hours per year for testing and up to the equivalent heat input of 168 hours per year including testing and periods when natural gas is unavailable. This represents a substantial reduction in the ULSD operating time limitation from the current operating permit limit of 720 hours per year.²

1.3 Project Benefits

This project has been proposed and designed to improve conditions and provide benefits to MIT and the surrounding community. The intent of the project is to increase the resiliency of the campus, safeguarding crucial research and public safety by enabling MIT to function during a power-loss event; to equip the MIT community with an efficient, reliable power source capable of supporting their groundbreaking work and experimentation; and to continue conserving energy and reducing MIT's impact on the environment.

The upgraded plant will provide a reliable source of energy that is more efficient than conventional energy sources — and that will lower both GHG and pollutant emissions, as mentioned above. In addition, the upgraded plant will improve campus resiliency by placing critical equipment above the flood level, safeguarding the system to ensure that it can provide energy to MIT's campus during a flooding event.

By providing the MIT campus with a reliable power source and improving its self-sufficiency, the project will reduce the burden on the community in a power-loss situation. As a further benefit, MIT is providing Eversource Energy (formerly NSTAR) with a location inside the plant for a new regulator station that gives Eversource access to high-pressure gas. With this access, Eversource can continue providing service to this area of Cambridge even as it develops and expands. By allowing and hosting new Eversource equipment, the proposed project will also provide the City of Cambridge with a back-up gas supply for existing natural gas users, a significant public benefit.

The project is also expected to improve the surrounding community by enhancing the Albany Street streetscape, installing new lighting on public walkways, and installing new public seating.

² The original December 2015 application requested an increase in the allowable natural gas-fired operating hours for Boilers Nos. 7 and 9. MIT has withdrawn this request because further analysis of projected operations shows that the steam load will be more efficiently met using the new CHP units, and additional operation of Boilers Nos. 7 and 9 will not be needed. Specifically, projected future operation (for model year 2023) shows that the steam generated by the CTG and HRSG units will be 1,446,663 MMBtu/year, and the steam generated by existing boilers will only be 2,154 MMBtu/year.

A further benefit is the collection of rainwater on the roof of the expanded plant's new addition. This rainwater will be discharged to an existing holding basin (approximately 145,000 gallon capacity) located on the roof of Building N16. This water will be used in the facility's cooling towers and will not flow into the City of Cambridge storm water system. The reuse of storm water will reduce local flooding risks and the facility's burden on the City's water and storm water systems.

1.4 Outline of Application

The remainder of this application is organized as follows.

Section 2 provides a detailed description and estimate of emissions for the proposed CHP expansion.

Section 3 describes Prevention of Significant Deterioration (PSD) applicability to the project.

Section 4 is the Best Available Control Technology (BACT) Analysis for the CHP expansion.

Section 5 documents compliance with specific PSD requirements.

Appendices include air quality dispersion modeling results, supplemental information, calculation details, and technical information.

Section 2.0

Project Description

2.0 PROJECT DESCRIPTION AND EMISSIONS

2.1 Description of Project Site

MIT is a world-class educational institution which admitted its first students in 1865. Teaching and research, with relevance to the practical world as a guiding principle, continue to be its primary purpose. MIT is independent, coeducational, and privately endowed. Its five schools and one college encompass numerous academic departments, divisions, and degree-granting programs, as well as interdisciplinary centers, laboratories, and programs whose work cuts across traditional departmental boundaries.

As an academic and research facility, MIT has steam and electricity reliability needs that exceed those of typical industrial facilities. The MIT CUP has been sized to provide nearly 100% of the Institute's thermal and electrical needs during most operating and weather conditions. The thermal and electrical energy generated is used to maintain critical research facilities, laboratories, classrooms, and dormitories in the event of a power outage, gas curtailment, or other emergency.

The Central Utility Plant (CUP) is housed in Building 42 (N16, N16A, N16C and 43 on MIT campus maps), which is located between Vassar Street and Albany Street in Cambridge, MA. The new CTGs would be housed in an addition to Building 42 to be built on the site of an existing parking lot along Albany Street between the cooling towers and an existing parking garage. The addition would be approximately 184' x 118' by 63' above ground level (AGL) tall with two 167' AGL high flues centrally co-located in a common stack structure. There will be a flue for each CTG vented through its respective Heat Recovery Steam Generator (HRSG). The cold-start engine will be roof-mounted and will have its own exhaust vent above its housing (93.5' AGL). An aerial locus of the area around the new project is shown in Figure 2-1. The proposed new cogeneration addition and the proposed site for the new CTG stacks and new cold-start engine stack are shown.


Table 2-1 describes the key equipment at the CUP and lists the equipment designation abbreviations used in the operating permit (Application MBR-95-OPP-026).

LEGEND


- New Stack
- ▨ New Turbine Building

Scale 1:4,200
1 inch = 350 feet

0 175 350 Feet



Basemap: 2013 Orthophotography, MassGIS



MIT Cogeneration Project Cambridge, Massachusetts



Figure 2-1
Aerial Locus Map

Table 2-1 Key Existing Equipment at the MIT Plant

Turbine No. 1	ABB GT10 (GT-42-1A) and Heat Recovery Steam Generator No. 1 (HRSG-42-1B) (collectively the Cogeneration Unit)
Boiler No. 3	Wickes 2 drum type R dual fuel (BLR-42-3)
Boiler No. 4	Wickes 2 drum type R dual fuel (BLR-42-4)
Boiler No. 5	Riley type VP dual fuel (BLR-42-5)
Generator No. 01	Emergency Diesel Generator Caterpillar No. 3516B 2MW (DG-42-6)
Boiler No. 7	Indeck Dual Fuel firing natural gas with ULSD backup (BLR-42-7)
Boiler No. 9	Rentech Boiler rated at 125 MMBtu/hr firing natural gas with Ultra Low Sulfur Diesel (ULSD) backup (BLR-42-9)
Cooling Towers	Wet mechanical towers Nos. 7, 8, 9, 10, 11, 12, 13.

2.2 Project Description

The proposed project consists of two nominal 22 MW Solar Titan 250 CTGs fired primarily on natural gas. Backup ULSD will be used for up to the equivalent heat input of 48 hours per year for testing and up to the equivalent heat input of 168 hours per year including testing and periods when natural gas is interrupted by the supplier or is otherwise unavailable to be combusted in the equipment. Each CTG will exhaust to its own HRSG with a 134 MMBtu/hr (HHV) gas-fired duct burner. The HRSG will include SCR for NO_x control and an oxidation catalyst for CO and VOC control.

Pending approvals, MIT intends to begin installing the new CTGs in 2019 and complete installation and shakeout in late 2019 or early 2020. The existing Siemens CTG will be fully retired following completion of installation and shakeout for both of the new units in 2020. At no time will the existing Siemens CTG be operating at the same time as the new Solar Titan 250 CTGs.

In addition to the two new CTGs, MIT plans to add a 2 MW ULSD-fired cold-start engine unit to be used to start the CTGs in emergency conditions.

As a result of this project, existing Boilers Nos. 3, 4, and 5 will cease burning No. 6 fuel oil and will burn only natural gas, with ULSD as a backup fuel for up to the equivalent heat input of 48 hours per year for testing and up to the equivalent heat input of 168 hours per year including testing and periods when natural gas is unavailable.

Also, existing Boilers Nos. 7 and 9 will fire natural gas only, with ULSD as a backup fuel for up to the equivalent heat input of 48 hours per year for testing and up to the equivalent heat input of 168 hours per year including testing and periods when natural gas is unavailable. This is a substantial reduction in ULSD operating time from the current operating permit limit of 720 hours per year.

Technical specifications for the Solar Titan 250 CTG units are included in Appendix B – Part 1.

As an unrelated project, MIT has recently replaced cooling towers 3 and 4 with three new cooling towers (towers 11, 12, and 13). Cooling towers 1, 2, 5, and 6 are retired. Towers 7, 8, 9, and 10 will remain. The cooling tower replacements do not rely on the proposed project and vice-versa; the replacement cooling towers are not required for the proposed project to operate, and the proposed project does not need to be constructed for MIT to gain full use of the replacement cooling towers. Replacement of the cooling towers did not trigger Massachusetts plan approval thresholds (potential emissions less than one ton per year). The projects were funded and constructed separately. Based on a pre-application meeting with MassDEP on July 29, 2014, the changes to the cooling towers are addressed in the air quality dispersion modeling analysis for this project.

2.3 Source Emissions Discussion

The two new CTGs will emit products of combustion from the firing of natural gas or ULSD. Emissions are minimized through the use of clean burning fuels (natural gas with ULSD backup) and good combustion practices (Solar's *SoLoNOx* technology), in combination with post-combustion controls. Air emissions, including the natural gas-fired duct burner, are further reduced using Selective Catalytic Reduction (SCR) for post-combustion control of NO_x and an oxidation catalyst for post-combustion control of CO and VOC.

Because proposed ULSD use is very limited, the new CTGs have the opportunity to use dry low- NO_x combustors instead of water injection for natural gas firing. ULSD firing will make use of a separate combustor that uses water injection.

Emissions from the new cold-start engine will be minimized due to the anticipated low operating hours and burning of ULSD.

The existing boilers will have the same short-term emission rates as currently permitted, with the same emissions controls.

Potential short-term and long-term emission rates of the project are summarized below.

Table 2-2 Proposed Emission Rates for CTGs

Pollutant	Emission Rate, Natural Gas-fired	Emission Rate, ULSD-fired	Duct Burner Emission Rate (Natural Gas only)	Control Technology
Nitrogen oxides (NO _x)	2.0 ppm	9.0 ppm	0.011 lb/MMBtu	SCR
Carbon Monoxide (CO)	2.0 ppm	7.0 ppm	0.011 lb/MMBtu	Oxidation Catalyst
Volatile Organic Compounds (VOC)	1.7 ppm	7.0 ppm	0.03 lb/MMBtu	Oxidation Catalyst

Table 2-2 Proposed Emission Rates for CTGs (Continued)

Pollutant	Emission Rate, Natural Gas-fired	Emission Rate, ULSD-fired	Duct Burner Emission Rate (Natural Gas only)	Control Technology
Particulate Matter (PM/PM ₁₀ /PM _{2.5})	0.02 lb/MMBtu	0.04 lb/MMBtu	0.02 lb/MMBtu	Low ash fuels
Sulfur dioxide (SO ₂)	0.0029 lb/MMBtu	0.0016 lb/MMBtu	0.0029 lb/MMBtu	Low sulfur fuels
Carbon Dioxide (CO ₂ e) ³	119 lb/MMBtu	166 lb/MMBtu	119 lb/MMBtu	N/A
Ammonia (NH ₃)	2.0 ppm	2.0 ppm	2.0 ppm	SCR

ppm = parts per million (dry volume, corrected to 15% oxygen)

lb/MMBtu = pounds per million British Thermal Unit

Short-term NO_x, CO, VOC, and NH₃ emission rates are for full-load, steady-state operations.

Table 2-3 Proposed Project Potential Emissions in Tons Per Year [From Table C-10 of Appendix C]

	CTGs & Duct burners	Cold-start Engine	Total
NO _x	21.1	5.3	26.4
CO	15.1	0.33	15.4
VOC	20.9	0.17	21.0
PM/PM ₁₀ /PM _{2.5}	50.0	0.06	50.1
SO ₂	7.0	0.004	7.0
CO ₂ e	294,970	480	295,450

CO₂e emission rates are rounded to the nearest ten tons.

Boilers Nos. 3, 4, 5, 7 and 9 are part of the project but have no emissions increase. As such, they are not included in the potential emissions from the project.

The basis for each proposed emission limit is described in Section 4, and a summary of the proposed emission limits and compliance mechanisms is in Section 4.5. CHP systems using CTGs are not “off-the-shelf” items but instead are more customized to the specific application. The published specifications sheets for the Solar Titan 250 CTG are included in Appendix B – Part 1, and a vendor video is posted at <https://www.youtube.com/watch?v=gfXKgG84ITk>. Air emissions calculations to document

³ CO₂e emission factors are from 40 CFR Part 75 Appendix G

the short-term emission rates (Tables C-1 and C-2), long-term emission rates (Tables C-10), and stack exhaust parameters (Tables C-1, C-2, and C-3) for different conditions are in Appendix C.

Tables C-1 and C-2 in Appendix C calculates emission rates and exhaust parameters across a range of conditions. Key design inputs include CTG fuel input (MMBtu/hr) and exhaust flow (CTG outlet Flow Rate (ft³/min) at CTG Exhaust Temp. (°F)), provided by Solar for the ambient conditions (including elevation) and expected system back pressure associated with the HRSG, pollution control catalysts, ductwork, and stack. Duct burner fuel input (MMBtu/hr) and stack exhaust temperature are calculated by Vanderweil Engineers based on the HRSG system specification prepared by Vanderweil.

Detailed project design is continuing. Data provided by Solar and Deltak (HRSG vendor) in September 2016 for representative conditions show heat input data within 0.5% to 2% of the values in Appendix C (Tables C-1 and C-2) and exhaust flow data within 0.5 to 4.5% of the values in Appendix C (Tables C-1 and C-2). The current project design exhaust flows are higher than what was used in the air quality dispersion modeling (and therefore the modeled exhaust parameters have conservatively low exhaust flow and will tend to overstate impacts). MIT will operate the upgraded CUP in compliance with the proposed emission and operating limits in this application and will provide final design data prior to initiating construction.

In contrast, diesel engines such as the cold-start engine behave approximately the same irrespective of atmospheric conditions and the service they are placed in. They are relatively “off-the-shelf” items with published vendor specifications. MIT proposes to use the CAT Model DM8263 or equivalent as the cold-start engine; the published specification sheets for the CAT DM8263 are in Appendix B – Part 2.

2.4 Exhaust Design Configurations

Emissions from the existing Boilers Nos. 3, 4, and 5 are vented out the brick stack on the roof of the existing CUP. The existing CTG No. 1 stack and the emergency generator stack are also located on the roof of the CUP. Existing Boilers Nos. 7 and 9 are located adjacent to Building N16A at 60 Albany Street, across the railroad tracks from the main CUP building. Exhaust from both Boiler No. 7 and Boiler No. 9 is combined and vents through a common stack.

The two new CTGs with HRSGs and nonpolluting ancillary equipment will be located in an addition to Building 42 to be built on the site of an existing parking lot along Albany Street between the cooling towers and an existing parking garage⁴. The project layout is shown in Figure 2-1. There will be two 167' AGL high flues centrally co-located in a common stack structure. There will be a flue for each CTG vented through its respective HRSG system. The cold-start engine flue will be located atop its housing (93.5' AGL).

2.5 Project Schedule

Pending approvals, MIT intends to begin installing the new CTGs and cold-start engine in 2019 and complete installation and shakeout in late 2019 or early 2020. The existing Siemens CTG will be fully retired following completion of installation and shakeout for both of the new units in 2020. The fuel switch for Boilers Nos. 3, 4, and 5 will occur within 12 months of the startup of the new CTGs.

⁴ Ancillary equipment includes electrical switchgear and natural gas metering equipment. The electrical equipment will not contain any sulfur hexafluoride (SF₆).

Section 3.0

PSD Applicability

3.0 PSD APPLICABILITY

Under federal and state air laws, the MassDEP and the EPA have promulgated air quality regulations that establish ambient air quality standards and emission limits. These standards and limits impose design constraints on new facilities and provide the basis for an evaluation of the potential impacts of proposed projects on ambient air quality. This section briefly describes these regulations and their relevance to the proposed expansion of the CUP.

Prevention of Significant Deterioration review is a federally mandated program for review of new major sources of criteria pollutants or major modifications to existing sources. In Massachusetts, as of April 2011, MassDEP has “full responsibility for implementing and enforcing the federal PSD regulations.”

The project as a whole triggers PSD Major Modification thresholds as follows:

- ◆ MIT is an existing major stationary source of air emissions per the federal PSD program at 40 CFR 52.21 (b)(1)(i), with potential emissions of one or more PSD pollutants above 100 tons/year for a facility with combinations of fossil-fuel boilers totaling more than 250 MMBtu/hr heat input.
- ◆ The project per 40 CFR 52.21 (b)(52) is the installation of the CTGs and associated HRSGs, the cold-start engine, and the change from No. 6 oil firing to ULSD firing in Boilers Nos. 3, 4, and 5. The restriction of ULSD operations in Boilers Nos. 7 and 9 is not a physical change or change in the method of operation. For purposes of PSD applicability review, to be conservative the project emission rates in Table 3-1 below include emissions from the recently-installed, unrelated cooling tower installation.
- ◆ Per 40 CFR 52.21(a)(2)(iv), a project is a major modification for a regulated New Source Review (NSR) pollutant if it causes two types of emissions increases - a significant emissions increase, and a significant net emissions increase.
- ◆ The project will create a significant emissions increase per 40 CFR 52.21(b)(23)(i) for CO_{2e}, PM₁₀ and PM_{2.5}. The emissions from the project are compared to PSD thresholds in Table 3-1.
- ◆ The project will also create a significant net increase for CO_{2e}, PM₁₀ and PM_{2.5}, as there are no contemporaneous emissions decreases that are enforceable as a practical matter per 40 CFR 52.21(b)(3)(vi).

Therefore, the project will be a major modification of an existing major source, subject to the requirement to obtain a PSD permit.

Table 3-1 Comparison of Project Emissions to PSD Triggers

Pollutant	Estimated Potential Emission Rates (tpy)	Significant Emission Rate (tpy)	Significant?
NO _x	26.4	40	No
CO	15.4	100	No
VOC	21.0	40	No
PM ₁₀	51.0	15	Yes
PM _{2.5}	51.0	10	Yes
SO ₂	7.0	40	No
CO ₂ e	295,450	75,000	Yes
Lead	Negligible	0.6	No
Fluorides	Negligible	3	No
Sulfuric Acid Mist	5.4	7	No
Hydrogen Sulfide	None expected	10	No
Total reduced sulfur	None expected	10	No
Reduced sulfur compounds	None expected	10	No

The project is not expected to emit any other regulated NSR pollutants as defined in 40 CFR 52.21 (b)(50); that is: pollutants with standards promulgated under Section 111 of the Clean Air Act Amendments of 1990 and not listed above, Class I or II ozone-depleting substances regulated subject to a standard promulgated under or established by Title VI of the Clean Air Act Amendments of 1990, and pollutants otherwise subject to regulation under the Clean Air Act Amendments of 1990 as defined in paragraph 40 CFR 52.21 (b)(49) and not listed above.

The PSD regulations define “minor source baseline date” at 40 CFR 52.21(b)(14)(ii) as “the earliest date after the trigger date on which... a major modification subject to 40 CFR 52.21... submits a complete application.” Therefore, if the minor source baseline date has not been established for the baseline area, this application will establish the baseline date when it is determined to be complete. EPA has established increment standards for PM₁₀ and PM_{2.5}. The project will comply with all applicable PSD requirements including demonstrating BACT and complying with all NAAQS (U.S. National Ambient Air Quality Standards) and PSD increments.

Section 4.0

Best Available Control Technology (BACT) Analysis

4.0 BEST AVAILABLE CONTROL TECHNOLOGY (BACT) ANALYSIS

The MIT CHP expansion will meet Massachusetts and federal BACT through the use of clean fuels (natural gas with ULSD backup), efficient combustion, and post-combustion controls (Selective Catalytic Reduction and oxidation catalyst). The applicable requirements are discussed in detail in this Section, followed by descriptions of how BACT is applied for each separate PSD-regulated pollutant.

4.1 PSD BACT Applicability

The PSD regulations include (at 40 CFR 52.21(j)(3)) a requirement to “apply best available control technology for each regulated NSR pollutant for which it would result in a significant net emissions increase.”

Federal BACT does not apply to the boilers because per 40 CFR 52.21(j)(3) BACT “applies to each proposed emissions unit at which a net emissions increase in the pollutant would occur as a result of a physical change or change in the method of operation in the unit.” There is no net emissions increase of PM_{2.5}, PM₁₀, and CO_{2e} from the boilers (and no physical change or change in the method of operation for Boilers Nos. 7 and 9).

Regarding Boilers Nos. 3, 4, and 5, the change from No. 6 oil to ULSD will reduce emissions of CO_{2e} because ULSD has a lower carbon content. The EPA emission factors at 40 CFR 98 Table C-1 are as follows:

- ◆ No. 6 oil: 75.10 kg CO₂/MMBtu
- ◆ ULSD: 73.96 kg CO₂/MMBtu

EPA also states “Particulate matter will generally be reduced when a lighter grade of fuel oil is burned” (EPA AP-42 Compilation of Air Pollutant Emission Factors, Section 1.3.4; factors show a decrease in PM emissions of more than 75%). Between burning the lighter grade of fuel oil and dramatically restricting the amount of fuel oil burned (168 hours/year total), the fuel change will not create a net emissions increase of particulate matter in Boilers Nos. 3, 4, or 5.

The reasons listed above are sufficient to document that boiler emissions will not increase, and therefore BACT does not apply to Boilers Nos. 3, 4, or 5. Additional documentation of non-applicability is as follows: The PSD regulations’ definition of “net emissions increase” does not apply in this context, as it is addressing source-wide applicability. A review of

EPA's Applicability Determination Index⁵ finds a single reference to 40 CFR 52.21(j)⁶ and that reference states "This section clearly intends that technology review be assessed on an emissions unit rather than on a plant-wide basis." That said, on the basis of "each proposed emission unit" the definition of "net emissions increase" at 40 CFR 52.21(b)(3)(i)(a) refers to the "Actual-to-projected-actual applicability test for projects that only involve existing emissions units" at 40 CFR 52.21(a)(2)(iv)(c). Following the procedures in the actual-to-projected-actual applicability test for projects that only involve existing emissions units, the baseline actual emissions (the average rate, in tons per year, at which the emissions unit actually emitted the pollutant during any consecutive 24-month period selected by the owner or operator within the 10-year period immediately preceding the date a complete permit application is received by the Administrator) for 1/1/13 – 12/31/2014 was 11.4 tons per year of PM10 and PM2.5 total from all three boilers (3.21 tons per year from Boiler No. 3, 3.69 tons per year from Boiler 4, and 4.51 tons per year from Boiler 5). Of this, 10.0 tons/year were associated with No. 6 oil firing (calculations located in Table C-13 Appendix C). Projected actual emissions conservatively do not include any projected decrease in operation, although the analysis described in Section 4.4.4 shows a large predicted decrease in boiler use after installation of the CTG/HRSG systems. The projected actual emissions do account for the restriction to 48 hours of ULSD maintenance and testing, and the projection that no natural gas interruption will occur (so no ULSD use outside of maintenance and testing will occur). Replacing No. 6 oil with natural gas (and 48 hours of ULSD) provides a projected actual emission rate of 3.2 tons/year total from the three boilers (1.0 tons per year from Boiler 3, 1.0 tons per year from Boiler 4, and 1.2 tons per year from Boiler 5) (calculations located in Table C-13 Appendix C). Therefore, on an actual-to-projected actual basis, there is no net emissions increase at the existing Boilers Nos. 3, 4, and 5.

4.2 PSD BACT

The PSD definition of BACT is similar to the Massachusetts definition.

"Best available control technology means an emissions limitation... based on the maximum degree of reduction... which the Administrator, on a case-by-case basis, taking into account energy, environmental, and economic impacts and other costs, determines is achievable for such source or modification through application of production processes or available methods, systems, and techniques, including fuel cleaning or treatment or innovative fuel combustion techniques for control of such pollutant."

⁵ (<https://cfpub.epa.gov/adi/index.cfm>)

⁶ (<https://cfpub.epa.gov/adi/pdf/adi-nsps-nb20.pdf>)

The pollutants subject to the PSD BACT requirement are PM2.5, PM10, and CO_{2e}. A formal top-down analysis is presented for particulate matter and CO_{2e}.

The objective of the project is to provide highly reliable and responsive electrical and thermal energy to the MIT campus. The basic design of the facility is the use of dual-fuel CTGs with HRSG systems (and supporting equipment) to provide the ability to balance thermal and electrical output to meet campus needs, to respond quickly to system upsets, and to start and operate independent of external energy supply during emergencies.

Per the EPA GHG Guidance: “clean fuels which would reduce GHG emissions should be considered, but EPA has recognized that the initial list of control options for a BACT analysis does not need to include ‘clean fuel’ options that would fundamentally redefine the source.” Since “BACT should generally not be applied to regulate the applicant’s purpose or objective for the proposed facility,” this BACT analysis focuses on options that could be used with a system providing reliable and responsive electrical and thermal energy.

MIT proposes to burn natural gas, which is the cleanest fuel available that can provide a reliable energy supply to the MIT campus in the needed amounts. MIT is contracting for a firm, uninterruptable natural gas supply. However, to meet the objective of providing a highly reliable energy supply, the cogeneration system must have a backup fuel that can be stored onsite and called on reliably if natural gas cannot be used. MIT proposes to use ULSD as that backup fuel; ULSD is the cleanest available fuel that can be stored onsite in the quantities needed and called upon reliably without an external energy supply.

4.3 Particulate Matter BACT for the CTGs and HRSGs

Because particulate matter emissions are subject to both federal and Massachusetts BACT requirements, this BACT analysis follows the federal guidance in the New Source Review Workshop Manual, Prevention of Significant Deterioration and Nonattainment Area Permitting, USEPA Draft October 1990 document. Specific guidance from that document is included in boxes below, followed by MIT’s analysis based on the guidance. The BACT analysis follows the guidance in the Northeast States for Coordinated Air Use Management (NESCAUM) BACT Guideline dated June 1991, as well as the referenced NSR Workshop Manual.

Available fuels and emission controls are the same for the CTGs and the duct burners. Also, data on emission limits achieved-in-practice are generally based on total emissions from CTG and duct burner firing. This BACT analysis therefore applies to the combined emissions of the CTGs and the duct burners.

4.3.1 BACT Applicability

...the BACT determination must separately address..., for each regulated pollutant... air pollution controls for each emissions unit or pollutant emitting activity subject to review.

While “particulate matter” is listed as a regulated pollutant, EPA rescinded the national ambient air quality standard for particulate matter in favor of a PM₁₀ standard in 1987, and recent statutory and regulatory provisions impose controls and limitations on PM₁₀, not particulate matter.

Particulate matter consists of two broad categories: filterable PM and condensable PM. Based on recent guidance from the MassDEP on other projects, this analysis addresses total particulate, filterable plus condensable.

PM_{2.5} is a subset of PM₁₀; there is very limited data on PM_{2.5} emission limits achieved in practice, and there is considerable uncertainty regarding PM_{2.5} test methods. Much or most of the filterable PM₁₀ emissions will be 2.5 microns or smaller, and all of the condensable PM₁₀ emissions are generally considered 2.5 microns or smaller. BACT techniques for PM_{2.5} control will be the same as for PM₁₀ control. For all of these reasons, this application makes the conservative assumption that all PM₁₀ emitted from the CHP expansion is PM_{2.5}. The BACT emission rates reviewed in this analysis are for PM, PM₁₀ and PM_{2.5}. Throughout this application, the term PM refers to PM/PM₁₀/PM_{2.5}, filterable plus condensable.

4.3.2 Step 1-Identify All Control Technologies

The first step in a "top-down" analysis is to identify, for the emissions unit in question (the term "emissions unit" should be read to mean emissions unit, process or activity), all "available" control options. Available control options are those air pollution control technologies or techniques with a practical potential for application to the emissions unit and the regulated pollutant under evaluation.

In reference to the MIT project, available control options are:

- ◆ Post-combustion control, including:
 - Fabric filtration
 - Electrostatic precipitation
 - Wet scrubbing
 - Cyclone or multicyclone collection
 - Side-stream separation

- ◆ The use of clean fuels and good combustion practices

This project will use natural gas as the primary fuel. Natural gas is the cleanest fuel that can be reliably supplied in the quantities required. ULSD will be used as a secondary fuel source in the unlikely event natural gas is not available. The CTG design will utilize Solar's SoLoNOx technology to ensure optimal combustion resulting in minimal CO emissions. Details of how this technology works is included in Appendix B – Part 1.

Air pollution control technologies and techniques include the application of production process or available methods, systems, and techniques, including fuel cleaning or treatment or innovative fuel combustion techniques for control of the affected pollutant.

With reference to the list above, MIT's proposed project includes fuel combustion techniques and the use of clean fuels (natural gas with ULSD backup), which can be considered "fuel cleaning or treatment."

This includes technologies employed outside the United States.

MIT is unaware of technologies employed outside the United States that are not employed inside the United States.

... in some circumstances inherently lower-polluting processes are appropriate for consideration as available control alternatives.

MIT's proposed use of clean fuels (natural gas with ULSD backup) can be considered an inherently lower-polluting process.

The control alternatives should include not only existing controls for the source category in question, but also (through technology transfer) controls applied to similar source categories and gas streams, and innovative control technologies.

With regard to MIT's proposed project, the source category in question is the production of electricity in a CTG. Existing particulate controls are limited to the use of clean fuels (natural gas with ULSD backup) and good combustion techniques.

Through technology transfer, controls applied to similar source categories (residual oil or solid fuel combustion) include the post-combustion control options listed above.

Technologies required under lowest achievable emission rate (LAER) determinations are available for BACT purposes and must also be included as control alternatives and usually represent the top alternative.

MIT has reviewed the EPA RACT/BACT/LAER Clearinghouse and other online data sources which include LAER determinations. The top control technology found is the use of clean fuels (natural gas with ULSD backup) and good combustion techniques.

4.3.3 *Step 2-Eliminate Technically Infeasible Options*

In the second step, the technical feasibility of the control options identified in step one is evaluated with respect to the source-specific (or emissions unit-specific) factors.

Each identified control option is evaluated with respect to emissions unit-specific factors below.

- ◆ Post-combustion control: *technically infeasible*
- ◆ Use of clean fuels (natural gas with ULSD backup) and good combustion practices (Appendix B – Part 1): *technically feasible*

A demonstration of technical infeasibility should be clearly documented and should show, based on physical, chemical, and engineering principles, that technical difficulties would preclude the successful use of the control option on the emissions unit under review. Technically infeasible control options are then eliminated from further consideration in the BACT analysis.

With regard to MIT's proposed project, clear documentation of technical difficulties is demonstrated below for each technically infeasible control option:

- ◆ **Post-combustion control.** All available post-combustion controls have limits in terms of how clean an exhaust concentration they can achieve. The minimum outlet concentration achievable using post-combustion control is generally higher than the inlet concentration achievable using clean fuels (natural gas with ULSD backup). Therefore, the installation of post-combustion controls will not reduce particulate emissions for the proposed project.

For example, in cases where the level of control in a permit is not expected to be achieved in practice (e.g., a source has received a permit but the project was cancelled, or every operating source at that permitted level has been physically unable to achieve compliance with the limit), and supporting documentation showing why such limits are not technically feasible is provided, the level of control (but not necessarily the technology) may be eliminated from further consideration.

MIT has made a good faith effort to compile appropriate information from available information sources (per EPA guidance). Information sources considered included:

- ◆ EPA's RACT/BACT/LAER Clearinghouse and Control Technology Center - Information from the Clearinghouse⁷ was reviewed. No facilities are identified that use post-combustion control on a CTG smaller than 25 MW that fires natural gas and/or distillate oil;
- ◆ Best Available Control Technology Guideline - South Coast Air Quality Management District - The Guideline⁸ has no guidance for particulate matter;
- ◆ Control technology vendors - An online review of vendors⁹ does not find any offering post-combustion control for particulate matter from CTGs firing natural gas or distillate oil;
- ◆ Federal/State/Local new source review permits and associated inspection/performance test reports - A good faith effort to review permits available online found information as presented in Table 4-1 below;
- ◆ Environmental consultants - Consultants at Epsilon Associates, Inc. reviewed available information on current and past projects;
- ◆ Technical journals, reports and newsletters, air pollution control seminars - A review of papers posted by the Air and Waste Management Association¹⁰ found no recent papers associated with particulate emission rates achievable from gas and ULSD-fired CTGs; and
- ◆ EPA's policy bulletin board - A review of the online Office of Air and Radiation (OAR) Policy and Guidance¹¹ websites found no references to specific recent BACT emission limits or technologies for particulate matter from gas and ULSD-fired CTGs. Particulate control from boilers was reviewed in the development of the National Emissions Standards for Hazardous Air Pollutants (NESHAP) rules for industrial, commercial, and institutional boilers under 40 CFR 63¹². EPA concluded

⁷ <http://cfpub.epa.gov/rblc/> reviewed July 2014

⁸ <http://aqmd.gov/home/permits/bact/guidelines> reviewed March 2014

⁹ <http://www.icac.com/?Publications>, search March 2014 for particulate matter control equipment applicable to natural gas or ULSD combustion.

¹⁰ <http://awma.org/search> and <http://portal.awma.org/store/>, March 2014. Searches for "Particulate & Natural Gas" and "Particulate & Distillate." No applicable papers were identified.

¹¹ <http://epa.gov/ttn/oarpg/new.html> and <http://epa.gov/ttn/oarpg/ramain.html>. reviewed March 2014

¹² EPA-452/F-03-031

that, for boilers firing gaseous fuel with liquid fuel backup, “no existing units were using control technologies that achieve consistently lower emission rates than uncontrolled sources.”

The EPA Clearinghouse was queried for CTGs firing natural gas or distillate oil, operating in combined-cycle or cogeneration mode, sized smaller than 25 MW. Facilities listed in the Clearinghouse as having only filterable particulate matter limits were excluded. Additional facilities were added based on Epsilon experience.

No projects comparable to MIT’s proposed project were found that used post-combustion control. Key projects are summarized as follows:

Table 4-1 Summary of Available Data on PM CTG Emission Limits

Determination	PM emission limit	Converted
CARB Database determination for Los Angeles County Sanitation District, 9.9 MW Solar combustion turbine, combined cycle, firing landfill gas	5.7 lb/hr PM	~0.038 lb/MMBtu at full load
RBLC determination for Signal Hills Wichita Falls Power (TX), 20 MW turbine, combined cycle	1.04 lb/hr PM firing natural gas (type not specified, assume FILTERABLE)	~0.0052 lb/MMBtu at full load (type not specified, assume FILTERABLE)
RBLC determination for Maui Electric, 20 MW turbine, combined cycle	19.7 lb/hr PM firing No. 2 fuel oil	~0.099 lb/MMBtu firing No. 2 fuel oil
NYSDEC operating permit for Cornell University, 15 MW Solar turbine CHP	0.022 lb/MMBtu PM ₁₀ (filterable & condensable) firing natural gas, 0.04 lb/MMBtu firing ULSD (other limits also listed).	0.022 lb/MMBtu PM ₁₀ (filterable & condensable) firing natural gas, 0.04 lb/MMBtu firing ULSD
Conditional Approval for MassDEP operating permit for UMass Amherst, 10 MW Solar turbine CHP	0.03 lb/MMBtu PM ₁₀ firing natural gas); 0.036 lb/MMBtu PM ₁₀ firing diesel.	0.03 lb/MMBtu PM ₁₀ firing natural gas); 0.036 lb/MMBtu PM ₁₀ firing diesel.

Table 4-1 Summary of Available Data on PM CTG Emission Limits (Continued)

Determination	PM emission limit	Converted
MassDEP operating permit for Gillette Boston, Solar Taurus 70 turbine CHP	3.4 lb/hr PM firing natural gas (with and without duct burning); 4.5 lb/hr PM firing ULSD.	The Gillette Boston application states the emission limits are based on 0.022 lb/MMBtu firing natural gas & 0.037 lb/MMBtu firing ULSD, but that does not appear to correspond to the rated capacity of the permitted equipment. Based on available equipment data, the calculated limits would be 0.017 lb/MMBtu firing natural gas with the duct burner and 0.053 lb/MMBtu firing ULSD.
MassDEP operating permit for UMass Medical Center, Solar Taurus 70 turbine CHP	1.9 lb/hr firing natural gas without duct burning; 2.34 lb/hr firing natural gas with duct burning; 2.88 lb/hr firing ULSD	~0.021 lb/MMBtu firing natural gas ~0.034 lb/MMBtu firing ULSD
MassDEP operating permit for MATEP, Alston turbine & HRSG	0.025 lb/MMBtu firing gas, 0.040 lb/MMBtu firing ULSD (interim limits)	0.025 lb/MMBtu firing gas 0.040 lb/MMBtu firing ULSD
MassDEP operating permit for Biogen, Solar Taurus 60 turbine & HRSG	0.028 lb/MMBtu PM firing natural gas (with and without duct burning); 0.056 lb/MMBtu PM firing ULSD	0.028 lb/MWh firing natural gas 0.056 lb/MWh firing ULSD
MassDEP operating permit for Harvard, Solar Taurus 70 turbine & HRSG (not yet constructed)	3.3 lb/hr firing natural gas with or without duct burning; 3.7 lb/hr firing ULSD	0.022 lb/MMBtu firing natural gas 0.04 lb/MMBtu firing ULSD
RBLC Draft Determination for Lenzing Fibers, Inc. (AL) 25 MW Gas Turbine with HRSG	0.0075 lb/MMBtu filterable PM firing natural gas	0.0075 lb/MMBtu filterable PM firing natural gas

4.3.4 Step 3-Rank Remaining Control Technologies By Control Effectiveness

In step 3, all remaining control alternatives not eliminated in step 2 are ranked and then listed in order of overall control effectiveness for the pollutant under review, with the most effective control alternative at the top. A list should be prepared for each pollutant and for each emissions unit (or grouping of similar units) subject to a BACT analysis. The list should present the array of control technology alternatives and should include the following types of information:

- control efficiencies (percent pollutant removed);
- expected emission rate (tons per year, pounds per hour);
- expected emissions reduction (tons per year);
- economic impacts (cost effectiveness);
- environmental impacts (includes any significant or unusual other media impacts (e.g., water or solid waste), and, at a minimum, the impact of each control alternative on emissions of toxic or hazardous air contaminants);
- energy impacts.

With regard to MIT's proposed project, the only remaining control technology is the use of clean fuels (natural gas with ULSD backup) and efficient combustion. Requested data is summarized below.

Table 4-2 Summary of PM Effectiveness of Clean Fuels (Natural Gas with ULSD Backup) & Efficient Combustion

Control efficiencies (percent pollutant removed)	Not applicable (inherently clean technology used)
Expected emission rate (tons per year, pounds per hour)	Per the calculations in Appendix C (Tables C-1, C-2, and C-10), potential emissions are a maximum of 7.1 lb/hr firing gas, 11.9 lb/hr firing ULSD in each CTG (and gas in the duct burner), and 50 tons/year combined total. Expected emission rates are lower.
Expected emissions reduction (tons per year)	Not applicable (inherently clean technology used)
Economic impacts	In most cases, clean fuels (natural gas with ULSD backup) are more expensive than higher-polluting fuels. As of the time of this application, natural gas prices are low on an annual basis but high during peak winter use periods.
Environmental impacts (includes any significant or unusual other media impacts (e.g., water or solid waste), and, at a minimum, the impact of each control alternative on emissions of toxic or hazardous air contaminants)	The use of clean fuels (natural gas with ULSD backup) can have lower water, wastewater, solid waste, and toxic/hazardous air impacts than higher-polluting fuels.
Energy impacts	Energy use is a function of system efficiency; the proposed CHP is an efficient CTG with heat recovery and low energy impacts.

4.3.5 *Steps 4 & 5-Select BACT*

If the applicant accepts the top alternative in the listing as BACT, the applicant proceeds to consider whether impacts of unregulated air pollutants or impacts in other media would justify selection of an alternative control option. If there are no outstanding issues regarding collateral environmental impacts, the analysis is ended and the results proposed as BACT. In the event that the top candidate is shown to be inappropriate, due to energy, environmental, or economic impacts, the rationale for this finding should be documented for the public record. Then the next most stringent alternative in the listing becomes the new control candidate and is similarly evaluated. This process continues until the technology under consideration cannot be eliminated by any source-specific environmental, energy, or economic impacts which demonstrate that alternative to be inappropriate as BACT. The most effective control option not eliminated is proposed as BACT for the pollutant and emission unit under review.

Consistent with the analysis presented above, MIT proposes the use of clean fuels (natural gas with ULSD backup) and efficient combustion, achieving a total PM/PM₁₀/PM_{2.5} emission rate of 0.02 lb/MMBtu firing gas and 0.04 lb/MMBtu firing ULSD, as the top alternative for BACT. These limits are comparable to (and slightly lower than) recent projects of similar size (Cornell, UMass Amherst, Gillette, and Harvard). The proposed BACT emission limitations are the maximum degree of reduction achievable, taking into account the scarcity of comparable units with emission limits demonstrated-in-practice, the continued concerns with the accuracy and repeatability of the stack test method (EPA Method 202), and the limited technical opportunities to directly control and reduce particulate emissions.

4.4 **Greenhouse Gas BACT**

Similar to particulate matter, GHG emissions are subject to both federal and Massachusetts BACT requirements, so this BACT analysis follows the New Source Review Workshop Manual and the NESCAUM BACT Guideline. In addition, this BACT analysis refers to the March 2011 EPA document "PSD and Title V Permitting Guidance for Greenhouse Gases."¹³

Available fuels and emission controls are the same for the CTGs and the duct burners. Also, data on emission limits achieved-in-practice tend to be based on total emissions from CTG and duct burner firing. This BACT analysis therefore applies to the combined emissions of the CTGs and the duct burners in the proposed project.

¹³ EPA-457/B-11-001, <http://www.epa.gov/nsr/ghgdocs/ghgpermittingguidance.pdf>

4.4.1 *BACT Applicability*

...the BACT determination must separately address..., for each regulated pollutant... air pollution controls for each emissions unit or pollutant emitting activity subject to review.

The PSD regulations at 40 CFR 52.21(b)(49)(i) define GHG as a single pollutant, an aggregate of the following six gases: carbon dioxide (CO₂), nitrous oxide (N₂O), methane (CH₄), hydrofluorocarbons (HFCs), perfluorocarbons (PFCs), and sulfur hexafluoride (SF₆). Of these, HFCs, PFCs, and SF₆ are not products of combustion and will not be emitted by the proposed expanded CUP. The N₂O will be controlled as NO_x by the proposed project's Selective Catalytic Reduction (SCR), and the CH₄ will be controlled by good combustion practices. Therefore, this BACT analysis focuses on CO₂ emissions as the primary GHG component. Emissions calculations are as CO₂-equivalent, or CO₂e.

4.4.2 *Step 1-Identify All Control Technologies*

The first step in a "top-down" analysis is to identify, for the emissions unit in question (the term "emissions unit" should be read to mean emissions unit, process or activity), all "available" control options. Available control options are those air pollution control technologies or techniques with a practical potential for application to the emissions unit and the regulated pollutant under evaluation.

With regard to MIT's proposed project, available control options are:

- ◆ Carbon Capture Sequestration - (CCS)
- ◆ The use of clean fuels (natural gas with ULSD backup), good combustion practices (Appendix B – Part 1), and efficient operation

Air pollution control technologies and techniques include the application of production process or available methods, systems, and techniques, including fuel cleaning or treatment or innovative fuel combustion techniques for control of the affected pollutant.

With reference to the list above, MIT's proposed project includes fuel combustion techniques and the use of clean fuels (natural gas with ULSD backup), which can be considered "fuel cleaning or treatment."

This list includes technologies employed outside the United States.

MIT is unaware of technologies employed outside the United States that are not employed inside the United States.

...in some circumstances inherently lower-polluting processes are appropriate for consideration as available control alternatives.

With regard to MIT's proposed project, the use of clean fuels (natural gas with ULSD backup) can be considered an inherently lower-polluting process.

The control alternatives should include not only existing controls for the source category in question, but also (through technology transfer) controls applied to similar source categories and gas streams, and innovative control technologies.

The source category in question is the production of electricity in a CTG. Through technology transfer, controls applied to similar source categories (residual oil or solid fuel combustion) include the control options listed above.

Technologies required under lowest achievable emission rate (LAER) determinations are available for BACT purposes and must also be included as control alternatives and usually represent the top alternative.

MIT has reviewed the EPA RACT/BACT/LAER Clearinghouse and other online data sources which include LAER determinations. The top control technology found is the use of clean fuels (natural gas with ULSD backup) and good combustion techniques.

A RACT/BACT/LAER Clearinghouse search finds a single facility with GHG emission limits¹⁴. Midwest Fertilizer in Mount Vernon, IN, has two "open-simple cycle CTGs with heat recovery," each with a limit of 12,666 "BTU/KW-H, MINIMUM". It is not clear that this limit is comparable to the proposed project.

4.4.3 Step 2-Eliminate Technically Infeasible Options

In the second step, the technical feasibility of the control options identified in step one is evaluated with respect to the source-specific (or emissions unit-specific) factors.

Each identified control option is evaluated with respect to emissions unit-specific factors below.

- ◆ Carbon Capture Sequestration: *technically infeasible*
- ◆ Use of clean fuels (natural gas with ULSD backup), good combustion practices (Appendix B – Part 1), and energy efficiency: *technically feasible*

¹⁴ <http://cfpub.epa.gov/rblc/index.cfm>, Categories 16.210 and 16.290 (Small Combustion Turbines <25 MW, Combined Cycle and Cogeneration, natural gas and liquid fuel), pollutants CO₂ or CO₂e over the last 10 years.

A demonstration of technical infeasibility should be clearly documented and should show, based on physical, chemical, and engineering principles, that technical difficulties would preclude the successful use of the control option on the emissions unit under review. Technically infeasible control options are then eliminated from further consideration in the BACT analysis.


With regard to MIT's proposed project, clear documentation of technical difficulties is demonstrated below for each technically infeasible control option:

- ◆ **Carbon Capture Sequestration.** For CCS to be technically feasible, each of the following steps needs to be technically feasible: 1) capture; 2) compression; 3) transport; and 4) sequestration.
 - 1) **Capture.** Carbon capture is technically infeasible for the MIT project site. There is insufficient space for the required absorption system (more than 5 acres would be needed¹⁵). Also, the absorption process has not been demonstrated on a power generating unit beyond the pilot-scale or side-stream scale. Finally, the handling of the absorption media (which could be ammonia, monoethanolamine, or other amine solution) may not be feasible in an urban setting.
 - 2) **Compression.** Compressing the CO₂ to about 2,000 pounds per square inch for transport may or may not be technically feasible at the MIT site. There may or may not be space for the required equipment, and it may be impossible to operate the needed compressors and comply with Cambridge noise regulations.
 - 3) **Transport.** The transport of CO₂ from the MIT site is technically infeasible because the necessary approvals could not be obtained for a pipeline of pressurized gas or supercritical fluid CO₂ through Cambridge streets.
 - 4) **Sequestration.** Sequestration of CO₂ from the MIT site is technically infeasible. Sequestration is the injection and long-term storage of CO₂ in geologic formations such as coal seams and oil & gas reservoirs. There are no candidate geologic formations near enough to make the process feasible. As shown in Figure 4-1, the nearest potential geologic formation is at the

¹⁵ Sizing estimated from permits for CO₂ recovery plant at Indiantown Cogeneration, Florida Department of Environmental Protection Project Number [0850102-003-AC](#).

Pennsylvania/New Jersey border over 200 miles away; proven CO₂ storage locations are much more distant. Sequestration has in any event not been demonstrated in practice for control of CO₂ from electric generation.

Figure 4-1 Potential CO₂ Sequestration Sites



Source: <http://www.epa.gov/climatechange/ccs/>

Also, the EPA 2011 GHG guidance notes:

...in cases where it is clear that there are significant and overwhelming technical (including logistical) issues associated with the application of CCS for the type of source under review (e.g., sources that emit CO₂ in amounts just over the relevant GHG thresholds...) a much less detailed justification may be appropriate and acceptable for the source. In addition, a permitting authority may make a determination to dismiss CCS for a small natural gas-fired package boiler, for example, on grounds that no reasonable opportunity exists for the capture and long-term storage or reuse of captured CO₂ given the nature of the project.

The proposed project's CTGs and duct burners emit CO₂ in amounts just over the relevant GHG thresholds and have a similar emission profile to a natural gas-fired package boiler.

Since most or all of the steps in CCS are not technically feasible for the MIT project, as shown above, CCS is not technically feasible.

- ◆ Use of clean fuels (natural gas with ULSD backup), good combustion practices (as described in Appendix B – Part 1), and energy efficiency: Technically feasible.

4.4.4 Step 3-Rank Remaining Control Technologies By Control Effectiveness

In step 3, all remaining control alternatives not eliminated in step 2 are ranked and then listed in order of overall control effectiveness for the pollutant under review, with the most effective control alternative at the top. A list should be prepared for each pollutant and for each emissions unit (or grouping of similar units) subject to a BACT analysis. The list should present the array of control technology alternatives and should include the following types of information:

- control efficiencies (percent pollutant removed);
- expected emission rate (tons per year, pounds per hour);
- expected emissions reduction (tons per year);
- economic impacts (cost effectiveness);
- environmental impacts (includes any significant or unusual other media impacts (e.g., water or solid waste), and, at a minimum, the impact of each control alternative on emissions of toxic or hazardous air contaminants);
- energy impacts.

With regard to MIT's proposed project, the only remaining control technology is the use of clean fuels (natural gas with ULSD backup) and efficient combustion. Requested data is summarized in Table 4-3 below.

Table 4-3 Summary of CO₂e Effectiveness of Clean Fuels (Natural Gas with ULSD Backup) & Efficient Combustion

Control efficiencies (percent pollutant removed)	Not applicable (inherently clean technology used)
Expected emission rate (tons per year, pounds per hour)	Per the calculations in Appendix C (Tables C-9 and C-10), potential emissions are 42,071 lb/hr firing gas, 51,167 lb/hr firing ULSD in each CTG (and gas in the duct burner), and 294,970 tons/year combined total.
Expected emissions reduction (tons per year)	Not applicable (inherently clean technology used)
Economic impacts	In most cases, clean fuels (natural gas with ULSD backup) are more expensive than higher-polluting fuels. As of the time of this application, natural gas prices are low on an annual basis but high during peak winter use periods.
Environmental impacts (includes any significant or unusual other media impacts (e.g., water or solid waste), and, at a minimum, the impact of each control alternative on emissions of toxic or hazardous air contaminants)	The use of clean fuels (natural gas with ULSD backup) can have lower water, wastewater, solid waste, and toxic/hazardous air impacts than higher-polluting fuels.
Energy impacts	Energy use is a function of system efficiency; the proposed CHP is an efficient CTG with heat recovery and low energy impacts.

The MIT project is designed to provide BACT for GHG by optimizing equipment size and efficiency to provide the most efficient electrical and thermal generation across the range of MIT's projected loads.

As part of its evaluation, MIT performed an hour-by-hour model of CUP operation (including the proposed CTGs, associated duct burners, and existing boilers) against projected MIT campus electric and thermal loads. This model was run for the entire project design period (2019-2030), with two different sets of assumptions for MIT campus electric and thermal loads. The model results consistently showed that a slightly smaller CTG model (Solar Titan 250) met MIT's needs with lower GHG. Both CTG/HRSG combinations had similar full load electric and thermal efficiencies. The key difference was the ability of the smaller CTG to effectively meet MIT's energy needs for more hours of the year using fuel fired in the CTG, allowing more hours of true cogeneration (where fuel is fired in the CTG to generate electricity, and the hot exhaust is used to generate useful thermal energy).

For the larger CTG configuration, there were more modeled hours when one CTG would be shut off and a larger portion of the campus energy needs would be met using grid electricity and duct firing.

Table 4-4 below provides an apples-to-apples comparison of two CTG configuration options and annotation explaining how the slightly smaller CTG is a better fit to maximize efficient cogeneration.

Table 4-4 Comparison of CHP Configurations

CTG Model	Total Run Time (2 CTGs) (hrs/year)	Total Generated Electric (MWh/yr)	Total Purchased Electric (MWh/yr)	Total CTG Gas Usage (MMBtu/yr)	Total HRSG Gas Usage (MMBtu/yr)	Steam Generated by CTG & HRSG (MMBtu/yr)	Total Existing Boiler Gas Usage (MMBtu/yr)
Solar T250	14,219	273,964	85,882	2,537,725	324,375	1,446,663	2,154
GE LM2500	11,695	234,421	125,115	2,353,174	337,896	1,463,185	1,675
Notes	The T250 CTGs can remain operating for more hours of the year, generating more electricity.		This results in lower electricity purchases, and lower GHG emissions from grid electricity.	More fuel is fired in the CTGs, and less in the HRSGs, allowing for more cogeneration.		For both cases, the CTGs and HRSGs provide almost all the campus steam needs. Existing boilers remain for reliability, but generally do not run.	

Basis: Projected 2023 MIT loads, as modeled

A summary spreadsheet is provided in Appendix C [Table C-14] which follows a sample calculation provided by the Massachusetts Department of Energy Resources (DOER) for the Massachusetts Environmental Policy Act (MEPA) process. This calculation compares, for the same amount of electricity and useful heat, the CO₂ emissions generated by the CHP versus the CO₂ emissions that would be generated by the import of electricity from the distribution grid and creation of the useful heat with conventional natural gas boilers. Using the same emission factors as were used in the MEPA process, the calculations show a net GHG reduction of 67,254 tons per year for the Solar Titan 250 and 59,863 tons per year for the GE LM2500. Since the Solar Titan 250 had a greater reduction in GHG emissions, it is the better fit to maximize efficient cogeneration and minimize GHG emissions.

The thermal efficiency of the HRSG will be significantly higher than that of an equivalent stand-alone boiler. MIT expects a 95% thermal efficiency in the final design. As such, MIT expects to use the HRSGs to meet most of the campus thermal energy needs, keeping the existing boilers as backup units. The thermal efficiency of the final design will be a function

of space constraints, the mechanical and structural considerations involved in integrating the HRSG with the rest of MIT's steam generation and supply equipment, catalyst placement requirements, etc.

4.4.5 *Steps 4 & 5-Select BACT*

If the applicant accepts the top alternative in the listing as BACT, the applicant proceeds to consider whether impacts of unregulated air pollutants or impacts in other media would justify selection of an alternative control option. If there are no outstanding issues regarding collateral environmental impacts, the analysis is ended and the results proposed as BACT. In the event that the top candidate is shown to be inappropriate, due to energy, environmental, or economic impacts, the rationale for this finding should be documented for the public record. Then the next most stringent alternative in the listing becomes the new control candidate and is similarly evaluated. This process continues until the technology under consideration cannot be eliminated by any source-specific environmental, energy, or economic impacts which demonstrate that alternative to be inappropriate as BACT. The most effective control option not eliminated is proposed as BACT for the pollutant and emission unit under review.

Consistent with the analysis presented above, MIT proposes the use of clean fuels (natural gas with ULSD backup) and efficient combustion, achieving a total CO₂e emission of 42,071 lb/hr firing gas and 51,167 lb/hr firing ULSD in the CTG (and gas in the duct burner) as the top alternative for BACT.

As discussed in Section 1.1, this CHP project will promote very efficient fuel use by generating both electricity and useful heat. Per the Massachusetts Energy and Environmental Affairs website¹⁶:

"A Combined Heat and Power (CHP) system (or cogeneration) can effectively and reliably generate useful heat and electric power using less fuel than a typical system that generates power only. CHP systems offer tremendous opportunities for customers with predictable and consistent heat and power needs (particularly large commercial, industrial, and institutional facilities), providing potential for significant economic savings and reductions in fuel consumption and greenhouse gas emissions."

¹⁶ <http://www.mass.gov/eea/energy-utilities-clean-tech/energy-efficiency/ee-for-business-institutions/combined-heat-power/>

4.5 Proposed CTG & HRSG Emission Limits

MIT proposes combined, mass-based emissions limits that reflect BACT as described above, for the following reasons:

- ◆ Based on guidance in the NSR Workshop Manual, emission limits should be “enforceable as a practical matter.” Because the duct burner emissions are entirely commingled with the CTG emissions, it is not practical to enforce separate permit limits.
- ◆ A well-designed CHP system is well matched to the electric and thermal loads it is serving, and lb/MWh limits, which are primarily intended to encourage electric power generation efficiency, would limit MIT’s ability to operate the facility in the most efficient manner to serve the electric, chilled water, and thermal demands of the campus. A limit on lb/MWh that includes thermal energy output could be complicated to calculate and could serve to reduce overall CUP plant efficiency by restricting MIT’s ability to operate its most efficient equipment as needed to respond to changing campus needs.

MIT’s proposal of mass-based emissions limits is consistent with the plan approvals recently issued by MassDEP for very similar projects (The Gillette Company, Boston, February 2, 2010, and Harvard University, Cambridge, October 29, 2013). The proposed emission limits and compliance mechanisms are summarized in Table 4-5, below. Supporting calculations are in Appendix C.

Table 4-5 Proposed Short-Term Emission Limits Per CHP Unit [Table C-1/C-2 of Appendix C]

Operating Condition	Pollutant	Proposed Limit Per CHP Unit	Proposed Compliance Method
Natural gas, with or without duct firing	PM (with duct firing)	7.14 lb/hr	Stack testing based on EPA Method 5/202 or other method approved by MassDEP, every 5 years.
	PM (without duct firing)	4.47 lb/hr	Stack testing based on EPA Method 5/202 or other method approved by MassDEP, every 5 years.
	CO ₂ e (with duct firing)	42,071 lb/hr	Initial calculations based on rated capacity, emission factor
	CO ₂ e (without duct firing)	26,103 lb/hr	Initial calculations based on rated capacity, emission factor
ULSD in CTG, with or without natural gas duct firing	PM (with duct firing)	11.9 lb/hr	Stack testing based on EPA Method 5/202 or other method approved by MassDEP, every 5 years.
	PM (without duct firing)	9.17 lb/hr	Stack testing based on EPA Method 5/202 or other method approved by MassDEP, every 5 years.
	CO ₂ e (with duct firing)	51,167 lb/hr	Initial calculations based on rated capacity, emission factor
	CO ₂ e (with duct firing)	35,198 lb/hr	Initial calculations based on rated capacity, emission factor

Emissions of CO₂e will be limited through the use of clean fuels (natural gas with ULSD backup) and efficient operation.

MIT proposes that the short-term limits, above, exclude startup periods, shutdown periods, and fuel changes. MIT will not operate the CTG/HRSG at power generating loads below 40% of CTG rated capacity, excluding startup or shutdown periods or fuel changes. Emissions of PM are not expected to be elevated relative to the proposed full-load steady-state emission rates in Table 4-5. Emissions of CO₂e are directly related to fuel use and will be lower during startup and shutdown periods than during full-load operation.

For long-term emission rates, MIT proposes to restrict operation on ULSD up to the equivalent heat input of 168 hours per year (268,800 gallons per year per CTG (calculations in Table C-12 of Appendix C)) including testing and periods when natural gas is unavailable. Proposed long-term emission limits are summarized in Table 4-6, below. The proposed long-term emission rates include startup periods, shutdown periods, and fuel changes. The proposed long-term emission rates are based on a heat input of 1,094,825 MMBtu/12-month rolling period for the two HRSGs (4,380 hours/year full load equivalent).

Table 4-6 Proposed Long-Term Emission Limits for the CTGs and HRSGs

PM	50.0 ton/12-month rolling period, based on stack test data and fuel use
CO ₂ e	294,970 ton/12-month rolling period, based on emission factors and fuel use

MIT requests that the approval avoid limits that are linked to energy production (pounds per megawatt-hour or lb/MWh limits). The MIT CUP supplies steam, chilled water, and/or electricity to over 100 buildings on campus. The proposed project is designed to be integrated operationally into the existing CUP system that provides steam, chilled water, and electricity through a variety of production equipment. The combustion equipment process flow diagram is included in Appendix B Part 3. Imposing specific pounds per megawatt-hour (lb/MWh) limits on individual generating units would either ignore the useful heat generated by the CHP system or would require a real time analytical model to account for the thermal energy generated. During any period of time, and at any given moment of the day, there is a range of production equipment in service as required by ever-changing campus demands.

In summary, tracking lb/MWh emissions against a limit would be complicated and would yield data that would be subject to various inaccuracies and assumptions, limiting its value as an indicator of compliance. Electrical generation efficiency is only one element of a properly-designed CHP system. The overall CHP project efficiency is based on the combination of electric power and thermal heat.

4.6 BACT for Cold-Start Engine

MIT is proposing to install a 2 MW engine in order to meet the minimum requirements necessary to start up the CTG units during a black-out situation. The cold-start engine is intended to be used to provide power to one CTG and its supporting equipment during a black-out situation in order to start up the CUP facility. As such, the engine is required to output enough power to meet the requirements to get one CTG up and running. MIT determined that the minimum engine size required to perform this function was the 2 MW unit. This determination is based on the estimated electric loads for the different components that the engine would serve, which are listed in Appendix B – Part 2. The cold-start engine falls within the range of sources subject to the MassDEP Environmental Results Program (ERP) Standards for emergency engines and turbines at 310 CMR 7.26(42). The ERP limitations for emergency engines and turbines mandate compliance with the applicable emission limits set by the US EPA for non-road engines (40 CFR 89), use of ULSD fuel and hours of operation limited to no more than 300 per 12-month rolling period. MIT will obtain the appropriate engine supplier certification for this unit. These design and operating restrictions constitute BACT pursuant to 310 CMR 7.02(5).

The following sections describe a top-down BACT analysis specifically regarding BACT for PSD-applicable pollutants.

4.6.1 *Particulate Matter*

Step 1: Identify Candidate Control Technologies

- ◆ Active Diesel Particulate Filter (DPF)
- ◆ Low PM engine design (an engine that complies with Tier 2 engine limitations set forth in 40 CFR 60 Subpart IIII)

Step 2: Eliminate Infeasible Technologies

With regard to MIT's proposed project, both of the technologies listed above are technically feasible, although it would be highly unusual to use a DPF for a cold-start engine.

Step 3: Rank Control Technologies by Control Effectiveness

An active DPF, which can achieve up to 85% removal of particulate matter (CARB Level 3), is more effective than the low emission engine design.

Step 4: Evaluate Controls

Since a DPF is technically feasible in the proposed project, an economic analysis of the cost effectiveness for emission control was conducted. This economic analysis is presented in Table C-11 of Appendix C. The capital cost estimate for an active DPF system is based on a

budgetary quote from RYPOS for Exelon West Medway's 450 kW Emergency Diesel Generator¹⁷, scaled according to *Plant Design and Economics for Chemical Engineers*¹⁸. The other factors are from the OAQPS Control Cost Manual. Appendix C (Table C-11) indicates that the cost effectiveness of an active DPF is approximately \$730,000 per ton of PM/PM₁₀/PM_{2.5}. This is not a cost-effective approach for MIT's project, even if the cold-start engine runs the maximum allowable amount of 300 hours per year, which is unlikely.

Considering the unfavorable economics of the DPF, there are no energy or environmental benefits that would outweigh the economics and indicate the selection of a DPF as BACT.

Step 5: Select BACT

With respect to the selection of a PSD BACT for PM/PM₁₀/PM_{2.5} for the cold-start engine, DPF is eliminated as a BACT on economic grounds with regard to the proposed project. As such, the low PM engine design (an engine that meets EPA non-road engine standards for a Tier 2 engine) is proposed as BACT for PM for this project.

4.6.2 Greenhouse Gas (GHG) Emissions

Step 1 – Identify All Control Technologies

- ◆ Post-combustion controls
- ◆ Use of clean fuels (ULSD) and good combustion practices

Step 2 – Eliminate Infeasible Technologies

Post-combustion controls for carbon dioxide and other greenhouse gases are not technically feasible for an engine of this size (2 MW). These controls are designed for much larger systems and even then have many technical issues as described in section 4.4. For example, GHG emissions are mostly composed of carbon dioxide emissions which are directly proportional to the amount of fuel fired. Given the size of this unit, it would be hard to control GHG emissions, especially from a cold-start engine that is used infrequently.

The use of clean fuels (ULSD) and good combustion practices is technically feasible with regard to MIT's proposed project. ULSD is the fuel of choice because it is the cleanest fuel that could be used for this project while still meeting the project's intended purpose as defined above in section 4.0. ULSD can be stored in a small tank adjacent to the engine,

¹⁷ Exelon West Medway CPA Application, Application Number CE-15-016

¹⁸ M. Peters and K. Timmerhaus, *Plant design and economics for chemical engineers*, 3rd ed. New York: McGraw-Hill, 1980, p. 166.

satisfying the requirement for the engine to have a fuel supply that is directly available without interruption. By comparison, propane may be a less reliable source. While propane can be stored locally, the operator would need to evaporate the propane before firing it in the emergency engine. Due to its size, the cold-start engine proposed for this project might need an external heat source to vaporize the propane to make it usable, especially in cold weather. Due to the possible need for an external heat source, propane would be a less reliable resource in an emergency. As such, MIT has proposed ULSD for the project's cold-start generator engine.

Step 3 – Rank Control Technologies by Control Effectiveness

The only technically feasible control option is the use of clean fuels (ULSD) and good combustion practices.

Step 4 – Evaluate Controls

There is no need to analyze the controls because the only remaining technically feasible control is the use of clean fuels (ULSD) and good combustion practices.

Step 5 – Select BACT

With regard to MIT's proposed project, BACT was determined to be the use of clean fuels (ULSD) and good combustion practices. However, as discussed in Step 2 of the BACT process for GHG emissions from the cold-start engine, this does not have much of an impact on GHG emissions. This is primarily due to the fact that GHG emissions are largely carbon dioxide, which is produced proportionally to the amount of fuel fired. The cold-start engine will have very low run times and will be vendor-certified per the MassDEP Environmental Results Program (ERP). It will also comply with EPA standards for non-road engines (40 CFR 89) as well as with the NSPS regulations at 40 CFR 60 Subpart IIII for stationary emergency engines.

Section 5.0

PSD Compliance

5.0 PSD COMPLIANCE

This section documents how MIT's PSD application process will meet the requirements as described by applicable guidance.

5.1 NSR Workshop Manual Guidance

The preface of the EPA NSR Workshop Manual lists five requirements for an applicant to obtain a PSD permit. Each is copied in boxes below, along with a brief description of how MIT intends to fulfill the requirements:

1. Apply the best available control technology (BACT);

Sections 4.3 and 4.4 of MIT's application include BACT analyses for the pollutants subject to PSD review, done on a case-by-case basis considering energy, environmental, and economic impacts in determining the maximum degree of reduction achievable.

2. Conduct an ambient air quality analysis;

Appendix A contains an air quality analysis to demonstrate that new pollutant emissions from MIT's proposed project would not violate either the applicable NAAQS or the applicable PSD increment.

3. Analyze impacts to soils, vegetation, and visibility;

Appendix A includes an analysis to demonstrate that the proposed project's emissions increases would not significantly impair visibility or impact soils or vegetation. No significant impacts are expected from general commercial, residential, industrial, and other growth associated with the project.

4. Not adversely impact a Class I area; and

Appendix A contains an air quality analysis to demonstrate that the proposed project's new pollutant emissions would not significantly impair visibility in any Class I area (national parks and similar).

5. Undergo adequate public participation by applicant.

MIT expects that the application review process will include: consultation letters to tribes, U.S. Fish and Wildlife Service (FWS), National Marine Fisheries Service (NMFS), and the Massachusetts State Historic Preservation Officer (SHPO); enhanced public participation through the MEPA Environmental Justice policy; public notice and comment period; EPA comment period; and a hearing if requested. Additional details are in Section 5.2, below.

5.2 PSD Program Delegation Agreement

The April 2011 document “Agreement for Delegation of the Federal Prevention of Significant Deterioration (PSD) Program by the United States Environmental Protection Agency, Region I to the Massachusetts Department of Environmental Protection” contains specific instructions for the review and approval of PSD permits by MassDEP. Key text is copied in boxes below, followed by a description of how MIT’s application process will satisfy the instructions.

Require PSD permit applicants to submit, as part of their PSD permit applications, any information necessary to determine whether issuance of such permits: (1) may affect federally-listed threatened or endangered species or the designated critical habitat of such species; and, if so, whether permit issuance is likely to adversely affect such species/designated critical habitat and/or jeopardize the continued existence of such species or result in the destruction or adverse modification of designated critical habitat; (2) has the potential to cause effects on historic properties; and, if so, whether such effects may be adverse; and/or (3) has the potential to affect Indian tribes.

The proposed project involves one new building (located at the site of a current parking lot). No critical habitat will be affected. Similarly, no changes to historic properties are proposed, and no impacts to historic properties are expected. MIT is unaware of any potential for the project to affect Indian tribes.

Require the applicant to (1) notify, within 5 working days after submitting a PSD permit application, the following agencies, and (2) provide a copy of the permit application if requested by one of the agencies:

- A. U.S. Fish and Wildlife Service (FWS);
- B. National Marine Fisheries Service (NMFS);
- C. The Massachusetts State Historic Preservation Officer (SHPO);
- D. The Tribal Historic Preservation Officer (THPO) and, via separate copy, the tribal environmental director, for the Mashpee Wampanoag Tribe and for the Wampanoag Tribe of Gay Head (Aquinnah);
- E. When required by the NHPA Letter: the SHPO for a bordering state, and/or the THPO for a federally-recognized Indian tribe in a bordering state.

MIT has submitted these notification letters.

MassDEP will follow EPA policy, guidance, and determinations as applicable... including:

...The requirement to identify and address, as appropriate, disproportionately high and adverse human health or environmental effects of federal programs, policies, and activities on minority and low-income populations, as set forth in *Federal Actions to Address Environmental Justice in Minority Populations and Low-Income Populations*, Exec. Order 12,898, 59 Fed. Reg. 7,629 (Feb. 16, 1994).

The executive order referenced above instructs agencies to develop an environmental justice strategy that will, among other things, “promote enforcement of all health and environmental statutes in areas with minority populations and low-income populations” and “ensure greater public participation.” The May 1, 2013 EPA document *Draft Technical Guidance for Assessing Environmental Justice in Regulatory Analysis* addresses the executive order, focusing on rulemaking activities.


The Executive Office of Energy and Environmental Affairs (EEA) has established environmental justice neighborhoods which identify areas with minority populations and low-income populations. Figure 5-1 identifies areas with minority populations and low-income populations in the vicinity of MIT. This PSD application will assist MassDEP in promoting enforcement of the applicable health and environmental statutes in these areas, specifically the NAAQS.

5.2.1 Environmental Justice conclusions

As shown in the detailed sections below, MIT’s proposed project will have no disproportionately high and adverse human health or environmental effects on areas with minority populations and low-income populations.

In fact, the project represents an environmental improvement for all nearby areas and populations, including areas with minority populations and low-income populations, as follows:

- ◆ The upgraded plant will use natural gas for all normal operations, which is expected to lower MIT’s regulated pollutant emissions. As shown in Table 5-1 in Section 5.2.2 below, air emissions impacts on all nearby communities, including EJ communities, are projected to improve over existing conditions
- ◆ The two new turbines will be cleaner and more efficient than the plant’s current equipment. Their state-of-the-art emissions controls include two different catalysts that will reduce NO_x (nitrogen oxides) emissions by 90% compared to the current system, which does not have this technology.
- ◆ MIT’s new gas supply agreement with Eversource will enable the plant to run entirely on natural gas. This agreement will lead to further reduced emissions as the use of fuel oil is eliminated except for emergencies and testing.



MIT Cogeneration Project Cambridge, Massachusetts

- ◆ When in operation, the upgraded plant will produce electricity and relieve stress on the electric system across the City of Cambridge during periods of high demand. As a result, the likelihood of a power outage will decrease, as will the likelihood that emergency diesel generators (with more emissions and less dispersion) will be called into service in the area.
- ◆ As part of the proposed project, MIT will provide Eversource with a location inside the plant to install a new gas regulator station that will provide additional capacity and more reliable gas service to the Cambridge community.
- ◆ The upgraded plant will have “black start” restoration capability as a primary design objective. By design, the CUP will be able to shed part or parts of its service load in the case of a loss of grid power, in order to keep critical loops powered and continue to operate. This capability will allow MIT to avoid and minimize the use of diesel generators, thereby reducing local emissions during emergencies.

5.2.2 *The Impacts: Not Disproportionately High*

Recent EPA guidance provides that:

The term *disproportionate impacts* refers to differences in impacts or risks that are extensive enough that they may merit Agency action. In general, the determination of whether there is a disproportionate impact that may merit Agency action is ultimately a policy judgment which, while informed by analysis, is the responsibility of the decision maker. The terms *difference* or *differential* indicate an analytically discernible distinction in impacts or risks across population groups. It is the role of the analysis to assess and present differences in anticipated impacts across population groups of concern for both the baseline and proposed regulatory options, using the best available information (both quantitative and qualitative) to inform the decision maker and the public.¹⁹

The guidance further suggests a 3-step process to analyze differential impacts: 1. Identify potential environmental justice (EJ) concerns in the baseline condition; 2. Identify potential EJ concerns for the proposed regulatory action; 3. Identify whether potential EJ concerns are created or mitigated compared to the baseline.²⁰

¹⁹ USEPA “Technical Guidance for Assessing Environmental Justice in Regulatory Analysis,” June 2016, at p. 4 (the “Guidance”).

²⁰ *Id.*, at p. 11.

As shown in Table 5-1 below, in terms of potential air emissions impacts on EJ communities, the proposed facility represents a clear improvement over existing conditions.

Table 5-1 Expected Actual Air Quality Improvement in EJ Areas

Parameter	Current	Proposed
Number of discrete EJ areas with modeled peak 24-hour impacts above the PM _{2.5} significant impact level ¹ , based on full load normal CUP operation.	112	37
Square miles of EJ area with modeled peak 24-hour impacts above the PM _{2.5} significant impact level, based on full load normal CUP operation.	4.2	1.5
Highest modeled 24-hour average impact averaged across the impacted EJ areas, based on full load normal CUP operation, in micrograms per cubic meter	2.7	2.5

¹ Significant Impact Levels only indicate where additional modeling is needed to document that impacts are below health-based National Ambient Air Quality Standards. The project does not cause any violations of National Ambient Air Quality Standards at any location, inside or outside of EJ areas.

In addition to the results above, a population-weighted average concentration for PM₁₀ and PM_{2.5} was computed using the worst case AERMOD impacts Operating Scenario from all of the MIT sources for each averaging period. The population-weighted concentrations were calculated for areas classified as environmental justice (EJ) areas and compared to population-weighted concentrations in areas not classified as environmental justice areas within five miles of the project site. The results are presented in Table 5-2 below. The results demonstrate that the impacts from the proposed project are not disproportionately high in the EJ areas when compared to areas not classified as EJ areas. While the population-weighted impacts are slightly higher (less than 10%) for some pollutants and averaging times, they are not disproportionately higher.

Table 5-2 Population-weighted Predicted Impacts

Pollutant	Averaging Period	Post-Project Population-weighted Concentration ($\mu\text{g}/\text{m}^3$)	
		Non-EJ Areas	EJ Areas
PM _{2.5}	24-hour	1.12	1.23
	Annual	0.04	0.04
PM ₁₀	24-hour	1.58	1.70

Taken together, the results described in the two Tables above show that 1) air emissions impacts on EJ communities will improve as a result of the project, and 2) air emissions impacts on EJ communities will not be disproportionately higher in EJ communities when compared with non-EJ communities.

5.2.3. Impacts Will Not Be Adverse

The modeled ambient air impacts associated with MIT’s expanded plant show that the project will improve air quality in the area. As part of the Massachusetts Environmental Policy Act (MEPA), MIT was asked by the Massachusetts Department of Public Health to more fully examine the impact on EJ populations. MIT performed AERMOD dispersion modeling using the current configuration of the CUP (Boilers Nos. 3, 4, and 5 burning No. 6 Fuel Oil; the existing turbine operating on fuel oil, and Boilers Nos. 7 and 9 burning ULSD) and compared these existing configurations to how the CUP is projected to typically operate after completion of this project: Boilers Nos. 3, 4, 5 burning natural gas, the two new CTG units burning natural gas, and Boilers Nos. 7 and 9 burning natural gas. Based on the description above, peak 24-hr PM_{2.5} impacts will decrease by over 50% as a result of the project.


Table 5-3 documents the emission rates for each of these units under current operating conditions and the future projected actual emission rates. Figure 5-2 shows the extent of the reduction in concentrations, overlaid on the surrounding EJ populations in the vicinity of the project.

Table 5-3 Population-weighted Predicted Impacts

Pollutant	Averaging Period	Pre-Project Maximum Concentration ($\mu\text{g}/\text{m}^3$)	Post-Project Maximum Predicted Concentration ($\mu\text{g}/\text{m}^3$)
PM _{2.5}	24-hour	27.6	11.5

The project impacts for all pollutants and operational scenarios are below the NAAQS²¹ (as documented in Table A-16 of the modeling report). The NAAQS are considered protective of the health of sensitive populations such as asthmatics, children, and the elderly. The

²¹ The Clean Air Act required U.S. EPA to set NAAQS for wide-spread pollutants that were considered harmful to the public and environment. Separately, MassDEP has established health-based air guidelines - Ambient Air Limits (AALs) and Threshold Effect Exposure Limits (TELS) - that are used to evaluate potential human health risks from exposures to chemicals in air. In the separate MCPA application, MIT documents that the Project will not cause any exceedance of AALs or TELs.



MIT CUP Second Century Project Cambridge, Massachusetts

total impacts presented here are worst-case impacts; anticipated actual impacts are projected to decrease from present levels in all areas including Environmental Justice areas. Therefore, it has been demonstrated that no adverse impacts are expected within any Environmental Justice areas around MIT.

5.2.4 *The Public will Continue to be Informed of the Project*

In order to reach and inform residents of Environmental Justice neighborhoods in the area, MIT will work with MassDEP to identify opportunities to ensure greater public participation through the review process. MIT expects that will include use of alternative media outlets such as community or ethnic newspapers, use of alternative information repositories, translation of materials, and interpretation services at public meetings. More specifically, MIT expects that public participation can be enhanced through the following actions:

- ◆ MIT will publish the Notice of Public Hearing and Public Comment Period on the Draft PSD Permit in English, Spanish, Portuguese, Chinese (Cantonese), and French.
- ◆ MIT will publish a one or two page summary of the project and the permitting process in English, Spanish, Portuguese, Chinese (Cantonese), and French.
- ◆ Interpreters will be provided at the Public Hearing.
- ◆ MIT will post electronic copies of the notice of Public Hearing and Public Comment Period, Proposed Plan Approval, Draft PSD Permit, Draft PSD Fact sheet, Revised CPA Application, and Revised PSD Application on its project website (powering.mit.edu).

As of this revised submittal, MIT has also conducted public outreach specifically related to the Massachusetts Environmental Policy Act (MEPA) process. Specifically, MIT submitted a Notification of Filing an Expanded Environmental Notification Form (EENF) under the Massachusetts Environmental Policy Act and Public Scoping in December of 2015, then submitted the EENF in December 15, 2015. Availability of the EENF was announced in the *Environmental Monitor* on December 23, 2015, in the *Boston Herald* on December 18, 2015, and in the *Cambridge Chronicle* on December 24, 2015.

Following notice in the *Environmental Monitor*, MIT published a two-page fact sheet describing the project and options for comment in four common non-English languages spoken in the areas adjacent to the project site. The fact sheet was published in English in the *Cambridge Chronicle* on January 7, 2016, in Spanish in *El Mundo Boston* on January 7, 2016, in Chinese in *Sampan* on January 8, 2016, and in Portuguese in *O Jornal* on January 8, 2016. All fact sheets and the EENF were sent to the Cambridge Public Library, Central Square Branch. As stated in the fact sheets, the MEPA Office accepted comments in all languages through January 22, 2016.

A public scoping session was held to hear comments on the proposed project from 6:00 to 8:00 p.m. on January 14, 2016, at MIT Building 4 Room 270 (182 Memorial Drive, Cambridge). At that public meeting, MIT provided interpretation services in Spanish, Portuguese, French, and Cantonese.

MIT submitted a Notification of Filing a Single Environmental Impact Report (SEIR) under Massachusetts Environmental Policy Act in May of 2016, and submittal of the SEIR was announced in the *Environmental Monitor* on May 25, 2016. MIT published the notification of the availability of the SEIR and a copy of the fact sheet in English in the *Cambridge Chronicle* on May 26, 2016, in Spanish in *El Mundo* on May 19, 2016, in Chinese in *Sampan* on May 27, 2016 and in Portuguese in *O Jornal* on May 20, 2016. The SEIR and translated fact sheets were provided to the Cambridge Public Library, Central Square Branch. Members of the public were also able request copies through the MEPA Office.

MIT has posted copies of the current CPA and PSD applications, the EENF, the SEIR, and translated fact sheets on its project website (powering.mit.edu). The project website also includes an overall project description, additional project information, and responses to frequently asked questions.

Appendix A

Air Quality Dispersion Modeling Analysis

New Nominal 44 MW Cogeneration Project
PSD Air Quality Modeling Report
Massachusetts Institute of Technology

Submitted to:

Massachusetts Department of Environmental Protection
Bureau of Waste Prevention
One Winter Street
Boston, Massachusetts 02108

Prepared for:

MIT Department of Facilities
Building NW23
195 Albany Street
Cambridge, MA 02139

Prepared by:

Epsilon Associates, Inc.
3 Clock Tower Place, Suite 250
Maynard, MA 01754

November, 2016

Table Of Contents

A-1.	INTRODUCTION	A.1-1
	A-1.1 Project Overview – Combustion Turbine Expansion	A.1-1
	A-1.2 Project Overview – Other Proposed Changes	A.1-2
	A-1.3 Project Benefits	A.1-3
	A-1.4 Outline of the PSD Air Quality Modeling Report	A.1-4
A-2.	REGULATORY REQUIREMENTS	A.2-1
A-3	PROJECT DESCRIPTION	A.3-1
	A-3.1 Description of Project Site	A.3-1
	A-3.2 Project Description	A.3-2
	A-3.3 Source Data	A.3-3
	A-3.4 Urban/Rural Analysis	A.3-13
	A-3.5 Background Air Quality Data	A.3-14
	A-3.5.1 Justification to use SILs	A.3-16
	A-3.6 Good Engineering Practice Stack Height Determination	A.3-17
A-4.	AIR QUALITY IMPACT ANALYSES	A.4-1
	A-4.1 Modeling Methodology	A.4-2
	A-4.2 Air Quality Model Selection and Options	A.4-4
	A-4.3 Meteorological Data for Modeling	A.4-5
	A-4.4 Receptor Grid	A.4-6
A-5.	AIR QUALITY IMPACT RESULTS	A.5-1
	A-5.1 CTG Load Analysis	A.5-1
	A-5.2 Significant Impact Level Analysis	A.5-1
	A-5.3 National Ambient Air Quality Analysis	A.5-2
	A-5.3.1 MIT Sources	A.5-3
	A-5.3.2 Cumulative Impact Modeling	A.5-5
	A-5.4 PSD Increment Modeling	A.5-8
	A-5.5 Class I Visibility Analysis	A.5-13
	A-5.6 Effects on Soils and Vegetation Analyses	A.5-15
	A-5.7 Growth	A.5-15
	A-5.8 Environmental Justice	A.5-16
A-6	REFERENCES	A.6-1

List of Attachments

ATTACHMENT A	SOURCE PARAMETERS FOR NEW TURBINE LOAD CASES
ATTACHMENT B	SOURCE PARAMETERS FOR CUMULATIVE IMPACT MODELING
ATTACHMENT C	CALCULATIONS OF ACTUAL EMISSION RATES FOR PSD INCREMENT MODELING

List of Figures

Figure A-1	Aerial Photo	A-3-4
Figure A-2	Site Layout	A-3-5
Figure A-3	Cooling Tower #1-10 Locations	A-3-6
Figure A-4	Cooling Tower #11-13 Locations	A-3-7
Figure A-5	USGS Topographic Map with 3 km Radius	A-3-15
Figure A-6	Building Footprints and Heights used in BPIP-Prime	A-3-18
Figure A-7	5-year (2010-2014) Wind Rose of measurements from the Boston Logan International Airport NWS station.	A-4-7
Figure A-8	Nested Receptor Grid used in AERMOD Modeling	A-4-8

List of Tables

Table A-1	Project Future Potential Emissions vs. Significant Emission Rates	A-2-2
Table A-2	National and Massachusetts Ambient Air Quality Standards, SILS, & PSD Increments	A-2-3
Table A-3	Key Existing Equipment Operating at the MIT CUP	A-2-2
Table A-4	Operational Scenarios	A-2-8
Table A-5	Physical Stack Characteristics for the New Sources	A-2-8
Table A-6	New CTG Source Characteristics and Emission Rates for 1 CTG with HRSG (Operational Scenario 1)	A-2-9
Table A-7	New CTG Source Characteristics and Emission Rates for 2 CTGs with HRSGs (Operational Scenario 2)	A-2-9
Table A-8	New 2 MW Cold Start Emergency Engine and Cooling Tower Source Characteristics and Emission Rates	A-2-9
Table A-9	Physical Stack Characteristics for the MIT Existing Sources	A-2-10
Table A-10	Worst-case Operating Conditions for Existing MIT Stacks by Pollutant and Averaging Period ¹	A-2-11
Table A-11	Existing MIT Source Characteristics and Emission Rates	A-2-12
Table A-12	Identification and Classification of Land Use	A-2-13

List of Tables (Continued)

Table A-13	Observed Ambient Air Quality Concentrations and Selected Background Levels	A-2-14
Table A-14	Comparison of the Difference between the Monitored Air Quality Concentrations and the NAAQS to the Significant Impact Levels	A-2-16
Table A-15	Proposed Project AERMOD Modeled Results for Operational Scenarios 1 and 2 Compared to Significant Impact Levels (SILs)	A-3-2
Table A-16	AERMOD Model Results for the Full MIT Facility Compared to the NAAQS	A-3-4
Table A-17	AERMOD Model Results for the Full MIT Facility with Interactive Sources for Operational Scenarios 1 & 2 Compared to the NAAQS	A-3-7
Table A-18	PM Emission Rates used in PSD Increment Modeling	A-3-10
Table A-19	PM Emission Rates used in PSD Increment Modeling	A-3-12
Table A-20	ERMOD Model Results for Operational Scenario 2 compared to PSD Increments	A-3-12
Table A-21	Class I Visibility Modeling Results -Maximum Visual Impacts Inside the Class I Area	A-3-14
Table A-1	MIT turbine & duct burner model cases Operational Scenario 1	A-A-1
Table A-2	MIT turbine & duct burner model cases - Operational Scenario 2	A-A-2
Table B-1	Source Parameters and Emission Rates for Cumulative Modeling Analysis	A-B-1
Table C-1	PM Short-term Emission Calculations based on Actual Operations	A-C-1
Table C-2	PM Annual Emission Calculations based on Actual Operations	A-C-2
Table C-3	PM Annual Emission Consuming Calculations based on Actual Operations for Boilers No. 3, 4, & 5	A-C-3
Table C-4	PM Annual Emission Consuming Calculations based on Actual Operations for Boilers No. 7 & 9	A-C-3

A-1 INTRODUCTION

A-1.1 Project Overview – Combustion Turbine Expansion

The Massachusetts Institute of Technology (MIT), located on 168 acres Cambridge side of the Charles River Basin, is determined to support its research and other world-changing activities with efficient, reliable power and utilities. To achieve this in the context of its recent commitment to at least a 32% reduction (by 2030) in greenhouse gas emissions, MIT is proposing to upgrade its on-campus power plant – a key step in developing an energy strategy that makes climate change mitigation a top priority.

The MIT Central Utilities Plant (CUP) currently provides electricity, steam heat, and chilled water to more than 100 MIT buildings through a combined heat and power (CHP) process, also known as cogeneration – a highly efficient method of generating electrical and thermal power simultaneously. This system has been designed to provide near 100% reliability through maintaining standby units at all times, as the heat and electrical power it generates is used to maintain critical research facilities, U.S. Government Research, classrooms and dormitories.

Since 1995, the CUP has consisted of a Siemens (ABB) GT10A Combustion Turbine Generator (CTG), a heat recovery steam generator (HRSG), an electric generator rated at approximately 21 Megawatts (MW), and ancillary equipment, all located in Building 42. The existing system also includes five boilers, designated as Boiler Nos. 3, 4, 5, 7, and 9, an emergency generator, and a number of cooling towers. Through a cogeneration process, the CTG provides about 60% of current campus electricity, and the steam from the HRSG is used for heating, and for steam-driven chillers that cool many building via steam and chilled water distribution systems.

MIT is proposing this Combustion Turbine Expansion Project (Project) to retire the existing CTG (now reaching the end of its useful life) and develop an enhanced system consisting of two nominal 22 MW CTGs, supplemental gas-fired (134 MMBtu/hr HHV) HRSGs, and other proposed updates to the CUP. MIT has retained Epsilon Associates Inc. (Epsilon) of Maynard, MA, to perform an air quality modeling analysis in support of the air permit application for this proposed development. The project is to be located in a new building at an existing parking lot along Albany Street.

A cogeneration system has significant efficiency and environmental advantages, as described by the Massachusetts Department of Environmental Protection (MassDEP)¹:

“In a combined heat and power (CHP) system, the engine or combustion turbine is connected to an electrical generator for electrical power production. The hot exhaust gasses from the engine or combustion turbine are directed through a heat

¹ Proposed Amendments to 310 CMR 7.00, March 2008

recovery system, such as a boiler, to recover thermal energy for use in heating, cooling, or other uses. This approach eliminates the need for a second combustion unit and therefore eliminates the emissions such a combustion unit would produce. CHP systems make more efficient use of fuel, such as natural gas or fuel oil, than two, separate stand alone, combustion units, one for electricity and one for thermal energy such as steam thus reducing the net emissions of greenhouse gas and other air contaminants.”

In MIT’s proposed system, each CTG will fire natural gas with Ultra Low Sulfur Diesel (ULSD) as a backup fuel for up to the equivalent heat input of 48 hours per year for testing and up to the equivalent heat input of 168 hours per year including testing and periods when natural gas is unavailable (more specifically, when natural gas is curtailed by the natural gas supplier or distributor or is otherwise unavailable to be combusted in the equipment). Each CTG will exhaust to its own HRSG with a 134 million Btu per hour (MMBtu/hr) higher heating value (HHV) gas-fired duct burner. The HRSG will include selective catalytic reduction (SCR) for Oxides of Nitrogen (NOx) control and an oxidation catalyst for the control of Carbon Monoxide (CO) and Volatile Organics (VOC).

The specific public and environmental benefits of MIT’s proposed system are detailed in Section A-1.3 (Project Benefits) below.

A-1.2 Project Overview – Other Proposed Changes

In addition to installing two new CTGs, MIT proposes the following other changes:

- ◆ Addition of a 2 MW ULSD-fired cold-start engine unit to provide emergency power to start the CTGs when grid electricity is unavailable.
- ◆ Existing Boilers Nos. 3, 4, and 5 will cease burning No. 6 fuel oil and only burn natural gas, with ULSD as a backup fuel for up to the equivalent heat input of 48 hours per year for testing and up to the equivalent heat input of 168 hours per year including testing and periods when natural gas is unavailable.

This fuel changeover will occur within 12 months of the startup of the new CTGs. This will allow for adequate time to finish construction and remove the old tanks to make space for new fuel storage to be built. Once a permit is issued, the units will only burn the No. 6 fuel oil left in the tanks or run for 48 hours of testing per year per unit, whichever is greater. The boilers will not fire No. 6 fuel oil after initial startup (first fire) of the new CTGs.

- ◆ Existing Boilers Nos. 7 and 9 will fire natural gas only, with ULSD as a backup fuel for up to the equivalent heat input of 48 hours per year for testing and up to the equivalent heat input of 168 hours per year including testing and periods when natural gas is unavailable. This represents a substantial reduction in the ULSD operating time limitation from the current operating permit limit of 720 hours per year.²

Portions of the project trigger the requirement to submit this Prevention of Significant Deterioration (PSD) application through MassDEP per the federal PSD regulations at 40 CFR 52.21.

As an unrelated project, MIT has recently replaced cooling towers 3 and 4 with three new cooling towers (towers 11, 12, and 13). Cooling towers 1, 2, 5, and 6 are retired. Towers 7, 8, 9, and 10 will remain. The cooling tower replacements do not rely on the proposed project and vice-versa; the replacement cooling towers are not required for the proposed project to operate, and the proposed project does not need to be constructed for MIT to gain full use of the replacement cooling towers. Replacement of the cooling towers did not trigger PSD permit thresholds (potential emissions less than one ton per year). The projects were funded and constructed separately. Based on a preapplication meeting with MassDEP July 29, 2014, the changes to the cooling towers are addressed in this air quality dispersion modeling analysis for this project.

A-1.3 Project Benefits

This project has been proposed and designed to improve conditions and provide benefits to MIT and the surrounding community. The intent of the project is to increase the resiliency of the campus, safeguarding crucial research and public safety by enabling MIT to function during a power-loss event; to equip the MIT community with an efficient, reliable power source capable of supporting their groundbreaking work and experimentation; and to continue conserving energy and reducing MIT's impact on the environment.

The upgraded plant will provide a reliable source of energy that is more efficient than conventional energy sources. and that will lower both GHG and pollutant emissions, as mentioned above. In addition, the upgraded plant will improve campus resiliency by placing critical equipment above the flood level, safeguarding the system will continue to ensure that it can provide energy to MIT's campus during a flooding event.

² The original December 2015 application requested an increase in the allowable natural gas-fired operating hours for Boilers Nos. 7 and 9. MIT has withdrawn this request because further analysis of projected operations shows that the steam load will be more efficiently met using the new CHP units, and additional operation of Boilers Nos. 7 and 9 will not be needed. Specifically, projected future operation (for model year 2023) shows that the steam generated by the CTG & HRSG units will be 1,446,663 MMBtu/year, and the steam generated by existing boilers will only be 2,154 MMBtu/year.

By providing the MIT campus with a reliable power source and improving its self-sufficiency, the project will reduce the burden on the community in a power-loss situation. As a further benefit, MIT is providing Eversource Energy (formerly NSTAR) with a location inside the plant for a new regulator station that gives Eversource access to high-pressure gas. With this access, Eversource can continue providing service to this area of Cambridge even as it develops and expands. By allowing and hosting new Eversource equipment, the proposed project will also provide the City of Cambridge with a back-up gas supply for existing natural gas users, a significant public benefit.

The project is also expected to improve the surrounding community by enhancing the Albany Street streetscape, installing new lighting on public walkways, and installing new public seating.

A further benefit is the collection of rainwater on the roof of the expanded plant's new addition. This rainwater will be discharged to an existing holding basin (approximately 145,000 gallon capacity) located on the roof of Building N16. This water will be used in the facility's cooling towers and will not flow into the City of Cambridge storm water system. The reuse of storm water will reduce local flooding risks and the facility's burden on the City's water and storm water systems.

A-1.4 Outline of the PSD Air Quality Modeling Report

This report describes the air quality modeling analysis for PM₁₀ and PM_{2.5} performed in support of the PSD Application. The air quality analyses described in this report demonstrate that the proposed project will not violate the National Ambient Air Quality Standards (NAAQS), PSD increments, and other applicable federal regulations.

The remainder of this report is organized in five sections. Section A-2 describes the federal and state air quality regulations applicable to the modeling analysis and presents the applicable air quality standards. Section A-3 provides a detailed description of the proposed Project including the design configuration, source data and the urban/rural determination for modeling, background air quality data, and the Good Engineering Practice (GEP) stack height analysis. Section A-4 describes the air quality modeling methodology. Section A-5 describes the modeling results. Finally, Section A-6 lists the reference documents used in compiling this modeling report.

A-2 REGULATORY REQUIREMENTS

Under federal and state air laws, the MassDEP and the EPA have promulgated air quality regulations that establish ambient air quality standards and emission limits. These standards and limits impose design constraints on new facilities and provide the basis for an evaluation of the potential impacts of proposed projects on ambient air quality. This section briefly describes these regulations and their relevance to the proposed expansion of the CUP.

Prevention of Significant Deterioration review is a federally mandated program for review of new major sources of criteria pollutants or major modifications to existing sources. In Massachusetts, as of April 2011, MassDEP has “full responsibility for implementing and enforcing the federal PSD regulations.”

The project as a whole triggers PSD Major Modification thresholds as follows:

- ◆ MIT is an existing major stationary source of air emissions per the federal PSD program at 40 CFR 52.21 (b)(1)(i), with potential emissions of one or more PSD pollutants above 100 tons/year for a facility with combinations of fossil-fuel boilers totaling more than 250 MMBtu/hr heat input.
- ◆ The project per 40 CFR 52.21 (b)(52) is the installation of the CTGs and associated HRSGs, the cold-start engine, and the change from No. 6 oil firing to ULSD firing in Boilers Nos. 3, 4, and 5. The restriction of ULSD operations in Boilers Nos. 7 and 9 is not a physical change or change in the method of operation.
- ◆ Per 40 CFR 52.21(a)(2)(iv), a project is a major modification for a regulated New Source Review (NSR) pollutant if it causes two types of emissions increases - a significant emissions increase, and a significant net emissions increase.
- ◆ The project will create a significant emissions increase per 40 CFR 52.21(b)(23)(i) for CO_{2e}, PM₁₀ and PM_{2.5}. The emissions from the project are compared to PSD thresholds in Table A-1.
- ◆ The project will also create a significant net increase for CO_{2e}, PM₁₀ and PM_{2.5}, as there are no contemporaneous emissions decreases that are enforceable as a practical matter per 40 CFR 52.21(b)(3)(vi).

Therefore, the project will be a major modification of an existing major source, subject to the requirement to obtain a PSD permit.

Table A-1 Project Future Potential Emissions vs. Significant Emission Rates

Pollutant	Estimated Potential Emission Rates (tpy)	Significant Emission Rate (tpy)	Significant? PSD Review Applies
NO _x	26.4	40	No
CO	15.4	100	No
PM ₁₀	50.1	15	Yes
PM _{2.5}	50.1	10	Yes
SO ₂	7.0	40	No
VOC	21.0	40	No
CO ₂ E	295,450	75,000	Yes

The project is subject to the PSD program for Particulate Matter and Greenhouse Gases (CO₂e), and must apply for and obtain a PSD Permit that meets regulatory requirements including:

- ◆ Best Available Control Technology (BACT) requiring sources to minimize emissions to the greatest extent practical;
- ◆ An ambient air quality analysis to ensure all the emission increases do not cause or contribute to a violation of any applicable PSD increments or NAAQS;
- ◆ An additional impact analysis to determine direct and indirect effects of the proposed source on industrial growth in the area, soil, vegetation and visibility; and
- ◆ Public comment including an opportunity for a public hearing.

All of MA is designated as moderate non-attainment for the 1997 8-hr ozone standard and attainment for all other criteria pollutants. The project does not trigger Non-attainment New Source Review (NNSR) because potential NO_x emissions are below the 310 CMR 7.00: Appendix A major source modification threshold of 25 tpy due to the non-attainment status for ozone. MIT is not currently a major source of VOC.

The facility cannot cause or contribute to the violation of any National or Massachusetts State Ambient Air Quality Standard (NAAQS or MAAQS) or consume more than the available PSD increment for pollutants subject to the PSD requirement. Air quality dispersion modeling is used to demonstrate compliance with these thresholds.

PSD increment is tracked on a county wide basis in Massachusetts. The PSD regulations define “minor source baseline date” at 40 CFR 52.21(b)(14)(ii) as “the earliest date after the trigger date on which... a major modification subject to 40 CFR 52.21... submits a complete application”. Therefore, if the minor source baseline date has not been established for the

baseline area (Middlesex County), this application will establish the baseline date when it is determined to be complete. EPA has established increment standards for PM₁₀ and PM_{2.5}. Based on consultation with MassDEP the PM₁₀ minor source baseline date was triggered on September 10th, 2001 by a PSD application from Kendall Station.

Table A-2 shows the NAAQS, significant impact levels (SILs), and PSD increments applicable at this time. The SILs are numerical values that represent thresholds of insignificant, i.e., *de minimis*, modeled source impacts. As shown in Table A-2, the SILs are small fractions of the health protective NAAQS. For new sources that exceed these levels, the air quality impact analysis is required to include the new source, existing interactive sources and measured background levels. If the maximum predicted impacts of a pollutant due to a proposed emission increase from the existing facility are below the applicable SILs, the predicted emissions from the proposed modification are considered to be in compliance with the NAAQS and PSD increments for that pollutant.

Table A-2 National and Massachusetts Ambient Air Quality Standards, SILS, & PSD Increments

Pollutant	Averaging Period	NAAQS/MAAQS ($\mu\text{g}/\text{m}^3$)		Significant Impact Level ($\mu\text{g}/\text{m}^3$)	PSD Increments ($\mu\text{g}/\text{m}^3$)	
		Primary	Secondary		Class I	Class II
NO ₂	Annual ⁽¹⁾	100	Same	1	2.5	25
	1-hour ⁽²⁾	188	None	7.5	None	None
SO ₂	Annual ⁽¹⁾	80	None	1	2	20
	24-hour ⁽³⁾	365	None	5	5	91
	3-hour ⁽³⁾	None	1300	25	25	512
	1-hour ⁽⁴⁾	196	None	7.8	None	None
PM _{2.5}	Annual ⁽¹⁾	12	15	0.3	1	4
	24-hour ⁽⁵⁾	35	Same	1.2	2	9
PM ₁₀	24-hour ⁽⁶⁾	150	Same	5	8	30
CO	8-hour ⁽³⁾	10,000	Same	500	None	None
	1-hour ⁽³⁾	40,000	Same	2,000	None	None
Ozone	8-hour ⁽⁷⁾	147	Same	N/A	None	None
Pb	3-month ⁽¹⁾	1.5	Same	N/A	None	None

(1) Not to be exceeded

(2) 98th percentile of 1-hour daily maximum concentrations, averaged over 3 years

(3) Not to be exceeded more than once per year.

(4) 99th percentile of 1-hour daily maximum concentrations, averaged over 3 years

(5) 98th percentile, averaged over 3 years

(6) Not to be exceeded more than once per year on average over 3 years

(7) Annual fourth-highest daily maximum 8-hr concentration, averaged over 3 years

Note that in January 2013, the Circuit Court decision³ vacating the PM_{2.5} significant monitoring concentration does not preclude the use of the SILs for PM_{2.5} entirely, but requires monitoring data be presented. If the monitoring data shows that the difference between the PM_{2.5} NAAQS and the PM_{2.5} monitored background concentration in the area is greater than the EPA PM_{2.5} SIL value, then EPA believes it would be sufficient to conclude that a proposed source with a PM_{2.5} impact below the PM_{2.5} SIL value will not cause or contribute to a violation of the PM_{2.5} NAAQS and to forego a more comprehensive modeling analysis for PM_{2.5}.

For the source impact analysis for the PM_{2.5} NAAQS, the analysis should address impacts of direct PM_{2.5} emissions and/or PM_{2.5} precursor emissions based upon the total amount of these emissions as compared to the respective significant emission rates (SERs).

For the project, it is deemed that it is not necessary to address the secondary formation of PM_{2.5} in the NAAQS analysis. Based on Table III-1 in the EPA PM_{2.5} guidance (May, 2014), the project falls into Case 2 which does not include a secondary impacts approach, Case 2 is defined as the situation where the direct PM_{2.5} emissions are greater than 10 tpy and the precursor emissions of NO_x and SO₂ are individually less than 40 tpy.

³ <http://www.epa.gov/nsr/documents/20130304qa.pdf>.

A-3 PROJECT DESCRIPTION

A-3.1 Description of Project Site

MIT is a world-class educational institution which admitted its first students in 1865. Teaching and research—with relevance to the practical world as a guiding principle—continue to be its primary purpose. MIT is independent, coeducational, and privately endowed. Its five schools and one college encompass numerous academic departments, divisions, and degree-granting programs, as well as interdisciplinary centers, laboratories, and programs whose work cuts across traditional departmental boundaries.

As an academic and research facility, MIT has steam and electricity reliability needs that exceed those of typical industrial facilities. The MIT CUP has been sized to provide nearly 100% of the Institute's thermal and electrical power needs during most operating and weather conditions. The thermal and electrical energy generated is used to maintain critical research facilities, laboratories, classrooms and dormitories in the event of a power outage, gas curtailment, or other emergency.

The Central Utility Plant (CUP) is housed in Building 42 (N16, N16A, N16C and 43 on MIT campus maps), which is located between Vassar Street and Albany Street in Cambridge, MA. The new CTGs would be housed in an addition to Building 42 to be built on the site of an existing parking lot along Albany Street between the cooling towers and an existing parking garage. The addition to the existing building would be approximately 184' x 118' by 63' above ground level (AGL) tall with two 167' AGL high flues centrally co-located in a common stack structure. There will be a flue for each CTG vented through its respective Heat Recovery Steam Generator (HRSG). The cold-start engine will be roof-mounted and will have its own exhaust vent above its housing (93.5' AGL). An aerial locus of the area around the new project is shown in Figure A-1. The proposed new cogeneration addition and the proposed site for the new CTG stacks and new cold-start engine stack are shown.

Table A-3 describes the key equipment at the CUP and lists the equipment designation abbreviations used in the operating permit (Application MBR-95-OPP-026).

Table A-3 Key Existing Equipment Operating at the MIT CUP

Turbine #1	ABB GT10 (GT-42-1A) and Heat Recovery Steam Generator #1 (HRSG-42-1B) (collectively the existing Cogeneration Unit)
Boiler No. 3	Wickes 2 drum type R dual fuel (BLR-42-3)
Boiler No. 4	Wickes 2 drum type R dual fuel (BLR-42-4)
Boiler No. 5	Riley type VP dual fuel (BLR-42-5)
Generator #01	Emergency Diesel Generator Caterpillar #3516B 2MW (DG-42-6)
Boiler No. 7	Indeck Dual Fuel BLR-42-7 firing natural gas with ULSD backup
Boiler No. 9	Rentech Boiler rated at 125 MMBtu/hr firing natural gas with ULSD backup
Cooling Towers	Wet mechanical towers #7,8,9,10,11,12,13

A-3.2 Project Description

The proposed project will consist of adding two nominal 22 MW Solar Titan 250 CTGs fired primarily on natural gas. Backup ULSD will be used for up to the equivalent heat input of 48 hours per year for testing, and up to the equivalent heat input of 168 hours per year including testing and periods when natural gas is unavailable (more specifically, when natural gas is curtailed by the natural gas supplier or distributor or is otherwise unavailable to be combusted in the equipment). Each CTG will exhaust to its own HRSG with a 134 MMBtu/hr (HHV) gas-fired duct burner. The HRSG will include SCR for NO_x control, and an oxidation catalyst for CO and VOC control. The CTGs will be vented through its own approximately 167-foot-tall (AGL) 7' diameter flue, i.e., one flue for each CTG.

Pending approvals, MIT intends to begin installing the new CTGs in 2019 and complete installation and shakeout in late 2019 or early 2020. The existing Siemens CTG will be fully retired following completion of installation and shakeout for both of the new units in 2020. At no time will the existing Siemens CTG be operating at the same time as the new Solar Titan 250 CTGs. In addition to the two new CTGs, MIT plans to add a 2 MW ULSD-fired cold-start engine unit to be used to start the CTGs in emergency conditions.

As a result of this project, existing Boilers Nos. 3, 4, and 5 will cease burning No. 6 fuel oil and will burn only natural gas, with ULSD as a backup fuel for up to the equivalent heat input of 48 hours per year for testing and up to the equivalent heat input of 168 hours per year including testing and periods when natural gas is unavailable.

Also, existing Boilers Nos. 7 and 9 will fire natural gas only, with ULSD as a backup fuel for up to the equivalent heat input of 48 hours per year for testing and up to the equivalent heat input of 168 hours per year including testing and periods when natural gas is unavailable. This is a substantial reduction in ULSD operating time from the current operating permit limit of 720 hours per year.

MIT has retired some of the existing wet mechanical cooling towers and added three new ones. Tower #1, 2, 3, 4, 5, 6 have been taken out of service while Towers #11, 12, and 13 were added. Towers #7, 8, 9 and 10 remain. Figure A-3 shows the locations of cooling towers #1-10, and Figure A-4 shows the locations of cooling towers #11-13.

A-3.3 Source Data

In addition to modeling the impacts from the new units, the project includes modeling of the existing units at the MIT CUP to determine full facility impacts. Some modifications are proposed for the operations of the existing units while operating coincident with the new CTGs, including new restrictions are proposed on oil firing for existing Boiler Nos. 3,4,&5,7&9. A range of potential operating loads (40%, 50%, 65%, 75%, and 100%) were modeled for the new units using a range of ambient temperatures (0°, 50° & 60°F). The parameters for each operating case are listed in Attachment A. The new CTGs may burn natural gas with a backup fuel of ULSD. Both options over a range of loads and ambient temperatures were modeled to determine the case resulting in the highest air quality impact of each pollutant. The HRSG with duct burners will fire gas only but can be used during gas or oil firing of the CTGs. The worst case scenario is then modeled with the existing facility to demonstrate compliance with the NAAQS. The cooling tower emissions are below the MassDEP threshold for inclusion in air quality modeling, however because this is a PSD project for PM_{2.5}, the cooling towers are included in the modeling analysis at the request of MassDEP.

Two operational configurations shown in Table A-4 have been modeled, i.e. one new CTG operating through the HRSG, 2 new CTGs operating through their HRSG's. For the one CTG case, both CTG 1 and CTG 2 stacks were modeled in the load analysis and the worst case location was carried throughout the modeling. When modeling the case of the two new CTGs operating through their HRSG's their plumes have been merged using an effective diameter to represent the area of the two individual flues.


LEGEND

- New Cogeneration Stack
- Cold Start Emergency Engine
- New Turbine Building


Scale 1:4,200
1 inch = 350 feet

0 175 350 Feet

Basemap: 2013 Orthophotography, MassGIS




MIT Cogeneration Project Cambridge, Massachusetts





MIT Cogeneration Project Cambridge, Massachusetts



MIT Cogeneration Project Cambridge, Massachusetts

Table A-4 Operational Scenarios

Scenario	New CTG Configuration	2MW Cold Start Emergency Engine	Additional MIT Sources Operating
1	1 CTG with HRSG	included	Turbine#1; Boilers No. 3,4,5; Boilers No. 7,9; Generator #01 Cooling Towers#7,8,9,10,11,12,13
2	2 CTGs with HRSG	included	Boilers No. 3,4,5; Boilers No. 7,9; Generator #01 Cooling Towers#7,8,9,10,11,12,13

Table A-5 summarizes the physical stack parameters for the new stacks and cooling towers. Note that the cooling towers have multiple cells, denoted with a letter in the naming convention. The UTM coordinates are located in zone 19.

Table A-5 Physical Stack Characteristics for the New Sources

Stack	UTM E (m)	UTM N (m)	Base Elevation (m)	Stack Height (m)	Stack Diameter (m)
CTG/HRSG 1	327,593.31	4,692,056.99	5.5	50.9	2.1
CTG/HRSG 2	327,595.85	4,692,058.57	5.5	50.9	2.1
Merged CTG Stack	327,594.54	4,692,057.79	5.5	50.9	3.0
2 MW Cold Start Emergency Engine	327,612.55	4,692,070.18	5.5	28.5	0.61
Cooling Tower 11A	327,552.38	4,692,017.83	2.73	29.7	6.8
Cooling Tower 11B	327,545.00	4,692,012.54	2.73	29.7	6.8
Cooling Tower 12A	327,558.64	4,692,008.53	2.73	29.7	6.8
Cooling Tower 12B	327,550.46	4,692,003.71	2.73	29.7	6.8
Cooling Tower 13A	327,563.45	4,692,001.47	2.73	29.7	6.8
Cooling Tower 13B	327,555.91	4,691,996.01	2.73	29.7	6.8

Oil is intended to be used only in the case of gas interruption (curtailment, gas supply emergency, or any required testing), however it is still included in the modeling. The source parameters and emission rates are shown in Tables A-6 and A-7 for the worst case load conditions for each pollutant and averaging time. The source parameters and emission rates for the 2 MW cold start emergency engine and cooling towers #11-13 are provided in Table A-8.

Table A-6 New CTG Source Characteristics and Emission Rates for 1 CTG with HRSG (Operational Scenario 1)

Pollutant	Avg. Period	Exit Velocity (m/s)	Exit Temp (°K)	Emission Rate (g/s)	Fuel	Load Condition
PM ₁₀	24-Hour	21.5	380.4	1.39	ULSD	Case 9: 60°F, Turbine A, 100% Load, Duct Burner On
PM _{2.5}	24-Hour	21.5	380.4	1.39	ULSD	Case 9: 60°F, Turbine A, 100% Load, Duct Burner On
	Annual	17.2	355.4	0.88 ¹	NG	I. Annual, Duct Burners On, Turbine A

¹ Emission rate reflects the potential emission limit specified in the air plan approval application.

Table A-7 New CTG Source Characteristics and Emission Rates for 2 CTGs with HRSGs (Operational Scenario 2)

Pollutant	Avg. Time	Exit Velocity (m/s)	Exit Temp (°K)	Emission Rate ¹ (g/s)	Fuel	Load Condition ²
PM ₁₀	24-Hour	19.2	380.4	2.35	ULSD	Case 2.k: 60°F, 75% Load, ULSD, Duct Burner On
PM _{2.5}	24-Hour	24.1	380.4	2.99	ULSD	Case 2.j: 0°F, 100% Load, ULSD, Duct Burner On
	Annual	17.2	355.4	1.76 ³	NG	II. Annual

¹ Emission rate is the total for both CTGs.

² Condition is modeled as a merged flue for CTG 1 and 2.

³ Emission rate reflects the potential emission limit specified in the air plan approval application.

Table A-8 New 2 MW Cold Start Emergency Engine and Cooling Tower Source Characteristics and Emission Rates

Source	Exit Temp (K)	Exit Velocity (m/s)	Short Term/ Annual	PM ₁₀ / PM _{2.5} (g/s)
2 MW Cold Start Emergency Engine	673.2	24.7	Short-Term	1.6E-2 ¹
			Annual ²	1.8E-4
Cooling Towers #11, 12, 13 per cell (6)	298.7	8.0	N/A	4.4E-3

¹Emission rate is scaled to reflect that MIT will not operate this engine any more than 8 hours in a given day

²Emission rate is scaled by 300/8760 per EPA Guidance (www.epa.gov/nsr/documents/20100629no2guidance.pdf) to reflect the intermittent operation of the emergency engine.

MIT Existing Facility Sources

As part of the permitting effort, MassDEP has the option to require demonstration that the full MIT facility will comply with the NAAQS. Boiler No. 9 was recently permitted (2011) and full facility compliance was achieved then. However, since then there have been new nearby structures either built or proposed to be built. This modeling analysis takes those new structures into account and the operational changes to the existing sources described previously. This modeling analysis also relies upon the load analysis conducted during the Boiler No. 9 permitting effort (Table A-10 reproduces the results of this load analysis). During the interim period where the existing CTG is still operating in conjunction with one new CTG/HRSG, Boilers No. 7 & 9 will not concurrently burn ULSD, after the existing CTG is decommissioned this restriction will be lifted and in the event of an emergency both Boilers No. 7 & 9 would be capable of burning ULSD. The source parameters and emission rates used for this analysis are presented in Tables A-9, A-10 and A-11.

Emissions from Boilers Nos. 3, 4 and 5 are vented out the brick stack on the roof of the CUP. The existing turbine #1 stack and the emergency generator stack are also located on the roof of the CUP. Boilers Nos.7 and 9 are located adjacent to Building N16A at 60 Albany Street, across the railroad tracks from the main CUP building. Exhaust from both Boiler No. 7 and Boiler No. 9 are combined and vent through a common stack.

Table A-9 Physical Stack Characteristics for the MIT Existing Sources

Stack	UTM E (m)	UTM N (m)	Base Elevation (m)	Stack Height (m)	Stack Diameter (m)
Boilers No. 7 & 9 Stack	327,510.2	4,692,006.1	2.73	35.1	1.7
Boilers No. 3,4,5	327,570.3	4,691,983.3	2.74	54.0	3.4
Turbine #1	327,575.2	4,691,973.9	2.74	36.6	1.8
Generator #01	327,595.7	4,691,984.2	2.74	19.4	0.4
Cooling Tower 1A	327,604.2	4,692,009.7	2.73	18.1	4.4
Cooling Tower 1B	327,609.4	4,692,013.8	2.73	18.1	4.4
Cooling Tower 2A	327,614.7	4,692,016.6	2.73	18.1	4.4
Cooling Tower 2B	327,619.5	4,692,020.0	2.73	18.1	4.4
Cooling Tower 3A	327,545.7	4,692,010.4	2.73	20.6	6.2
Cooling Tower 3B	327,541.6	4,692,016.3	2.73	20.6	6.2
Cooling Tower 4A	327,553.7	4,692,015.4	2.73	20.6	6.2
Cooling Tower 4B	327,549.8	4,692,021.9	2.73	20.6	6.2
Cooling Tower 5	327,571.0	4,691,990.9	2.73	17.4	2.5
Cooling Tower 6	327,576.8	4,691,994.7	2.73	17.4	2.5
Cooling Tower 7A	327,522.7	4,691,998.6	2.73	20.6	4.9
Cooling Tower 7B	327,528.5	4,692,002.2	2.73	20.6	4.9
Cooling Tower 7C	327,518.9	4,692,004.9	2.73	20.6	4.9
Cooling Tower 7D	327,523.9	4,692,008.3	2.73	20.6	4.9
Cooling Tower 8A	327,513.3	4,692,013.3	2.73	20.6	5.0
Cooling Tower 8B	327,518.5	4,692,016.4	2.73	20.6	5.0
Cooling Tower 8C	327,514.5	4,692,022.9	2.73	20.6	5.0
Cooling Tower 8D	327,509.3	4,692,019.3	2.73	20.6	5.0

Table A-9 Physical Stack Characteristics for the MIT Existing Sources (Continued)

Stack	UTM E (m)	UTM N (m)	Base Elevation (m)	Stack Height (m)	Stack Diameter (m)
Cooling Tower 9A	327,501.1	4,691,981.7	2.73	10.0	4.0
Cooling Tower 9B	327,497.6	4,691,980.0	2.73	10.0	4.0
Cooling Tower 9C	327,493.8	4,691,976.7	2.73	10.0	4.0
Cooling Tower 9D	327,490.3	4,691,975.0	2.73	10.0	4.0
Cooling Tower 10A	327,542.2	4,692,034.4	2.73	30.2	8.0
Cooling Tower 10B	327,534.2	4,692,027.3	2.73	30.2	8.0

Table A-10 Worst-case Operating Conditions for Existing MIT Stacks by Pollutant and Averaging Period¹

Pollutant	Averaging Period	Boiler No. 7/9 Stack	Boilers No. #3,4,5	CTG
PM ₁₀	Short-term	Boiler No. 9 alone full load	Full load	Full load
	Annual	Boiler No. 9 alone full load	Minimum Load	Full load
PM _{2.5}	Short-term	Boilers No. 7 and 9 ²	Full load	Full load
	Annual	Boiler No. 9 alone full load	Minimum Load	Full load

¹Reproduced from Table F-5 of the Boiler 9 Modeling Report, dated February 2011.

² For Operational Scenario 1, Boilers No. 7 & 9 will not concurrently burn ULSD therefore, the worst case scenario is Boiler No. 9 alone on full load burning ULSD.

Table A-11 Existing MIT Source Characteristics and Emission Rates

Stack	Operating Condition	Short-Term/ Annual	Exit Temp (K)	Exit Velocity (m/s)	PM ₁₀ (g/s)	PM _{2.5} (g/s)
Boilers No. 7 & 9	Boilers No. 7 & 9 (full load)	Short-Term	473.7	17.68	0.83	0.83
		Annual			-	0.29
	Boiler No. 9 only (full load)	Short-Term	430.4	8.06	0.45	0.45
		Annual			-	0.164
Boilers No. 3,4,5	Full Load	Short-Term	430.4	5.91	2.62	2.62
		Annual			-	1.45
	Minimum Load	Short-Term	405.4	0.73	0.32	0.32
		Annual			-	0.179
Turbine #1	Full Load	Short-Term	405.4	35.79	1.756	1.756
		Annual			-	0.63
Generator	Full Load	Short-Term	790.3	61.94	9.58E-2	9.58E-2
		Annual			-	3.28E-3
Cooling Tower 1 per cell (2)	N/A	N/A	298.7	8.0	3.33E-3	3.33E-3
Cooling Tower 2 per cell (2)	N/A	N/A	298.7	8.0	3.33E-3	3.33E-3
Cooling Tower 3 per cell (2)	N/A	N/A	298.7	8.0	5.86E-3	5.86E-3
Cooling Tower 4 per cell (2)	N/A	N/A	298.7	8.0	5.18E-3	5.18E-3
Cooling Tower 5	N/A	N/A	298.7	8.0	2.15E-3	2.15E-3
Cooling Tower 6	N/A	N/A	298.7	8.0	2.15E-3	2.15E-3
Cooling Tower 7 per cell (4)	N/A	N/A	298.7	8.0	4.91E-3	4.91E-3
Cooling Tower 8 per cell (4)	N/A	N/A	298.7	8.0	4.91E-3	4.91E-3
Cooling Tower 9 per cell (4)	N/A	N/A	298.7	8.0	2.65E-3	2.65E-3
Cooling Tower 10 per cell (2)	N/A	N/A	298.7	8.0	4.40E-3	4.40E-3

A-3.4 Urban/Rural Analysis

The USGS topographic quadrangle maps in the vicinity of the project were used to determine whether the land-use pattern in the environs of MIT is urban or rural for modeling purposes. The EPA recommended procedure in *The Guideline on Air Quality Models* (EPA, 2005) was followed to determine urban/rural classification using the Auer (1977) land use technique. The land use within the total area circumscribed by a 3 kilometer radius circle around the MIT CUP has been classified using the meteorological land use typing scheme shown in Table A-12. If the land use types I1, I2, C1, R2 and R3 account for 50 percent or more of the area, then urban dispersion coefficients should be used. Figure A-5 shows the 3 km radius around the project site. Observation of USGS topographic map shows that the area within a 3 kilometer radius of the MIT CUP is a predominantly urban setting. Therefore urban dispersion coefficients were used in the AERMOD modeling.

Table A-12 Identification and Classification of Land Use

Type	Use and Structures	Vegetation
I1	Heavy Industrial Major chemical, steel and fabrication industries; generally 3-5 story buildings, flat roofs	Grass and tree growth extremely rare; < 5% vegetation
I2	Light-Moderate Industrial Rail yards, truck depots, warehouses, industrial parks, minor fabrications; generally 1-3 story buildings, flat roofs	Very limited grass, trees almost absent; < 5% vegetation
C1	Commercial Office and apartment buildings, hotels; > 10 story heights, flat roofs	Limited grass and trees; < 15% vegetation
R1	Common Residential Single family dwellings with normal easements; generally one story, pitched roof structures; frequent driveways	Abundant grass lawns and light-moderately wooded; > 70% vegetation
R2	Compact Residential Single, some multiple, family dwellings with close spacing; generally < 2 story, pitched roof structures; garages (via alley), no driveways	Limited lawn sizes and shade trees; < 30% vegetation
R3	Compact Residential Old multi-family dwellings with close (< 2m) lateral separation; generally 2 story, flat roof structures; garages (via alley) and ashpits, no driveways	Limited lawn sizes, old established shade trees; < 35% vegetation
R4	Estate Residential Expansive family dwellings on multi-acre tracts	Abundant grass lawns and lightly wooded; > 95% vegetation

Table A-12 Identification and Classification of Land Use (Continued)

Type	Use and Structures	Vegetation
A1	Metropolitan Natural Major municipal, state or federal parks, golf courses, cemeteries, campuses, occasional single story structures	Nearly total grass and lightly wooded; > 95% vegetation
A2	Agricultural; Rural	Local crops (e.g., corn, soybean); > 95% vegetation
A3	Undeveloped; Uncultivated; wasteland	Mostly wild grasses and weeds, lightly wooded; > 90% vegetation
A4	Undeveloped Rural	Heavily wooded; > 95% vegetation
A5	Water Surfaces: Rivers, lakes	

A-3.5 Background Air Quality Data



Modeled concentrations due to emissions from the project are added to ambient background concentrations to obtain total concentrations. These total concentrations were compared to the NAAQS and MAAQS. To estimate background pollutant levels representative of the area, the most recent air quality monitor data reports published by MassDEP were obtained for 2012 through 2014. Background concentrations were determined from the most representative available monitoring stations to the MIT CUP. The most representative monitoring site is also the closest monitoring site, located at Kenmore Square in Boston, MA, approximately 0.9 miles from the MIT CUP. The urban environment surrounding the monitor in Boston is similar to the urban environment in Cambridge near the MIT CUP. All pollutants are monitored at Kenmore Square, i.e., PM₁₀, and PM_{2.5}. A summary of the background air quality concentrations based on the 2012-2014 data are presented in Table A-13. For the short-term averaging periods, the form of the standard value is used, and the highest monitored value is used for annual averages.



Table A-13 Observed Ambient Air Quality Concentrations and Selected Background Levels

Pollutant	Averaging Period	2012	2013	2014	Background Level	NAAQS
PM ₁₀ (µg/m ³)	24-Hour	28.0	50.0	53.0	53.0	150
PM _{2.5} (µg/m ³)	Annual ¹	9.0	8.0	6.0	7.7	12


¹ Background level for Annual PM_{2.5} is the average concentration of three years.

LEGEND

-  New Cogeneration Project
-  3-km Radius

Scale 1:36,000 0 1,500 3,000
1 inch = 3,000 feet  Feet 

Basemap: USGS Quadrangles, MassGIS



MIT Cogeneration Project Cambridge, Massachusetts

For this analysis some level of temporal pairing of modeled and monitoring data was used. 24-hour PM_{2.5} is not represented in Table A-13 because background values of PM_{2.5} was used in a post-processing step within AERMOD. For PM_{2.5} the 3-year (2012-2014) average 98th percentile seasonal concentration was utilized consistent with the Tier 2 approach detailed in the EPA, Guidance for PM_{2.5} Permit Modeling Memorandum was utilized (EPA, May 2014, EPA-454/B-14-001).

MIT utilized 3-years (2012 – 2014) of PM_{2.5} 24-hr monitoring concentrations from the Kenmore monitoring site (AQS 25-025-0002) for utilization in AERMOD modeling run. These monitored concentrations are on a once every three day cycle, therefore consistent with EPA guidance, the concentrations for each year were ranked and the top two concentrations removed from further consideration. The remaining concentrations were then separated into seasons by year, and the maximum value for each season was then averaged over the 3-year period.

A-3.5.1 Justification to use SILs

If the monitoring data shows that the difference between the NAAQS and the monitored background concentration in the area is greater than the EPA SIL value for that pollutant and averaging period, then EPA believes it would be sufficient to conclude that a proposed source with an impact below the SIL value will not cause or contribute to a violation of the NAAQS and to forego a more comprehensive modeling analysis for that pollutant for that averaging period. Table A-14 presents the difference between the NAAQS and the monitored background concentration, compared to the SILs. As shown in Table A-14, all averaging periods for each pollutant has a delta between the monitored value and the NAAQS which is greater than the respective SIL, therefore use of the SILs for PM₁₀, and PM_{2.5} as de minimis levels is appropriate.

Table A-14 Comparison of the Difference between the Monitored Air Quality Concentrations and the NAAQS to the Significant Impact Levels

Pollutant	Averaging Period	Background Level (µg/m ³)	NAAQS (µg/m ³)	Delta (NAAQS-Bkgrnd) (µg/m ³)	Significant Impact Level (µg/m ³)
PM ₁₀	24-Hour	53.0	150	97.0	5
PM _{2.5}	24-Hour	18.2	35	16.8	1.2
	Annual	7.7	12	4.3	0.3

A-3.6 Good Engineering Practice Stack Height Determination

The GEP stack height evaluation of the facility has been conducted in accordance with the EPA revised Guidelines for Determination of Good Engineering Practice Stack Height (EPA, 1985). The formula, as defined by the EPA guidelines, for the GEP stack height is:

$$H_{GEP} = H_b + 1.5L$$

where H_{GEP} = GEP stack height,

H_b = Height of adjacent or nearby structures,

L = Lesser of height or maximum projected width of adjacent or nearby building, i.e., the critical dimension, and

Nearby = Within $5L$ of the stack from downwind (trailing edge) of the building.

A GEP analysis was conducted to determine the GEP formula stack height for each stack to account for potential downwash from nearby structures. The latest version of the EPA Building Profile Input Program (BPIP-Prime) was run for all stacks and buildings in the vicinity of the project to create the building parameter inputs to AERMOD. The new and proposed construction on Albany Street and Main Street (Novartis buildings) are included. A GEP height of 124 meters was calculated for each stack with the 50.8 meter tier of the new 610/650 Main Street building as the controlling structure for determining the GEP height. Figure A-6 shows the structure footprints and stack locations input into BPIP-Prime (heights are depicted in the figure). Each of the stacks modeled are below their GEP height and therefore exhaust emissions will experience the aerodynamic effects of downwash. Wind direction specific building parameters generated by BPIP-Prime were input into AERMOD to account for potential downwash from nearby structures in the dispersion calculations.


LEGEND

- Stack
- Building Footprint/Tier with Height Above Grade (in Feet)

Scale 1:3,000
1 inch = 250 feet

0 125 250 Feet

Basemap: 2013 Orthophotography, MassGIS



MIT Cogeneration Project Cambridge, Massachusetts

A-4 AIR QUALITY IMPACT ANALYSES

The project conducted comprehensive air quality modeling analyses to demonstrate that the proposed project's air quality impacts would be in compliance with all Federal requirements. The ambient pollutant concentrations associated with the Project are addressed in the detailed air quality analysis discussed in this section. The following analyses were included:

- ◆ Load Analysis for new CTGs
- ◆ Modeling of PM₁₀, and PM_{2.5} for comparison with the SILs
- ◆ Modeling of PM₁₀, and PM_{2.5} for comparison with the NAAQS, including interactive source modeling
- ◆ Modeling of PM₁₀, and PM_{2.5} for comparison with the PSD Increments
- ◆ VISCREEN modeling

Impacts of PM₁₀, and PM_{2.5} emissions were modeled for comparison to ambient air quality standards. The modeling approach followed the guidance in the U.S. EPA Guideline on Air Quality Models (EPA, 2005) and the Massachusetts Modeling Guidance (MassDEP, 2011) to ensure that the ambient concentrations are protective of all applicable air quality standards.

In the New Source Review (NSR) Workshop Manual (EPA, 1990) the dispersion modeling analysis is separated into two distinct phases: 1) the preliminary analysis, and 2) a full impact analysis. In the preliminary analysis only the significant increase in potential emissions of a pollutant from a proposed new source or the significant net emissions increase of a pollutant from a proposed modification are modeled. The results of this analysis are used to determine:

- ◆ the worst-case stack parameters; and
- ◆ which criteria pollutants require a full impact analysis;
- ◆ the receptor locations to be used in the interactive modeling analysis (if necessary).

The EPA does not require a full impact analysis for a particular pollutant if the results of the preliminary analysis indicate the emissions from the proposed source or modification will not increase ambient concentrations by more than pollutant specific SILs (see Table A-2).

Per MassDEP Modeling Guidance for Significant Stationary Sources of Air Pollution (MassDEP, 2011), if impacts are below SILs, a compliance demonstration may still be required to ensure that the combined emissions from the existing facility and the proposed modification will not cause or contribute to a NAAQS violation for that pollutant.

A-4.1 Modeling Methodology

The project consists of the addition of two new CTGs and a 2MW cold start emergency engine at a new building along Albany Street, adjacent to the cooling towers. AERMOD modeling for each potential fuel burned at various ambient temperatures and load cases was performed for the new CTGs to determine the worst-case impact for each of the potential Operational Scenarios listed in Table A-4. Results from this analysis are presented in Section A-5.1.

The worst-case operating conditions for the new CTGs were then modeled with the 2MW cold start emergency engine and the cooling towers to assess the PM₁₀, and PM_{2.5} concentrations which are compared to the SILs presented earlier in Table A-2. Results from this analysis are presented in Section A-5.2.

If the maximum predicted impacts of a pollutant due to the emission increase from the existing facility are below the applicable SILs, the predicted emissions from the proposed modifications are considered to be in compliance with the NAAQS for that pollutant. However a compliance demonstration was conducted to ensure that the combined emissions from the existing facility and the proposed modification will not cause or contribute to a NAAQS violation for that pollutant (MassDEP, 2011). The appropriate modeled concentrations were combined with appropriate ambient background concentrations prior to comparison with the NAAQS.

If the maximum predicted impacts of a pollutant due to the emission increase from the existing facility are at or above the applicable SILs, and there are nearby sources of that pollutant that could significantly interact with emissions from the facility's proposed modification, the predicted air quality impacts from the existing facility as modified along with the predicted impacts from nearby significant sources should be added to the representative background and compared to the NAAQS for that pollutant (MassDEP, 2011).

EPA (2013) has adopted guidance regarding secondary PM_{2.5} formation in modeling analyses.

- ◆ Case 1: If PM_{2.5} emissions < 10 tpy and NO_x & SO₂ emissions < 40 tpy, then no PM_{2.5} compliance demonstration is required.
- ◆ Case 2: If PM_{2.5} emissions > 10 tpy and NO_x & SO₂ emissions < 40 tpy, then PM_{2.5} compliance demonstration is required for direct PM_{2.5} emission based on dispersion modeling, but no analysis of precursor emissions from the project source is necessary.

- ◆ Case 3: If PM_{2.5} emissions > 10 tpy and NO_x &/or SO₂ emissions > 40 tpy, then PM_{2.5} compliance demonstration is required for direct PM_{2.5} emission based on dispersion modeling, AND the applicant must account for impact of precursor emissions from the project source.
- ◆ Case 4: If PM_{2.5} emissions < 10 tpy and NO_x &/or SO₂ emissions > 40 tpy, then PM_{2.5} compliance demonstration not required for direct PM_{2.5} emissions, BUT the applicant must account for impact of precursor emissions from the project source.

Since this project falls into Case 2 (PM_{2.5} = 50.1 tpy, NO_x = 26.4 tpy and SO₂ = 7.0 tpy), only direct emissions of PM_{2.5} were modeled, and no analysis of precursor emissions is necessary.

In January 2013, EPA vacated the PSD rules for using the SIL for PM_{2.5}. As a result, EPA has allowed a modified SIL comparison to be acceptable for PM_{2.5}. One can justify the use of the SIL if the difference between the NAAQS and the measured background in the area is greater than the applicable SIL value (refer to discussion in Section A-3.5-1).

Since the project is PSD for particulate matter, additional air quality analyses are necessary. PSD Increment modeling is required for particulate matter (PM₁₀ and PM_{2.5}). The determined worst-case operating condition for the new CTGs is used in the AERMOD increment modeling for Operational Scenario 2 (final building configuration for the new CTGs). The PM increment-consuming sources (i.e., new CTGs, 2MW cold start emergency engine, increase in gas-fired operating hours for Boilers No. 7 and 9 to allow year-round operation and new cooling towers) are modeled at their maximum allowable emissions rates, while the increment expanding sources at MIT (i.e., retiring existing CTG, switch from No. 6 oil to natural gas on Boilers No. 3, 4, & 5, and switch from No. 2 oil to primarily natural gas on Boilers No. 7 & 9, and retiring cooling towers) are modeled at their maximum actual emission rates (using a negative emission rate in AERMOD). Since the initial application was filed with MassDEP MIT has withdrawn the request to increase gas-fired operating hours for Boilers 7 & 9. However, these boilers have conservatively been left in the modeling analysis.

A visibility analysis was conducted using the U.S. EPA VISCREEN model for the Lye Brook Wilderness Area in southern Vermont. PSD regulations require analysis of air quality impacts on sensitive vegetation types, with significant commercial or recreational value, or sensitive types of soil.

A-4.2 Air Quality Model Selection and Options

The U.S. EPA approved air quality model used for this analysis is AERMOD (v15181). Modeling was performed to identify maximum impact conditions and comparison of receptor concentrations to applicable levels and thresholds. The modeling of the maximum impact condition for each pollutant and averaging period was based on expected operating parameters and emission rates for both fuel options presented in Tables A-5 through A-11.

The AERMOD model is a steady state plume model using Gaussian distributions that calculates concentrations at each receptor for every hour in the year. The model is designed for rural or urban applications and can be used with a rectangular or polar system of receptors that are allowed to vary with terrain. AERMOD is designed to operate with two preprocessor codes: AERMET processes meteorological data for input to AERMOD, and AERMAP processes terrain elevation data and generates receptor information for input to AERMOD. The AERMOD model was selected for the air quality modeling analysis because of several model features that properly simulate the proposed facility environs, including the following:

- ◆ Concentration averaging time ranging from one hour to one year;
- ◆ Ability to model multiple sources; and
- ◆ Estimating cavity impacts; and
- ◆ Use of actual representative hourly average meteorological data; and
- ◆ Ability to calculate simple, complex, and intermediate terrain concentrations.

The AERMOD model has incorporated the latest EPA building downwash algorithm, the Plume Rise Model Enhancements (PRIME), for the improved treatment of building downwash. PRIME can also account for the stack placement relative to the building thereby allowing for the ability to estimate impacts in the cavity region near the stack.

The AERMODView graphical user interface (GUI) provided by Lakes Environmental, Inc. (Lakes) was used to set up the model inputs for this project. Additionally, Lakes provides a multi-processor version of the AERMOD executable which allows for significantly faster processing while producing identical output to the standard EPA version. For this project, the multi-processor version of AERMOD was used.

A complete technical description of the AERMOD model may be found in the User's Guide for AERMOD (EPA, 2004).

For 24-hr PM_{2.5} NAAQS modeling, the EPA Tier II methodology was employed. As part of the Tier II methodology it is necessary to demonstrate that there is a lack of a temporal correlation between modeled and monitored PM_{2.5} concentrations. The worst-case 24-hr PM_{2.5} load condition is when the new CTG(s) are burning ULSD. As mentioned previously, backup ULSD will be used for up to the equivalent heat input of 48 hours per year for testing and up to the equivalent heat input of 168 hours per year including testing and

periods when natural gas is unavailable. Therefore, it is extremely unlikely that the maximum 24-hour modeled concentration on ULSD would coincide with the maximum 24-hr monitored PM_{2.5} concentration and therefore utilization of the EPA Tier II methodology is justified.

Modeling for MIT was performed with all regulatory options in AERMOD set.

A-4.3 Meteorological Data for Modeling

The meteorological data required to run AERMOD includes five years of representative surface and upper air observations. Hourly surface data from the National Weather Service (NWS) station at Boston Logan Airport with twice-daily upper air soundings from Gray, ME were used. These stations are the closest to and most representative of the Cambridge area. Logan Airport is approximately 4 miles to the east of MIT. The meteorological data for the period 2010-2014 were processed using AERMET (15181), AERMINUTE and AERSURFACE programs. The profile base elevation for this station is 6 meters.

The methodology used in the meteorological data processing with AERMET (15181) is based on U.S. EPA guidance, as set out in the March 2013 EPA memo "Use of ASOS Meteorological Data in AERMOD Dispersion Modeling", 40 CFR Part 51 Appendix W, the AERSURFACE user's guide, and other U.S. EPA publications, and is described below:

- ◆ Land use data is determined using the latest version (13016) of the AERSURFACE utility.
- ◆ For AERSURFACE, 12 directional sectors and seasonal variation in land use parameters are used. A 1 km radius around the measurement site is used to determine surface roughness lengths.
- ◆ Per the AERSURFACE User's Guide, surface moisture characterization is determined by comparing annual precipitation totals to the 30-year climatological norm for the area: a year is classified as "dry" if annual precipitation was less than the 30th percentile value in the 30-year distribution, "wet" if greater than the 70th percentile, and "average" if between the 30th and 70th percentiles. Based on the Boston precipitation data 2010 and 2011 were classified as 'wet', and 2012 and 2013 were classified as "dry" and 2014 was classified as "average".
- ◆ AERMINUTE (version 14337) is used to incorporate 1-minute wind observations. A 0.5 m/s wind speed threshold is used for both AERMINUTE wind data.
- ◆ The MODIFY keyword, which performs automated QA/QC and data improvement algorithms on raw upper air data and is an established component of AERMET, is used.


- ◆ In order to make a determination as to whether Boston experiences continuous snow cover during the winter months, the 30-year climatological (1981-2010) monthly normal snow depth data was used. During this period Boston experienced at least an inch of snow on the ground less than 50% of the time. Therefore, the continuous snow cover option was not utilized in AERSURFACE as the site does not experience continuous snow cover during the winter months.
- ◆ AERMOD-ready meteorological data is assessed for completeness using the U.S. EPA's PSD meteorological data standard – data must be 90% complete on a quarterly basis, with four consecutive quarters meeting that standard being necessary for one year of meteorological data to be considered valid.

A composite wind rose for the five years of meteorological data to be used in the modeling analysis is presented in Figure A-7. The winds are predominantly from the western sector (SSW through NW).

A-4.4 Receptor Grid

The same nested Cartesian grid of receptors that was used in previous modeling (MIT Boiler No. 9, 2011) was used in this study. The grid was generated with spacing of 20 meters in a 40 meter by 40 meter bounding box centered on the main CUP stack, 50 meter spacing out to 200 meters, 100 meter spacing out to 2 km, 500 meter spacing out to 5 km, and 1000 meter spacing out to 10 km. The nested grid of receptors was converted to discrete receptors and those falling on MIT buildings were removed from the analysis, allowing for ground level concentrations to be predicted.

Terrain around the immediate site is relatively flat. The terrain elevation for each receptor was obtained electronically from USGS digital terrain data. The National Elevation Dataset (NED), with a resolution of 1/3 arc-second (approximately 10 meters) was processed using the AERMAP (11103) program. Figure A-8 shows the nested receptor grid. A total of 2,415 receptors were modeled in AERMOD. Elevations and hill heights for each receptor as well as the base elevations of the existing MIT sources modeled and buildings entered in BPIP-Prime were determined through the AERMAP processing.




**WINDSPEED
(m/s)**

- ≥ 10.80
- 8.20 - 10.80
- 5.10 - 8.20
- 3.10 - 5.10
- 1.50 - 3.10
- 0.50 - 1.50

Calms: 0.17%

**WIND DIRECTION
(blowing from)**

MIT Cogeneration Project Cambridge, Massachusetts



MIT Receptor Spacing:
 50 m out to 200 m
 100 m out to 2 km
 500 m out to 5 km
 1000 m out to 10 km

MIT Cogeneration Project Cambridge, Massachusetts

A-5. AIR QUALITY IMPACT RESULTS

A-5.1 CTG Load Analysis

A range of potential operating loads (40%, 50%, 65%, 75%, and 100%) were modeled for the new CTGs using three ambient temperatures (0, 50, and 60° F) with the duct burners on and off. 40% load is the minimum load on natural gas where emissions are guaranteed from the CTG manufacturer (50% load is the minimum load on ULSD), and 100% load represents maximum load. The ambient temperatures utilized represent the worst case heat input (0°F) and an average heat input ambient temperature (50 °F and 60 °F). The CTGs may burn natural gas with a backup fuel of ULSD. The HRSGs will only operate on natural gas. Twenty-eight options over a range of loads and ambient temperatures as shown in Attachment A were modeled to determine the case resulting in the highest air quality impact of each pollutant for each averaging period for each of the two Operational scenarios.

The results of the load analysis are relied on for the remainder of the modeling. The cases resulting in the highest air quality impacts are listed in the Section A-3.3, the source data section, in Tables A-6 and A-7.

A-5.2 Significant Impact Level Analysis

The predicted air quality levels of the criteria pollutants were assessed through the initial modeling analysis of the project sources, including the new CTGs, 2MW cold start emergency engine and the cooling towers (PM only). Each of the Operating Scenarios was modeled for comparison with the SILs. Table A-15 presents the criteria pollutant concentrations compared to the SILs for each operating scenario. As PM₁₀ and PM_{2.5} are above the SILs, cumulative impact modeling was required to be performed for these operational scenarios for the pollutants/averaging period combinations with impacts above the SILs.

Table A-15 Proposed Project AERMOD Modeled Results for Operational Scenarios 1 and 2 Compared to Significant Impact Levels (SILs)

Poll.	Avg. Time	Form	Max. Modeled Conc. ($\mu\text{g}/\text{m}^3$)	SIL ($\mu\text{g}/\text{m}^3$)	% of SIL	Period	Receptor Location (m) (UTME, UTMN, Elev.)
<i>Operational Scenario 1 (1 new CTG/HRSG)</i>							
PM ₁₀	24-hr	H	12.5	5	250%	1/29/10 hr 24	327650.08, 4692062.84, 2.74
PM _{2.5}	24-hr ⁽¹⁾	H	9.84	1.2	820%	2010-2014	327550.08, 4692062.84, 2.73
	Ann. ⁽¹⁾	H	0.91	0.3	303%	2010-2014	327550.08, 4692112.84, 2.73
<i>Operational Scenario 2 (2 CTGs/HRSGs)</i>							
PM ₁₀	24-hr	H	14.2	5	284%	1/29/10 hr 24	327650.08, 4692062.84, 2.74
PM _{2.5}	24-hr ⁽¹⁾	H	10.1	1.2	844%	2010-2014	327850.08, 4692362.84, 2.74
	Ann. ⁽¹⁾	H	0.98	0.3	327%	2010-2014	327850.08, 4692362.84, 2.74

¹ High 1st High maximum concentrations averaged over 5 years.

A-5.3 National Ambient Air Quality Analysis

Since the proposed project is a modification to an existing facility, a compliance demonstration was conducted to ensure that the combined emissions from the existing facility and the proposed modification will not cause or contribute to a NAAQS violation for that pollutant (MassDEP, 2011). For those pollutants and averaging periods with project impacts above the SILs, cumulative source modeling was conducted and is described in Section A-5.3.2.

Post-processing of 24-hour PM_{2.5}

As AERMOD is run for the 24-hour PM_{2.5} impacts, the daily values of PM_{2.5} monitored background were input directly to the model (as seasonal values). The appropriate background value was added to the modeled impact depending on the season. Then the 98th percentile daily total impact (modeled + background) at each receptor for the multiyear average (5 years) was determined and the results compared to the 24-hour PM_{2.5} standard.

A-5.3.1 MIT Sources

The project sources were modeled with the existing MIT CUP sources; then the appropriate modeled concentrations were combined with appropriate ambient background concentrations prior to comparison with the NAAQS. For Scenario 2, the flues for the two new CTGs are merged and modeled with an effective diameter of 9.9 ft. Pending approvals, MIT intends to begin installing the new CTGs in 2019 and complete installation and shakeout in late 2019 or early 2020. The existing Siemens CTG will be fully retired following completion of installation and shakeout for both of the new units in 2020. At no time will the existing Siemens CTG be operating at the same time as the new Solar Titan 250 CTGs. Table A-16 presents the predicted concentrations compared to the NAAQS for each Operating Scenario. The total concentration (modeled plus background) are below the NAAQS.

Table A-16 AERMOD Model Results for the Full MIT Facility Compared to the NAAQS

Poll.	Avg. Period	Form	AERMOD Modeled Conc. ($\mu\text{g}/\text{m}^3$)	Background Conc. ($\mu\text{g}/\text{m}^3$)	Total Conc. ($\mu\text{g}/\text{m}^3$)	NAAQS ($\mu\text{g}/\text{m}^3$)	% of NAAQS	Period	Receptor Location (m)
									(UTME, UTMN, Elev.)
<i>Operational Scenario 1 (1 new CTG/HRSG)</i>									
PM ₁₀	24-hour	H6H ¹	31.6	53	84.6	150	56%	12/13/10 hr 24	327500.08, 4692212.84, 2.73
PM _{2.5}	24-hour	H8H ²	16.6	16.5	33.1	35	94%	2010-2014	327550.08, 4692162.84, 2.73
	Annual	H	2.1	7.7	9.8	12	82%	2010-2014	327550.08, 4692112.84, 2.73
<i>Operational Scenario 2 (2 new CTGs/HRSGs)</i>									
PM ₁₀	24-hour	H6H ¹	23.6	53.0	76.62	150	51%	5/23/11 hr 24	327500.08, 4692162.84, 2.73
PM _{2.5}	24-hour	H8H ²	16.9	16.7	33.6	35	96%	2010-2014	327550.08, 4692062.84, 2.73
	Annual	H	1.9	7.7	9.56	12	80%	2010-2014	327550.08, 4692112.84, 2.73

¹ High 6th High over 5 years.

² High 8th High over 5 years.

A-5.3.2 Cumulative Impact Modeling

The results of the SILs analysis are used as the basis for the cumulative impact modeling. The project's impacts are above the 24-hr and annual PM_{2.5}, 24-hr PM₁₀ SILs at some receptor locations. Cumulative impact modeling is required at these receptors to verify that the project is not contributing significantly to a violation of the NAAQS.

Non-MIT facilities required for inclusion in the cumulative modeling are those emission sources within 10 km of the MIT CUP that emit significant PM_{2.5} or PM₁₀ emission rates (> 10 tpy PM_{2.5}, > 15 tpy PM₁₀ based on reported actual emissions). Four nearby facilities have been identified satisfying the criteria. The following facilities were identified as interactive sources for modeling purposes:

1. Veolia Kendall Station (~ 1.2 km to the east-northeast of MIT CUP)
2. Harvard Blackstone (~ 1.8 km to the west-northwest of MIT CUP)
3. MATEP (~ 3.0 km to the southwest of MIT CUP)
4. Boston Generating Mystic Station (~ 3.8 km to the north-northeast of MIT CUP)

Epsilon has worked with MassDEP to define the source parameters and emissions rates for the sources at the facilities proposed for the cumulative impact modeling. Title V operating permits for the facilities were reviewed. The emission rates used in the cumulative modeling represents the maximum permitted emission rates for each facility. The cumulative source parameters proposed in the modeling protocol have been revised prior to the modeling commencing. The parameters have been updated to better align the stack coordinates with the MIT modeling domain and to better reflect the operations at these facilities. In particular, the following changes were incorporated:

- ◆ A review of the most recent operating permit for Kendall Station resulted in the following updates:
 1. Revised the exit velocity for Kendall Station Babcock Wilson #1-2, based on Unit #1 being taken out of service.
 2. Revised the stack diameter for the Combined Cycle CTG
 3. Determine the NO_x emission rate for Kendall Station sources.
 3. Emission rates were adjusted because Kendall Station no longer burns No. 6 fuel oil.
- ◆ A review of the most recent operating permit for Mystic Station was used to determine the NO_x emission rate for Mystic Station sources.

Georeferenced MrSID basemaps were imported into AERMODview based on the NAD83 Datum, and the interactive source coordinates presented in the protocol were evaluated for accuracy. All stack and building UTM coordinates were adjusted to accurately reflect their locations with respect to the MIT modeling domain datum.

The table of source parameters and emission rates used in the cumulative modeling for the interactive sources is presented in Attachment B.

The latest version of the EPA Building Profile Input Program (BPIP-Prime) was run for all stacks and buildings in the vicinity of each facility to create the building parameter inputs to AERMOD. The cumulative AERMOD modeling accounts for potential downwash for each stack at each facility.

Cumulative AERMOD modeling was conducted for each of the project Operating Scenarios with predicted impacts above the SILs. The cumulative modeling included the project sources, existing MIT sources and the interactive sources listed in Attachment B. The cumulative impacts of all modeled sources plus the monitored background concentration are then compared to the NAAQS. The results of the cumulative source air quality modeling are presented in Table A-17.

The cumulative AERMOD modeling demonstrates that the project sources in any of the Operating Scenarios will not cause or contribute to a violation of the NAAQS.

Table A-17 AERMOD Model Results for the Full MIT Facility with Interactive Sources for Operational Scenarios 1 & 2 Compared to the NAAQS

Pollutant	Avg. Period	Form	Total Conc. ($\mu\text{g}/\text{m}^3$)	AERMOD Predicted Contribution ($\mu\text{g}/\text{m}^3$)					Bkgnd Conc. ($\mu\text{g}/\text{m}^3$)	NAAQS ($\mu\text{g}/\text{m}^3$)	% of NAAQS	Period	Receptor Location (m)
				MIT	Kendall Station	Harvard Blackstone	MATEP	Mystic Station					(UTME, UTMN, Elev.)
<i>Operational Scenario 1 (1 new CTG/HRSG)</i>													
PM ₁₀	24-hr	H6H	84.7	31.6	0.002	0.04	0.021	0.0047	53	150	56.5%	12/13/10 hr 24	327500.08, 4692212.84, 2.73
PM _{2.5}	24-hr	H8H	33.4	16.3	0.01	0.34	0.00	0.02	16.7	35	95.4%	2010-2014	324550.08, 4692062.84, 2.73
	Annual	H	11.2	2.6	0.18	0.51	0.05	0.21	7.7	12	93.6%	2010-2014	327550.08, 4692112.84, 2.73
<i>Operational Scenario 2 (2 new CTGs/HRSGs)</i>													
PM ₁₀	24-hr	H6H	76.7	23.6	0.0032	0.0092	0.01452	0.0099	53	150	51%	5/23/11 Hr: 24	327500.08, 4692162.84, 2.73
PM _{2.5}	24-hr	H8H	34.4	18.1	0.014	0.4	0.010	0.014	15.9	35	98%	2010-2014	327550.088, 4692062.84, 2.73
	Annual	H	11.0	2.34	0.18	0.51	0.05	0.21	7.7	12	92%	2010-2014	327550.08, 4692062.84, 2.73

A-5.4 PSD Increment Modeling

A PSD increment is the maximum allowable increase in concentration that is allowed to occur above a baseline concentration for a pollutant. The baseline concentration is defined for each pollutant (and relevant averaging period) and, in general, is the ambient concentration existing at the time that the first complete PSD permit application affecting the area is submitted. Significant deterioration is said to occur when the amount of new pollution would exceed the applicable PSD increment. Modeling to show that allowable increments are not exceeded must include existing sources that are both within the baseline area and were constructed after the PSD baseline date and can include increment expanding sources (those that have added controls or stopped operating) after the PSD baseline date. It is important to note, however, that the air quality cannot deteriorate beyond the concentration allowed by the applicable NAAQS, even if not all of the PSD increment is consumed.

The project is a major modification of an existing major source, subject to the requirement to obtain a PSD permit. PSD Increment modeling is required for PM₁₀ and PM_{2.5}. Epsilon has conferred with MassDEP Boston BWP Air Planning and Evaluation Branch to determine if the PM_{2.5} minor source baseline date has been established for the baseline area (county). It is believed that this application will establish the baseline date for PM_{2.5} when it is determined to be complete. MassDEP confirmed that the baseline has been set for PM₁₀ in Middlesex County. Increment-consuming sources (i.e., new CTGs, 2MW cold start emergency engine and cooling towers) will be modeled at their maximum allowable emissions rates, while the increment expanding sources at MIT (i.e., retiring existing CTG, switch from No.6 oil to No. 2 Fuel Oil on Boilers No. 3, 4, & 5, and reduction of ULSD firing to 168 hours/yr in Boilers No. 7 & 9, and retiring cooling towers) will be modeled at their maximum actual emission rates (using a negative emission rate in AERMOD). The previously determined worst-case operating condition for the new CTGs was used in the PSD increment modeling. However, for PM₁₀ the baseline has been established and the following sources will be included as increment consuming: GenOn Kendall Station, Harvard Blackstone, MATEP, and Mystic Generating Station. The actual emissions are determined for the existing sources at MIT in accordance with the October 1990 draft guidance in the New Source Review Workshop Manual, Prevention of Significant Deterioration and Nonattainment Area Permitting, which states the following:

For any increment-consuming (or increment-expanding) emissions unit, the actual emissions limit, operating level, and operating factor may all be determined from source records and other information (e.g., State emissions files), when available, reflecting actual source operation. For the annual averaging period, the change in the actual emissions rate should be calculated as the difference between:

- ◆ the current average actual emissions rate, and

- ◆ the average actual emissions rate as of the minor source baseline date (or major source baseline date for major stationary sources).

In each case, the average rate is calculated as the average over previous 2-year period (unless the permitting agency determines that a different time period is more representative of normal source operation).

For each short-term averaging period (24 hours and less), the change in the actual emissions rate for the particular averaging period is calculated as the difference between:

- ◆ the current maximum actual emissions rate, and
- ◆ the maximum actual emissions rate as of the minor source baseline date (or major source baseline date for applicable major stationary sources undergoing construction before the minor source baseline date).

In each case, the maximum rate is the highest occurrence for that averaging period during the previous 2 years of operation.

Following this guidance the source operation records were reviewed for the 2-year period of April 1st, 2013 – March 31st 2015 for Boilers No. 3, 4, 5, 7 & 9, and the existing CTG and duct burner. The maximum gas and oil usage were determined for a 24-hour period and the actual emission rate calculated based on the Lb/MMBtu permit limits in the current Title V operating permit for MIT. Emission statement data was reviewed for cooling towers 1, 2, 3, 4, 5, and 6.

The current actual emissions rates (annual emissions after the change) for MIT are as follows:

- ◆ For the new CTGs, the proposed permit limits for natural gas firing times, 8,592 hours/year plus the proposed permit limits for ULSD firing for 168 hours/year.
- ◆ For the new HRSGs, the proposed permit limits times 8,760 hours/year (natural gas only). This assumption of 8,760 hours per year of operation is a conservative approximation due to the fact that the duct burners are proposed with a limit equivalent to 4,380 hours of full load operation of both duct burners.
- ◆ For the new cold start emergency engine, the proposed permit limit times an annual operating restriction of 300 hours/year (ULSD)
- ◆ For Boilers No. 7 & 9, the proposed permit limits for natural gas firing times 8,592 hours/year plus the proposed permit limits for ULSD firing for 168 hours/year. This reflects the requested increase in allowable operating hours. Since the filing of the initial application, MIT has withdrawn the requested increase in allowable operating hours for Boilers 7 & 9, however these are conservatively included in the modeling.

- ◆ For Boilers No. 3, 4, & 5, the average of the actual total heat input (gas & oil) for the 2-year period of April 1st, 2013 – March 31st, 2015 times the natural gas per pound MMBtu permit limits in the current operating permit for MIT. Added to this are the permit limits for ULSD firing for 168 hours/year. Boilers No. 3, 4, & 5 will cease burning No. 6 oil prior to the new CTGs beginning normal operation (after installation and shakeout of the new units).
- ◆ For the cooling towers, the annual emission rate.

The PSD Increment modeling rates are summarized in Table A-18. Calculations are provided in Attachment C.

Table A-18 PM Emission Rates used in PSD Increment Modeling

<i>Increment Consuming Sources</i>		
	PM₁₀/PM_{2.5} Emission Rate short term (g/s)	PM_{2.5} Emission Rate annual (g/s)
New CTG 1 w/HRSG	PM ₁₀ : 1.17; PM _{2.5} : 1.49	0.88
New CTG 2 w/HRSG	PM ₁₀ : 1.17; PM _{2.5} : 1.49	0.88
Total	PM₁₀: 2.35; PM_{2.5}: 2.99	1.76
Boiler No. 3	0.071 (NG)	0.037 (NG/ULSD)
Boiler No. 4	0.069 (NG)	0.040 (NG/ULSD)
Boiler No. 5	0.076 (NG)	0.048 (NG/ULSD)
Total	0.215	0.126
Boiler No. 7 ¹	0.063 (NG)	-
Boiler No. 9 ¹	0.083 (NG)	0.164 (NG/ULSD)
Total	0.146	0.164
Cooling Towers #11, 12, 13 per cell (6)	0.0044	0.0044
Total	0.026	0.026
Cold Start Emergency Engine	0.0168	0.014
<i>Increment Expanding Sources</i>		
Existing CTG	1.27	0.21
HRSG	0.032	0.018
Total	1.31	0.24
Boiler No. 3 (No. 6)	0.54	0.088
Boiler No. 4 (No. 6)	0.82	0.100
Boiler No. 5 (No. 6)	0.71	0.126
Total	2.066	0.315
Boiler No. 7	0.20	-
Boiler No. 9	0.23	3.53E-3
Total	0.42	3.53E-3

Table A-18 PM Emission Rates used in PSD Increment Modeling (Continued)

<i>Increment Consuming Sources</i>		
	PM₁₀/PM_{2.5} Emission Rate short term (g/s)	PM_{2.5} Emission Rate annual (g/s)
Cooling Tower 1 per cell (2)	3.33E-3	3.33E-3
Cooling Tower 2 per cell (2)	3.33E-3	3.33E-3
Cooling Tower 3 per cell (2)	5.86E-3	5.86E-3
Cooling Tower 4 per cell (2)	5.18E-3	5.18E-3
Cooling Tower 5	2.15E-3	2.15E-3
Cooling Tower 6	2.15E-3	2.15E-3
Total	0.034	0.034

¹ Plans to increase Boiler No. 7 & 9 operation have been withdrawn from the permit application. Emission rates are presented here as they are included in the PSD Increment modeling

As mentioned previously, the PM₁₀ baseline has been previously triggered and it becomes necessary to perform modeling of the proposed changes for MIT in conjunction with changes in the PM₁₀ baseline area as increment consuming. Emissions were modeled at the potential to emit as a conservative measure even though MIT had the option of modeling these sources at their actual emission rates. The following sources were included for the PM₁₀ PSD increment modeling only and are summarized in Attachment B:

- ◆ Kendall Station: Babcock & Wilson #1-2, Babcock & Wilson #3, Turbopower CTG#1, and the Combined Cycle CTG
- ◆ Harvard Blackstone: The new combined heat and power system, and Boiler 13
- ◆ MATEP: Stack (Two identical flues)
- ◆ Mystic Station: CTG/HRSG #81, CTG/HRSG #82, CTG/HRSG #93, and CTG/HRSG #94

The PM-10 Emission Rates for the interactive sources used in the PSD Increment Modeling are summarized in Table A-19.

Table A-19 PM Emission Rates used in PSD Increment Modeling

<i>PM₁₀ PSD Increment Consuming Sources</i>	
	PM ₁₀ Emission Rate grams/sec
Kendall Station	
Babcock & Wilson #1-2	0.81
Babcock & Wilson #3	1.22
Turbopower CTG #1	0.47
Combined Cycle CTG	6.3
Harvard Blackstone	
Boiler 6 & Boiler 13	3.53
New CHP	0.47
MATEP	
Stack (Two identical flues)	4.29
Mystic Station	
CTG/HRSG #81	4.1
CTG/HRSG #82	4.1
CTG/HRSG #93	4.1
CTG/HRSG #94	4.1

All sources are input in the AERMOD model with increment consuming sources using positive emissions rates and increment expanding sources with negative emission rates.

The PSD increment comparison was run for Operational Scenario 2 only as this is the final build scenario for this project. All impacts are matched in space and time and the resultant impact is compared to the PSD increment. The maximum resultant impact is used for annual averages and the highest second-high resultant impact is used for the 24-hr averages. The results of the PSD increment analysis are presented in Table A-20. The analysis shows that applicable PSD increments are not exceeded at any receptor for any project operating scenario.

Table A-20 ERMOD Model Results for Operational Scenario 2 compared to PSD Increments

Poll.	Avg. Period	Form	Resultant Modeled Conc. (µg/m ³)	Increment (µg/m ³)	% of Increment	Period	Receptor Location (m)
							(UTME, UTMN, Elev.)
<i>Operational Scenario 2 (2 new CTGs/HRSGs)</i>							
PM ₁₀	24-hr	H2H	8.85	30	29.5	5/9/10 hr 24	327650.08, 4692062.84, 2.74
PM _{2.5}	24-hr	H2H	8.25	9	91.7%	11/14/11 hr 24	327850.08, 4692362.84, 2.74
	Annual	H	1.41	4	35.3%	2010	327550.08, 4692062.84, 2.73

A-5.5 Class I Visibility Analysis

Section 169A of the Clean Air Act states “Congress hereby declares as a national goal the prevention of any future, and the remedying of any existing, impairment of visibility in mandatory Class I Federal areas which impairment results from man made air pollution.” Under the regulations promulgated for visibility protection (40 CFR 51.301) visibility impairment is defined as “...any humanly perceptible change in visibility (visual range, contrast, coloration) from that which would have existed under natural conditions.” As part of this air quality analysis, a visibility impact analysis was performed.

The Lye Brook Wilderness Area in southern Vermont is the closest Class I area to the MIT CUP. Lye Brook is located approximately 175.5 km to the northwest of MIT. As part of the Regional Haze Regulations, EPA has devised a screening criterion for sources located more than 50 km from the Class I area. A source is considered to have negligible impacts when the combined annual emissions of SO₂, NO_x, PM₁₀, and H₂SO₄ (in tons) divided by the distance (in km) from the Class I area is 10 or less. In this case, this ratio is about 0.52 (92.1 tons/175.5 km). Therefore, the proposed modifications to the source are expected to have negligible visibility impacts with respect to the Lye Brook Wilderness Area, and would not require any further Class I visibility impact analyses.

To confirm this result, a visibility analysis of the proposed project was conducted using the EPA VISCREEN program (Version 1.01 dated 88341). The VISCREEN model (EPA, 1992) provides the capability of assessing plume contrast (C_p) and plume perceptibility (Delta E) against two backgrounds: sky and terrain.

Visibility impacts are a function of particulate and NO₂ emissions. Particles are capable of either scattering or absorbing light while NO₂ absorbs light. It should be noted that NO₂ absorbs light greater in the blue end of the spectrum. These constituents can either increase or decrease the light intensity (or contrast) of the plume against its background. VISCREEN plume contrast calculations are performed at three wavelengths within the visible spectrum (blue, green, and red). Plume perceptibility as determined by VISCREEN is determined from plume contrast at all visible wavelengths and “is a function of changes in both brightness and color” (EPA, 1992).

The VISCREEN model provides three levels of analysis; Level 1, Level 2, and Level 3. The first two Levels are screening approaches. If the Project fails a Level-1 screening analysis, then more refined modeling must be conducted.

The perceptibility of a distinct plume depends on the plume contrast at all visible wavelengths. Perceptibility is a function of changes in both brightness and color. The color difference parameter, ΔE , was developed to specify the perceived magnitude of changes in color and brightness and is used as the primary basis for assessing perceptibility of plume visual impacts in the screening analysis. Plume contrast results from an increase or decrease in light transmitted from the viewing background through the plume to the

observer. This increase or decrease in light intensity is caused by plume constituents that scatter and/or absorb light. The first criterion is a ΔE value of 2.0; the second is a contrast value of 0.05 (EPA 1992).

A Level 1 VISCREEN analysis was performed on the nearest Class I area; Lye Brook Wilderness Area. Level 1 Screening in the VISCREEN model is designed to provide a conservative estimate of visual impacts from the plume. This conservatism is achieved by assuming worst-case meteorological conditions: extremely stable (F) atmospheric conditions, coupled with a very low wind speed (1 meter per second [m/s]) persisting for 12 hours, with a wind that would transport the plume directly adjacent to the observer. The observer is located at the closest location of the Class I area to the proposed source per VISCREEN guidance (EPA 1992), in this case, it is the east area of the Lye Brook Wilderness Area.

To be conservative, the proposed worst case new CTG emissions for each pollutant were used: PM (2 CTGs at 100% load, 0°F, ULSD) and NO_x (2 CTGs at 100% load, 0°F, ULSD). In addition to the CTGs emissions, the total emission rate includes the 2 MW cold start emergency engine (for PM and NO_x) and the cooling towers (for PM only). The total PM emission rate (3.03 g/s) and total NO_x emission rate (2.55 g/s) were input into the VISCREEN model. The minimum (175.5 km) and maximum (183.3 km) distances from the source to the Lye Brook Wilderness Area were input. A default background visual range of 194.8 km was used (U.S. Department of Interior, 2010). Table A-21 presents results of the VISCREEN modeling analysis completed for the MIT Cogen project.

The VISCREEN modeling demonstrates that the addition of the new CTGs, 2 MW cold start emergency engine and the cooling towers associated with the MIT Cogen project will comply with the criteria established in the Workbook for Plume Visual Impact Screening and Analysis (Revised) (EPA 1992) for maximum visual impacts inside the Lye Brook Wilderness Area.

Table A-21 Class I Visibility Modeling Results -Maximum Visual Impacts Inside the Class I Area

Background	Theta (°)	Azimuth (°)	Distance (km)	Alpha (°)	Delta-E		Absolute Contrast	
					Screening Criteria	Plume	Screening Criteria	Plume
SKY	10	84	175.5	84	2.00	0.203	0.05	0.003
SKY	140	84	175.5	84	2.00	0.039	0.05	-0.001
TERRAIN	10	84	175.5	84	2.00	0.167	0.05	0.002
TERRAIN	140	84	175.5	84	2.00	0.021	0.05	0.000

A-5.6 Effects on Soils and Vegetation Analyses

PSD regulations require analysis of air quality impacts on sensitive vegetation types, with significant commercial or recreational value, or sensitive types of soil. Evaluation of impacts on sensitive vegetation is by comparison of predicted project impacts with screening levels presented in *A Screening Procedure for the Impacts of Air Pollution Sources on Plants, Soils and Animals* (EPA, 1980). These procedures specify that predicted impact concentrations used for comparison account for project impacts and ambient background concentrations.

Most of the designated vegetation screening levels are equivalent to or exceed NAAQS and/or PSD increments, so that satisfaction of NAAQS and PSD increments assures compliance with sensitive vegetation screening levels. Since there are no specific PM₁₀ or PM_{2.5} screening level sensitive concentrations, no formal comparison was performed.

A-5.7 Growth

The peak construction work force is estimated to be 300 persons. MIT would not expect to add staff for plant operations.

It is expected that a significant construction force is available and is supported by the fact that within the Cambridge/Boston area, significant construction activities have already occurred. Therefore, it is expected that because this area can support the Project's construction from within the region, new housing, commercial and industrial construction will not be necessary to support the Project during the building period.

If any new personnel do move to the area to support the Project, a significant housing market is already established and available. Therefore, no new housing is expected. Due to the significant level of existing commercial activity in the area, new commercial construction is not foreseen to be necessary to support the Project's work force. In addition, no significant level of industrial related support will be necessary for the Project, thus industrial growth is not expected.

Thus, no new significant emissions from secondary growth during either the construction phase or operations are anticipated.

A-5.8 Environmental Justice

Section 5.2 of the PSD permit application includes documentation to enable MassDEP to fulfill its obligation under the provisions of the April 11, 2011 PSD Delegation Agreement between MassDEP and EPA to “identify and address, as appropriate, disproportionately high and adverse human health or environmental effects of federal programs, policies, and activities on minority and low-income populations as set forth in Federal Actions to Address Environmental Justice in Minority Populations and Low-Income Populations.” The Executive Office of Energy and Environmental Affairs (EEA) has established environmental justice neighborhoods which identify areas with minority populations and low-income populations.

A-6 REFERENCES

- 40 CFR Part 51, Appendix W. "Guideline on Air Quality Models"
- Auer, A.H., 1977. Correlation of Land Use and Cover with Meteorological Anomalies. *J. Applied Meteor.*, 17:636-643.
- EPA, 1980. "A Screening Procedure for the Impacts of Air Pollution Sources on Plants, Soils and Animals". EPA 450/2-81-078, U.S. Environmental Protection Agency, Research Triangle Park, NC.
- EPA, 1985. "Guideline for Determination of Good Engineering Practice Stack Height", EPA-450/4-80-023R, June, 1985.
- EPA, 1988. "Workbook for Plume Visual Impact Screening and Analysis". EPA 450/4-88-015, U.S. Environmental Protection Agency, Research Triangle Park, NC.
- EPA, 1990. "New Source Review Workshop Manual – Prevention of Significant Deterioration and Non Attainment Area Permitting." Office of Air Quality Planning and Standards, Research Triangle Park, NC.
- EPA, 2004. "User's Guide for the AMS/EPA Regulatory Model-AERMOD". EPA-454/B-03-001, U.S. Environmental Protection Agency, Research Triangle Park, NC.
- EPA, 2009. "AERMOD Implementation Guide". U.S. Environmental Protection Agency, Research Triangle Park, NC.
- EPA, 2010. Applicability of Appendix W Modeling Guidance for the 1-hour SO₂ National Ambient Air Quality Standard. U.S. Environmental Protection Agency, Research Triangle Park, NC.
- EPA, 2013. "AERSURFACE User's Guide". EPA-454/B-08-001 (revised 1/16/2013). U.S. Environmental Protection Agency, Research Triangle Park, NC.
- EPA, 2013. Use of ASOS Meteorological Data in AERMOD Dispersion Modeling. U.S. Environmental Protection Agency, Research Triangle Park, NC.
- EPA, 2014. Guidance for PM_{2.5} Permit Modeling. EPA-454/B-14-001 (May 2014). U.S. Environmental Protection Agency, Research Triangle Park, NC.
- MassDEP, 2011. Modeling Guidance for Significant Stationary Sources of Air Pollution. MassDEP Bureau of Waste Prevention, Boston, MA.

ATTACHMENT A

Source Parameters for New Turbine Load Cases

Table A-1 MIT turbine & duct burner model cases Operational Scenario 1

Case	1	2	3	4	5	6	7	8	9	10	11	12	13	14
Ambient Temp (F)	50	0	60	0	60	0	60	0	60	0	60	0	60	0
% Load	100	100	75	75	50	50	40	40	100	100	75	75	65	65
Turbine Fuel	NG	NG	NG	NG	NG	NG	NG	NG	ULSD	ULSD	ULSD	ULSD	ULSD	ULSD
Duct Burner Fuel	NG	NG	NG	NG	OFF	OFF	OFF	OFF	NG	NG	NG	NG	OFF	OFF
Turbine Fuel Input (MMBtu/hr, LHV)	197.8	202.0	156.0	161.6	121.8	125.4	108.8	110.9	198.9	215.1	162.7	172.0	148.4	156.4
Duct Burner Fuel Input (MMBtu/hr, LHV)	112.4	120.5	106.0	135.2	0.0	0.0	0.0	0.0	113.9	122.3	107.3	136.6	0.0	0.0
Turbine Fuel Input (MMBtu/hr, HHV)	219.0	223.7	172.7	179.0	134.9	138.8	120.5	122.7	212.0	229.3	173.4	183.3	158.2	166.7
Duct Burner Fuel Input (MMBtu/hr, HHV)	124.5	133.4	117.4	149.7	0.0	0.0	0.0	0.0	126.1	135.4	118.8	151.3	0.0	0.0
Stack Exit Temp. (F)	180	180	180	180	180	180	180	180	225	225	225	225	225	225
Stack Flow Rate (ft3/min)	149,161	161,526	130,069	148,184	111,718	126,102	104,916	118,101	162,628	182,407	145,324	167,016	135,906	156,253
Stack Exit Velocity (ft/s)	64.6	70.0	56.3	64.2	48.4	54.6	45.4	51.1	70.4	79.0	62.9	72.3	58.9	67.7
Emission Rates Turbine Only - Lb/Hr														
PM10	4.38	4.47	3.45	3.58	2.70	2.78	2.41	2.45	8.48	9.17	6.94	7.33	6.33	6.67
PM2.5	4.38	4.47	3.45	3.58	2.70	2.78	2.41	2.45	8.48	9.17	6.94	7.33	6.33	6.67
Duct Burner - Lb/Hr														
PM10	2.49	2.67	2.35	2.99	0.00	0.00	0.00	0.00	2.52	2.71	2.38	3.03	0.00	0.00
PM2.5	2.49	2.67	2.35	2.99	0.00	0.00	0.00	0.00	2.52	2.71	2.38	3.03	0.00	0.00
Total Emissions (Lb/Hour)														
PM10	6.87	7.14	5.80	6.57	2.70	2.78	2.41	2.45	11.00	11.88	9.31	10.36	6.33	6.67
PM2.5	6.87	7.14	5.80	6.57	2.70	2.78	2.41	2.45	11.00	11.88	9.31	10.36	6.33	6.67
Total Emissions (g/s)														
PM ₁₀	8.66E-01	9.00E-01	7.31E-01	8.28E-01	3.40E-01	3.50E-01	3.04E-01	3.09E-01	1.39E+00	1.50E+00	1.17E+00	1.31E+00	7.97E-01	8.40E-01
PM _{2.5}	8.66E-01	9.00E-01	7.31E-01	8.28E-01	3.40E-01	3.50E-01	3.04E-01	3.09E-01	1.39E+00	1.50E+00	1.17E+00	1.31E+00	7.97E-01	8.40E-01
AERMOD v15181 X/Q Results														
24-hr High (X/Q) – Turb A	9.29971	8.74454	10.12015	9.33882	10.97504	10.30647	11.31536	10.68336	8.54524	7.77871	9.25009	8.38393	9.65012	8.78836
24-hr High (X/Q) – Turb B	9.26518	8.67077	10.14546	9.30208	11.00514	10.33432	11.35853	10.7047	8.47298	7.60733	9.23381	8.30549	9.66147	8.79115
24-hr High (X/Q) (5yr avg) – Turb A	7.47788	6.74535	8.51876	7.52494	9.70717	8.77411	10.17981	9.3124	6.57972	5.58007	7.48573	6.30563	7.95874	6.88942
24-hr High (X/Q) (5yr avg) – Turb B	7.34906	6.56117	8.43485	7.40539	9.62438	8.68979	10.11866	9.1919	6.40604	5.39525	7.4087	6.16153	7.88954	6.68898
Maximum Predicted Concentration (µg/m³)														
24-hr PM _{2.5}	6.47	6.07	6.23	6.23	3.30	3.07	3.09	2.88	<u>9.12</u>	8.35	8.78	8.23	6.35	5.79
24-hr PM ₁₀	8.05	7.87	7.42	7.73	3.74	3.62	3.45	3.31	<u>11.85</u>	11.64	10.85	10.94	7.70	7.38

Table A-2 MIT turbine & duct burner model cases - Operational Scenario 2

Case	2.a	2.b	2.c	2.d	2.e	2.f	2.g	2.h	2.i	2.j	2.k	2.l	2.m	2.n
Ambient Temp (F)	50	0	60	0	60	0	60	0	60	0	60	0	60	0
% Load	100	100	75	75	50	50	40	40	100	100	75	75	65	65
Turbine Fuel	NG	NG	NG	NG	NG	NG	NG	NG	ULSD	ULSD	ULSD	ULSD	ULSD	ULSD
Duct Burner Fuel	NG	NG	NG	NG	OFF	OFF	OFF	OFF	NG	NG	NG	NG	OFF	OFF
Turbine Fuel Input (MMBtu/hr, LHV)	197.8	202.0	156.0	161.6	121.8	125.4	108.8	110.9	198.9	215.1	162.7	172.0	148.4	156.4
Duct Burner Fuel Input (MMBtu/hr, LHV)	112.4	120.5	106.0	135.2	0.0	0.0	0.0	0.0	113.9	122.3	107.3	136.6	0.0	0.0
Turbine Fuel Input (MMBtu/hr, HHV)	219.0	223.7	172.7	179.0	134.9	138.8	120.5	122.7	212.0	229.3	173.4	183.3	158.2	166.7
Duct Burner Fuel Input (MMBtu/hr, HHV)	124.5	133.4	117.4	149.7	0.0	0.0	0.0	0.0	126.1	135.4	118.8	151.3	0.0	0.0
Stack Exit Temp. (F)	180	180	180	180	180	180	180	180	225	225	225	225	225	225
Stack Flow Rate (ft ³ /min)	298,322	323,052	260,138	296,368	223,437	252,205	209,832	236,202	325,256	364,814	290,647	334,032	271,811	312,506
Stack Exit Velocity (ft/s)	64.6	70.0	56.3	64.2	48.4	54.6	45.4	51.1	70.4	79.0	62.9	72.3	58.9	67.7
Emission Rates Turbine Only - Lb/Hr (per Turbine)														
PM10	4.38	4.47	3.45	3.58	2.70	2.78	2.41	2.45	8.48	9.17	6.94	7.33	6.33	6.67
PM2.5	4.38	4.47	3.45	3.58	2.70	2.78	2.41	2.45	8.48	9.17	6.94	7.33	6.33	6.67
Duct Burner - Lb/Hr (per Turbine)														
PM10	2.49	2.67	2.35	2.99	0.00	0.00	0.00	0.00	2.52	2.71	2.38	3.03	0.00	0.00
PM2.5	2.49	2.67	2.35	2.99	0.00	0.00	0.00	0.00	2.52	2.71	2.38	3.03	0.00	0.00
Total Emissions (Lb/Hour) (from both Turbines)														
PM10	13.74	14.28	11.60	13.15	5.40	5.55	4.82	4.91	22.01	23.76	18.63	20.72	12.66	13.33
PM2.5	13.74	14.28	11.60	13.15	5.40	5.55	4.82	4.91	22.01	23.76	18.63	20.72	12.66	13.33
Total Emissions (g/s) (from both Turbines)														
PM ₁₀	1.73	1.80	1.46	1.66	0.68	0.70	0.61	0.62	2.77	2.99	2.35	2.61	1.59	1.68
PM _{2.5}	1.73	1.80	1.46	1.66	0.68	0.70	0.61	0.62	2.77	2.99	2.35	2.61	1.59	1.68
AERMOD v15181 X/Q Results														
24-hr High (X/Q)	5.63293	4.52955	7.39274	5.72659	8.42715	7.6349	8.86685	8.09395	6.2328	5.08673	6.95852	5.95062	7.30458	6.36353
24-hr High (X/Q) (5yr avg)	4.04493	3.71782	5.28415	4.10114	0.59437	0.55819	0.61301	0.57828	3.49691	3.29464	4.1029	3.45017	4.67377	3.56039
Maximum Predicted Concentration (µg/m³)														
24-hr PM _{2.5}	7.00	6.69	7.72	6.79	4.45	3.87	4.29	3.76	9.70	9.86	9.63	9.01	7.45	5.98
24-hr PM ₁₀	9.75	8.15	10.81	9.49	5.73	5.34	5.38	5.01	12.31	11.31	13.61	10.38	10.68	8.11

ATTACHMENT B

Source Parameters for Cumulative Impact Modeling

Table B-1 Source Parameters and Emission Rates for Cumulative Modeling Analysis

Facility/Sources	UTM* East	UTM* North	Stack Dimensions		Exit Velocity	Exit Temp	PM2.5	PM10	NOx
	(m)	(m)	Height (m)	Diam(m)	(m/s)	(K)	(g/s)	(g/s)	(g/s)
<i>Kendall Station</i>									
BABCOCK & WILSON #2	328780.78	4692241.85	53.3	3.05	6.25	427.6	0.81	0.81	9.6
BABCOCK & WILSON #3	328760.64	4692244.83	53.3	2.92	9.45	460.9	1.22	1.22	14.4
TURBOPOWER CTG#1	328659.1	4692298.2	9.9	4.08	39.62	838.7	0.47	0.47	14.9
COMBINED CYCLE TURBINE	328722.3	4692228.1	76.2	5.11	28.96	394.3	6.3	6.3	6.9
<i>Harvard Blackstone</i>									
Turbine – ULSD; No Duct Fire (CHP) -ST	325795.4	4692345.7	33.5	1.25	19.21	444.3	0.47	0.47	0.54
Turbine – ULSD; No Duct Fire (CHP) –AN	325795.4	4692345.7	33.5	1.25	19.07	432.6	0.38	0.38	0.22
STACK 2 (Boilers 11 and 12)	325832.9	4692316.6	48.8	3.04	12.5	435.9	8.65	8.65	20.2
STACK2 (Boilers 6 and 13)	325806.8	4692328.7	45.7	3.66	10.36	469.3	3.53	3.53	10.2
<i>MATEP</i>									
STACK (TWO IDENTICAL FLUES)	326436.2	4689289.8	96	4.23	11.31	433.3	4.29	4.29	107.6
<i>Boston Generating Mystic Station**</i>									
HIGH PRESSURE BLR #7 (DUAL FUEL)	329748.6	4695288.9	152.4	3.66	25.91	443.9	34.7	34.7	173.6
CTG/HRSG #81	329943.6	4695254.2	93	6.25	22.04	365	4.1	4.1	2.7
CTG/HRSG #82	329944.8	4695263.2	93	6.25	22.04	365	4.1	4.1	2.7
CTG/HRSG #93	329957.3	4695325.4	93	6.25	22.04	365	4.1	4.1	2.7
CTG/HRSG #94	329958.9	4695333.6	93	6.25	22.04	365	4.1	4.1	2.7
ROLLS ROYCE CTG	329630	4695256.4	9.1	3.66	12.8	810.9	2.8	2.8	9

ATTACHMENT C

Calculations of Actual Emission Rates for PSD Increment Modeling

Table C-1 PM Short-term Emission Calculations based on Actual Operations

Source	Oil Historical Usage					NG Historical Usage				
	Max Oil Usage in a 24-hour period (gallons)	24-hour Period	Total MMBtuon Oil	EF Oil (Lb/MMBtu)	Actual Emission Oil Rate (lb/hr)	Max Gas Usage in a 24-hour period (scf)	24-hour Period	Total MMBtu on Gas	EF Gas (Lb/MMBtu)	Actual Emission Gas Rate (lb/hr)
Boiler No. 3	13,214	12/31/2013	1876	0.055	4.3	1,754,043	12/8/2014	1754	0.0076	0.56
Boiler No. 4	19,948	2/6/2015	2833	0.055	6.5	1,742,543	12/25/2013	1743	0.0076	0.55
Boiler No. 5	17,284	2/6/2015	2454	0.055	5.6	1,894,732	12/8/2014	1895	0.0076	0.6
Existing CT	43,976	1/24/2014	6245	0.04	10.1	6,192,320	12/13/2013	6192	0.007	1.81
Existing DB	N/A	N/A	N/A	N/A	N/A	1,190,100	4/2/2013	1190	0.005	0.25
Boiler No. 7	9,163	2/24/2015	1301	0.03	1.6	1,202,035	2/16/2015	1202	0.01	0.5
Boiler No. 9	10,210	2/24/2015	1450	0.03	1.8	1,580,329	3/23/2015	1580	0.01	0.66

Period of Available Data for All Emission Units 4/1/13 – 3/31/15

Table C-2 PM Annual Emission Calculations based on Actual Operations

Source	Oil Historical Usage				NG Historical Usage				
	Average Oil Usage over 2 Year period (gallons)	Total MMBtu Oil	EF Oil (Lb/MMBtu)	Annual PM Oil Emissions Lb/Yr	Average Gas Usage Over a 2 Year period (scf)	Total MMBtu on Gas	EF Gas (Lb/MMBtu)	Actual PM Gas Emissions (lb/yr)	Expanding Emission Rate Total Lb/hr
Boiler No. 3	6.72E+05	9.54E+04	0.055	5,248	1.15E+08	1.15E+05	0.0076	872	0.7
Boiler No. 4	7.84E+05	1.11E+05	0.055	6,123	1.19E+08	1.19E+05	0.0076	907	0.8
Boiler No. 5	9.84E+05	1.40E+05	0.055	7,684	1.17E+08	1.17E+05	0.0076	891	1
Existing CT	6.92E+05	9.82E+04	0.04	3,930	1.59E+09	1.59E+06	0.007	11,141	1.7
Existing DB	N/A	N/A	N/A	N/A	2.43E+08	2.43E+05	0.005	1,214	0.14
Boiler No. 7	1.11E+04	1.57E+03	0.03	47	6.39E+06	6.39E+03	0.01	64	0.013
Boiler No. 9	2.93E+04	4.16E+03	0.03	125	1.21E+07	1.21E+04	0.01	121	0.028

Period of Available Data for All Emission Units 4/1/13 – 3/31/15

Table C-3 PM Annual Emission Consuming Calculations based on Actual Operations for Boilers No. 3, 4, & 5

Annual PSD Increment Consuming Emission Calculation										
Source	Total MMBtu/hr Oil	Total MMBTU/hr Gas	Total MMBtu/hr	NG Emission Limit (lb/MMBtu)	NG Emissions (lb/yr)	Hrs/Yr Oil	MMBTU/hr Oil	Oil Emission Limit (lb/MMBtu)	Oil Emissions (lb/yr)	Consuming Emission Rate Total Lb/hr
Boiler No. 3	9.54E+04	1.15E+05	2.10E+05	0.0076	1,597.50	168	116.2	0.055	1,073.70	0.3
Boiler No. 4	1.11E+05	1.19E+05	2.31E+05	0.0076	1,753.00	168	116.2	0.055	1,073.70	0.32
Boiler No. 5	1.40E+05	1.17E+05	2.57E+05	0.0076	1,952.60	168	145.2	0.055	1,341.60	0.38

Period of Available Data for All Emission Units 4/1/13 – 3/31/15

Table C-4 PM Annual Emission Consuming Calculations based on Actual Operations for Boilers No. 7 & 9

Annual PSD Increment Consuming Emission Calculation									
Source	NG Hrs/Yr	MMBTU/hr Gas	NG Limit (Lb/MMBtu)	NG Emissions (Lb/yr)	Oil Hrs/yr	MMBTU/hr Oil	Oil Limit (Lb/MMBtu)	Oil Emissions (lb/yr)	Consuming Emission Rate Total Lb/hr
Boiler No. 7	8592 ¹	99.7	0.01	8,566.20	168	99.7	0.03	502.5	1
Boiler No. 9	8592 ¹	125.8	0.01	10,808.70	168	119.2	0.03	600.8	1.3

¹ Since the initial application, MIT has withdrawn the request for increasing the hours of operation on these units.

Appendix B

Supplemental Information

Appendix B – Part 1

Turbine Information

- ◆ Solar Titan 250 Brochure
- ◆ Solar Titan 250 Case Study
- ◆ Solar Titan 250 Generator Set Information
- ◆ Solar Titan 250 SoLoNO_x Information
- ◆ Haldor Topsoe SCR Catalyst Information

Solar Turbines

A Caterpillar Company

POWERING THE GLOBAL ENERGY DEMAND

TITAN 250

Gas Turbine System


For Power Generation Applications



Maximize Life-Cycle Benefits

Built on six decades of field-proven technology and experience, the *Titan 250* will maximize the life-cycle benefits of your application. It can operate on a wide range of gaseous and liquid fuels and delivers 22 MW (21 745 kWe) of power and 77,000 pounds of steam per hour in a highly compact package.

The *Titan 250* was designed to give customers many years of productivity with low life-cycle cost. This means a gas turbine with high availability, reliability and durability that delivers best-in-class 39% efficiency, saving on fuel and reducing emissions. No other gas turbine system gives you better power density and efficiency with lower emissions while costing you less per kilowatt-hour. The *Titan 250* provides all of these benefits and more throughout the entire life cycle of the package, adding more dollars to your bottom line.




Industrial Combined Heat and Power
Energy Star Award



University Combined Heat and Power
Energy Star Award



Hospital Combined Heat and Power
LEED Platinum Award



Sustainable Solutions that Fit Your Application

Solar maintains a clear focus on providing customer satisfaction by designing products that lead their categories in critical performance and environmentally sustainable operation. *Solar*[®] gas turbines meet customer needs in ways that limit the impact on the environment, protect people who operate the equipment, and respect people who live nearby.

These products, including the *Titan 250*, provide sustainable solutions through the application of advanced technologies that enable high operating efficiency and low greenhouse gas emissions. Solar's industry-exclusive *SoLoNOx*[™] dry low-emissions combustion technology has



**Municipal Power
Energy Star Award**

been proven to lower emissions and ensure compliance with stringent exhaust emission regulations worldwide. *SoLoNOx* technology cuts NOx emissions up to 90% and CO emissions are reduced as much as 30% over conventional combustion systems.

Solar gas turbines incorporating *SoLoNOx* combustion systems, have logged more than 86 million operating hours, saving 2.1 million tons of NOx emissions, improving air quality for millions of people around the world. And many of our gas turbines have helped our customers win Energy Star, LEED and other awards recognizing efficiency and sustainability.

The *Titan 250* gas turbine generator set can be applied in a variety of applications, including combined heat and power, peaking power/load management, district heating and cooling, and base load power. It will meet your requirements in a wide variety of industries and facilities, including hospitals, universities, rural electric cooperatives, municipal utilities, food processing, pulp and paper mills, manufacturing facilities, mining and refineries.

For combined heat and power applications, the *Titan 250* generator set can be coupled with heat recovery equipment to optimize your application by capturing otherwise wasted thermal energy from the exhaust to produce steam for space, water or process heating, maximizing energy efficiency and increasing sustainability.



Because the *Titan 250* is extremely reliable and efficient, utilities can benefit by using it to provide power to isolated communities, commercial centers and industries. Utilities will also benefit their communities by using the *Titan 250* in peaking applications to reduce the incremental cost of additional generation.



Leveraging Proven Technology

The *Titan 250* is a familiar machine, yet still a gas turbine like no other – taking the best from Solar's proven products. Each advancement builds on experience gained from our latest and most proven designs, while adding thoroughly tested technologies in critical areas of compressor aerodynamics, combustion, advanced materials, cooling performance and package design.

Configured for power generation, the *Titan 250* comes fully integrated and self-contained with lube oil, fuel and *Turbotronic™* control systems on board. Modular inlet, exhaust and ancillary systems can be adjusted to suit your application in enclosed or unenclosed packages.



Engineered for Excellence

Titan 250 gas turbines deliver best-in-class performance while saving on fuel and reducing emissions. Above all, the *Titan 250* is engineered for durability, reliability and availability. Using smart diagnostics, remote monitoring and onsite maintenance capabilities, the *Titan 250* takes advantage of advanced features to keep your operation online and producing for many years to come.

Look at the technologies behind the *Titan 250* and you'll recognize key contributions from our most widely accepted products:

Compressor Section Technology

A 16-stage compressor produces a 24:1 pressure ratio. Coated components provide corrosion resistant surfaces for durability. The four-piece, split-case design allows for easy field maintenance. Variable guide vanes and stators permit smooth, reliable starting and stopping.

Combustion Section Technology

The 14 dry, lean-premixed *SoLoNOx* injectors deliver less fuel than conventional designs resulting in lower emissions.

The combustion liner is an Augmented Backside Cooled (ABC) configuration providing maximum cooling ensuring long-term durability.

Hot Section Technology

The two-stage gas producer features internally air-cooled first and second stage nozzle vanes as well as internally cooled first stage rotor blades. The design provides cylindrical blade tips and a rub-tolerant coating for improved tip control increasing efficiency.

The power turbine is a three-stage configuration utilizing shrouded blades to maximize efficiency and flatten the power curve.

And the *Titan 250* gas turbine was designed with the same rigorous approach that has always served our customers well — extending these proven technologies to new products and advancing the state of the art.

The latest proven engineering methods give the *Titan 250* its performance edge. Tools like computational fluid dynamics (CFD) and computer-aided thermal and mechanical analysis ensure achievement of design and performance objectives. A comprehensive reliability analysis gives you refinements in design and processes that further enhance availability:

- Adding redundancy
- Improving controls and optimizing shutdown logic
- Enhancing component reliability and durability
- Minimizing service events and their duration
- Expanding machine health monitoring and predictive maintenance

This design methodology ensures that customers receive robust equipment ready for long, reliable service across the entire life cycle of their project.



Higher Availability

Tougher projects and challenging markets demand maximum equipment availability. The *Titan 250* promises more productive hours with less repair and fewer and shorter planned service intervals. It continues a design tradition of modular components for the ultimate in operational flexibility and service simplicity.


Monitoring and Diagnostics: Cornerstones of Productivity

Titan 250 packages provide remote monitoring and predictive diagnostics enabled by Solar's *InSight System*™, the industry's most advanced equipment health management system. This system provides a clear vision, focus and understanding of your equipment and is designed to save you time and money.

With *InSight System*, problems once found only by a technician's visit can be detected online from anywhere — even half a world away — so you can avoid unscheduled downtime.


Capabilities include:

- Advanced diagnostics
- Condition monitoring
- Remote troubleshooting
- E-mail alert notifications
- Predictive recommendations
- Equipment operation summary reports



Features delivered by *InSight System* rely on a dedicated connectivity solution, *InSight Connect*™, allowing reliable access to critical operational information. This secured web connection provides a standardized method for the acquisition and transmission of information while minimizing the impact to an existing customer network.

InSight System monitors your operation 24 hours a day. If trouble is detected at any time it helps you determine the prognosis, forecast the outcome, and decide whether to repair now or wait for the next scheduled service. With built-in predictive capability, some events that previously would have shut the package down now trigger fall-back to a safe operating mode and alert service personnel of the machine's status. The system also gathers and analyzes information — performance maps, historical displays, reports on availability and life-cycle cost — to help you make operational decisions that maximize your investment.



Designed for Productivity


The *Titan 250* gas turbine system has been designed to give customers many years of productivity with the highest life-cycle value at the lowest life-cycle cost. This means equipment with the highest availability, reliability and durability, and machines that are easy to maintain and service.

Our complete approach to machinery management includes digital monitoring and control systems that help further minimize emissions, support predictive maintenance, increase availability, enable unattended operation, and reduce life-cycle costs.


All regularly serviced components are placed near the sides of the package for ease of access and fast service. With our lateral and axial engine repair and maintenance system, you have the option of doing in situ condition-based repair, modular component exchange, or a complete exchange of major engine components.



Easy Access to Major Components




Onsite Inspection Capability



Axial Rail System

The rail-mounted service system supports the turbine from below and allows easy access to inspect, repair or replace hot section components, bearings, blades and seals. Technicians can also remove and replace the gas producer independently of the power turbine, avoiding realignment of the power turbine and driven equipment. The rails can also be used to roll the entire turbine out for factory overhaul or exchange, minimizing downtime.



Lateral Rail System

Contact Us and Put the Titan 250 to Work

Let us show you the true power and value of *Titan 250* turbomachinery package. We stand on our experience gained from more than 13,600 turbine packages in 96 countries with over 1.5 billion hours of operation. In addition to expert application advice, you'll get in-depth technical assistance through our global customer support system.

We're ready to serve you from locations all over the world:

- 13 repair and overhaul centers
- 19 parts facilities
- 43 service locations

For more information, contact one of our representatives. To see a complete listing of our worldwide locations, visit our website or contact us at one of the phone numbers listed below.



Worldwide Headquarters



Solar Turbines Incorporated

P.O. Box 85376
San Diego, California 92186-5376
Telephone: +1 (619) 544-5352
email: powergen@solarturbines.com

www.solarturbines.com



Turbomach S.A

Via Campagna 15
6596 Riazzino, Switzerland
Telephone: +41 91 851 15 11
email: contact@turbomach.com

www.turbomach.com

Caterpillar is a registered trademark of Caterpillar Inc.

Solar, Saturn, Centaur, Taurus, Mercury, Mars, Titan, SoLoNOx, TurboTronic, InSight System and InSight Connect are trademarks of Solar Turbines Incorporated. All other trademarks are the intellectual property of their respective companies

© 2010 Solar Turbines Incorporated. All rights reserved. Specifications subject to change without notice. Printed in the U.S.A.

B250PG/210/5M



50 MWe COMBINED HEAT AND POWER INDEPENDENT POWER PRODUCER

OWNER

Manisa OIZ

LOCATION

Turkey

PRODUCT

Two Titan 250 Generator Sets

CUSTOMER VALUE

High Efficient and Flexible Energy Supply

Our customer, Manisa OIZ, one of the biggest industrial parks in Turkey, needed to fulfill the rapidly growing demand of electricity, as well as provide steam and hot water to their industrial tenants. We extended the capacity of their power plant with two of our latest Titan™ 250 gas turbines, which are the best in class for efficiency and match the customer's variable demand for electricity, steam and hot water.

Solar Turbines

A Caterpillar Company

50 MWe COMBINED CYCLE POWER PLANT



PLANT DATA

Two Titan 250 Gas Turbine Generator Sets (44 MWe)

Two Heat Recovery Steam Generators

Two Steam Turbine Generators

50 MWe - 250 Mwth Heat Supply

Fuel: Natural Gas



OUR PRODUCTS AND SERVICES

Gas Turbine Packages Supply and Auxiliaries

Design

Construction

Commissioning and Installation

Maintenance

RELIABLE

HIGHLY EFFICIENT

FLEXIBLE SOLUTION

The new combined cycle power plant is fully capable of supporting a highly unpredictable electricity demand and the variable needs of steam and hot water. The organization can rely on this stand-alone power plant in order to support the more than 180 industries that are connected for electricity and heat supply. Moreover, the efficiency of the plant and the low emissions of the Titan 250 ensure the customer's full compliance to the industrial emissions regulations of the country.

Solar Turbines Incorporated
Tel: +01 619-544-5352
Mail: powergen@solarturbines.com Web: www.solarturbines.com

Caterpillar is a registered trademark of Caterpillar Inc. Solar and Titan are trademarks of Solar Turbines Incorporated. Copyright 2016 Solar Turbines Incorporated. All rights reserved. dschp-moiz/116/EO


Solar Turbines
A Caterpillar Company

GAS TURBINE PACKAGES

TITAN 250

PACKAGE AND PERFORMANCE DATA-TITAN 250 GAS TURBINE GENERATOR SET - POWER GENERATION >

OTHER MEDIA >



Titan 250 PG - Generator Set

[ISO PERFORMANCE/SPECIFICATIONS](#)

[BROCHURES](#)

[CASE STUDIES](#)

▼

TITAN 250 PG - GENERATOR SET

The Titan™ 250 is our most powerful package and is based on proven technologies from other Solar Turbines models. It produces 50 percent more power in the same footprint as the Titan 130. It provides 40 percent shaft efficiency with emissions reduced up to 30 percent.

ISO PERFORMANCE/SPECIFICATIONS


UNITS: US METRIC

Power	21 745 kWe
-------	------------

Heat Rate	8775 Btu/kW-hr
-----------	----------------

Exhaust Flow	541,590 lb/hr
--------------	---------------

Exhaust Temperature	865°F
Steam Production	77.6 - 298 klb/hr
Axial Exhaust	—
Radial Exhaust	—
SoLoNOx	Yes
Ultra Lean Premix	—



GAS TURBINE PACKAGES

TITAN 250

[Back](#)

PACKAGE AND
PERFORMANCE DATA-TITAN
250 GAS TURBINE
GENERATOR SET - POWER
GENERATION

OTHER MEDIA



CASE STUDIES **PERFORMANCE/SPECIFICATIONS**

TITAN 250 PG - GENERATOR SET

The Titan™ 250 is our most powerful package and is based on proven technologies from other Solar Turbines models. It produces 50 percent more power in the same footprint as the Titan 130. It provides 40 percent shaft efficiency with emissions reduced up to 30 percent.

ISO PERFORMANCE/SPECIFICATIONS

UNITS: **US** METRIC

Power

21 745 kWe 21 745 kWe

Heat Rate	8775 Btu/kW-hr 9260 kJ/kW-hr
Exhaust Flow	541,590 lb/hr 245 660 kg/hr
Exhaust Temperature	865°F 465°C
Steam Production	77.6 - 298 klb/hr 35.2 - 135.1 tonnes/hr
Axial Exhaust	— —
Radial Exhaust	— —
SoLoNOx	Yes Yes
Ultra Lean Premix	— —

PRODUCTS AND SOLUTIONS

Construction Services
 Gas Turbine Overview
 Gas Compressors
 Oil and Gas
 Power Generation

SERVICES

Certified Service Parts
 Equipment Health Management
 Field Service
 Gas Compressor Restage and Overhaul
 Gas Turbine Overhaul
 Package System Upgrades
 Technical Training

ABOUT US


Corporate
 Environmental Information
 History
 News and Events
 Solar Merchandise
 Supplier Information
 Worldwide Locations

CAREERS

Benefits
 Commitment to Diversity
 Commitment to Our Communities
 Explore Career Options
 Member of a Global Team
 Need Help Applying
 U.S. Career Opportunities
 New Graduate/Intern Opportunities
 Non-U.S. Career Opportunities
 Czech Republic Career Opportunities
 Solar Internal Career Opportunities

SOCIAL MEDIA


 LinkedIn

 YouTube

 Twitter

[Login](#) | [Site Map](#) | [Site Registration](#) | [Contact Us](#) | [Data Privacy Policy](#)

© 2016 Solar Turbines Incorporated



General Specifications

Titan™ 250 Gas Turbine

- Industrial, Two-Shaft
- 16 Stage Axial Compressor
 - Variable Inlet Guide Vanes
 - Pressure Ratio: 24:1
 - Inlet Airflow: 67.3 kg/sec (148 lb/sec)
 - Vertically Split Case
- Combustion Chamber Annular-Type
 - 14 Lean-Premixed, Dry Low Emissions Injectors
 - Torch Ignitor System
- Gas Generator Turbine
 - 2-Stage Reaction
 - Max. Speed: 10,500 rpm
- Power Turbine
 - 3-Stage Reaction
 - Max. Speed: 7000 rpm
- Bearings
 - 5 Radial Journal, Tilt-Pad
 - 2 Active Thrust, Tilt-Pad
 - 2 Inactive Thrust, Fixed Tapered Land
- Coatings
 - Compressor: Inorganic Aluminum
 - Turbine and Nozzle Blades: Precious Metal Diffusion Aluminide
- Vibration Transducer Type
 - Proximity Probes, 2 per Radial Bearing/2 per Thrust Bearing

Main Reduction Drive

- Epicyclic Type
 - 1500 rpm (50 Hz) or 1800 rpm (60 Hz)
 - Accessory Power Take-Off

Generator

- Salient Pole, 3 Phase, 6 Wire, Wye Connected, Synchronous, with Permanent Magnet Generator Exciter

- Available Construction Types:
 - Duct In/Duct Out
 - Totally Enclosed Air-to-Air Cooled
 - Totally Enclosed Water-to-Air Cooled
- Sleeve Bearings
- Oil Jacking System
- NEMA Class F Insulation
- Class B Temperature Rise
- Voltages: 1100 to 13,800 VAC
- Frequency: 50 or 60 Hz

Package

- Mechanical Construction
 - Steel Base Frame with Drip Pans
 - 316L Stainless Steel Piping ≤8" dia.
 - Compression-Type Tube Fittings
- Electrical System
 - NEC, Class 1, Group D, Div 2
 - CENELEC/ATEX Zone 2
 - Cable Tray Wiring
 - 120 VDC Battery/Charger System
- Direct-Drive AC Start System
- Fuel System
 - Dry Low Emission (SoLoNOx)
 - Conventional
- Fuel Types
 - Natural Gas or Dual (Gas/Distillate)
- Integrated Lube Oil System
 - Turbine-Driven Main Pump
 - AC Motor-Driven Pre/Post Pump
 - DC (120 V) Motor-Driven Backup Pump
 - Oil Cooler and Oil Heater*
 - Tank Vent Separator and Flame Trap
 - Lube Oil Filter
- Turbine Compressor Cleaning System
 - On-Crank/On-Line
 - Portable Cleaning Tank*

- Air Inlet and Exhaust System
 - Carbon Steel
 - Stainless Steel
 - Coastal Type Filters
- Enclosure
 - Driver Only
 - Fire Detection and Suppression
- Turbotronic™ 4 Control System
 - Onskid Control System
 - Digital Onskid Display Panel
 - 24 VDC Control Power (120 VDC Input)
 - Serial Link Supervisory Interface
 - Field Programmable
 - Vibration Monitoring
 - Temperature Monitoring
 - Generator Control
 - Selectable Control Modes
 - Solid-State Voltage Regulation
 - Automatic Synchronization
 - Metering Panel with Manual Synchronization*
 - KW Control*
 - Heat Recovery Application Interface
 - Multiple Operator Display Screens
 - Data Collection and Playback
 - Turbine Performance Map*
 - InSight System™ Equipment Health Management*
 - Printer/Logger*
- Documentation
 - Electrical Drawings
 - Mechanical Drawings
 - Quality Control Data Book
 - Inspection and Test Plan
 - Test Reports
 - O&M Manuals
- Factory Testing of Turbine
- Factory Testing of Package
 - Non-Dynamic
 - Dynamic

Performance

Output Power	21 745 kW _e
Heat Rate	9260 kJ/kWe-hr (8775 Btu/kWe-hr)
Exhaust Flow	245 660 kg/hr (541,590 lb/hr)
Exhaust Temp.	465°C (865°F)

Application Performance

Steam (Unfired)	35.2 tonnes/hr (77,600 lb/hr)
Steam (Fired)	184.8 tonnes/hr (407,490 lb/hr)
1536°C (2800°F)	
Chilling (Absorp.)	30 340 kW (8620 refrigeration tons)

Nominal rating – per ISO
At 15°C (59°F), sea level

No inlet/exhaust losses


Relative humidity 60%

Natural gas fuel with
LHV = 31.5 to 43.3 MJ/Nm³ (940 Btu/scf)

No accessory losses

Engine efficiency: 38.9%
(measured at generator terminals)


Available Power



DS250GSPG-002M

Enclosure Access and Maintenance Space

MINIMUM SPACE CLEARANCE REQUIRED FOR ENCLOSURE ACCESS DOORS AND ROUTINE OPERATION AND MAINTENANCE



Package Height: 4.1 m (13' 5")
Package Weight: 125 000 kg (276,000 lb)

FOR MORE INFORMATION

Solar[®] Turbines

A Caterpillar Company

Solar Turbines Incorporated

9330 Sky Park Court
San Diego, CA 92123
Tel: (858) 694-1616

Submitted Electronically

September 20, 2016

Dave Brown
Program Manager Utilities – Department of Facilities
Massachusetts Institute of Technology
browndj@MIT.edu

RE: Titan™ 250 SoLoNOx™ Installation

Dear Mr. Brown:

The Titan 250 SoLoNOx planned for the MIT installation represents “best in class efficiency” and is equipped with state-of-the-art low emissions technology.

The Titan 250 leads the industry when it comes to power, efficiency, emissions and envelope. Since its introduction in 2004, the Titan 250 has benefited from Solar's long standing tradition of continuous improvement. The Titan 250 incorporates high efficiency airfoil designs, optimized cooling strategies, the latest ultra low emissions technologies

Solar's SoLoNOx technology employs lean-premixed combustion to reduce NOx emissions. Lean-premixed combustion reduces the conversion of atmospheric nitrogen to NOx by reducing the combustion flame temperatures as NOx formation rates are strongly dependent on flame temperature. Further reductions in emission are achieved by premixing the fuel and combustor airflow upstream of the combustor primary zone. The pre-mixing prevents stoichiometric burning locally with the flame, thus ensuring the entire flame is at fuel lean condition resulting in low emissions.


Please refer to the attached brochure for additional information on the Titan 250 and let me know if any additional detail on the features of the Titan 250 is needed to support the air permitting process.

Please contact me at 858.694.6609 if you have any questions or need any additional information.

Sincerely,
Solar Turbines Incorporated
Leslie Witherspoon
Manager Environmental Programs
witherspoon_leslie_h@solarturbines.com

cc: Bernie Pfeiffer, Solar

DNX® GT



DNX® GT series – Raising performance

The DNX® GT-series is Haldor Topsoe's recently developed line of catalysts tailored for gas turbine service. The GT-series comprises a range of GT catalysts for SCR NOx reduction and GTC catalysts for CO oxidation. Topsoe's DNX® GT-series offers:

- lower pressure drop
- improved activity
- enhanced operation in all temperature ranges
- fast emission compliance

Features

To enhance power production by minimizing the pressure drop and the required space for catalyst in the heat recovery steam generator (HRSG), Topsoe has developed a dedicated series of gas-turbine catalysts for SCR and for CO oxidation.

SCR catalysts

The GT catalysts feature an enhanced SCR activity which has been achieved through reformulating and changing the monolith structure of the original DNX®catalyst. Thereby an increased specific surface area and a higher catalyst wall utilization have been achieved which together with a larger open area provide an attractive combination of increased activity and lower pressure drop.

CO oxidation catalysts

catalyst and are available as a high-temperature version that can be positioned upstream the ammonia injection grid (AIG) and a version optimized for positioning downstream the SCR catalyst where the dual functionality leads to reduced SCR catalyst volume and in turn even lower pressure drop.

Benefits

The 20% boost in volume activity for the GT catalysts yield a corresponding reduction in required catalyst volume. Together with a 10% lower specific pressure drop, the GT catalysts offer a saving in overall pressure loss across the SCR catalyst in the order of 30% compared to the previous DNX® versions. The dual function of the GTC catalysts makes it possible to locate the CO-oxidation catalyst downstream of the SCR in the HRSG. The SCR can then be designed with excess ammonia slip which is subsequently eliminated across the GTC catalyst with the remaining part of the NOx in the flue gas. This combined GT-GTC solution offers more than 40% reduction in SCR catalyst volume and more than 25% reduction in total pressure drop.

The low volume of high-void catalysts has a low thermal mass that offers unlimited heating rate and consequently a minimum time until emission compliance.

Property	Value
Range	180 - 500°C 356 - 932°F
Composition	V2O5/WO3/TiO2
Shape	Corrugated monolith

Used in industries

Ammonia

Automotive

Bio fuels

Cement

Chemicals

Coke & coal

Energy & power

Fertilizer

Hydrogen

Methanol

Mining & smelting

Oil & gas

Paper & printing

Petrochemicals

Polymers & plastics

Refining

Shale oil
Ships & marine
Steel
Sulfuric acid
Syngas
Waste disposal

Used in processes
NOx & CO removal

FIND US

 Haldor Topsoe A/S (HQ)
Haldor Topsøes Allé 1
DK-2800
Kgs. Lyngby
Denmark

 +45 45 27 20 00

 topsoe@topsoe.dk

[Find all locations here](#)

Visit our regional sites:

China
Russia

PLEASE CONTACT ME

Nature of your enquiry*

- Please Select - 

First name *

Last name *

What do you want to talk about? *

- Yes, please send me regular e-mail updates about Haldor Topsoe news, insights, products, events and services

SUBMIT

LATEST TWEETS

-  RT @LederneDK: Fei Chen fra @HaldorTopsoe i mag. Lederne: Tryghed i Danmark åbner for anderledes tænkning og innovation. #dkledelse <https://t.co/PL4cTotTnT>
1 day 4 hours ago
-  RT @MichaelBMonty: Stor tryghed i Danmark giver en god basis for at lave innovation, mener Fei Chen fra @HaldorTopsoe #dkledelse... <https://t.co/qEzpoByDWR>
1 day 4 hours ago



Appendix B – Part 2

Engine Information

- ◆ CAT Engine Technical Data
- ◆ Loads Served by Engine

STANDBY 2000 kW 2500 kVA

60 Hz 1800 rpm 480 Volts



TECHNICAL DATA

Open Generator Set - - 1800 rpm/60 Hz/480 Volts	DM8263	
EPA Certified for Stationary Emergency Application (EPA Tier 2 emissions levels)		
Generator Set Package Performance Genset Power rating @ 0.8 pf Genset Power rating with fan	2500 kVA 2000 kW	
Fuel Consumption 100% load with fan 75% load with fan 50% load with fan	522.5 L/hr 406.8 L/hr 293.6 L/hr	138.0 Gal/hr 107.5 Gal/hr 77.6 Gal/hr
Cooling System¹ Air flow restriction (system) Air flow (max @ rated speed for radiator arrangement) Engine Coolant capacity with radiator/exp. tank Engine coolant capacity Radiator coolant capacity	0.12 kPa 2480 m ³ /min 475.0 L 233.0 L 242.0 L	0.48 in. water 87580 cfm 125.5 gal 61.6 gal 63.9 gal
Inlet Air Combustion air inlet flow rate	185.5 m ³ /min	6550.9 cfm
Exhaust System Exhaust stack gas temperature Exhaust gas flow rate Exhaust flange size (internal diameter) Exhaust system backpressure (maximum allowable)	400.1 ° C 433.1 m ³ /min 203.2 mm 6.7 kPa	752.2 ° F 15294.8 cfm 8.0 in 26.9 in. water
Heat Rejection Heat rejection to coolant (total) Heat rejection to exhaust (total) Heat rejection to aftercooler Heat rejection to atmosphere from engine Heat rejection to atmosphere from generator	759 kW 1788 kW 672 kW 133 kW 85.5 kW	43164 Btu/min 101683 Btu/min 38217 Btu/min 7564 Btu/min 4862.4 Btu/min
Alternator² Motor starting capability @ 30% voltage dip Frame Temperature Rise	4999 skVA 826 105 ° C	189 ° F
Lube System Sump refill with filter	466.0 L	123.1 gal
Emissions (Nominal)³ NOx g/hp-hr CO g/hp-hr HC g/hp-hr PM g/hp-hr	5.45 g/hp-hr .3 g/hp-hr .11 g/hp-hr .025 g/hp-hr	

¹ For ambient and altitude capabilities consult your Cat dealer. Air flow restriction (system) is added to existing restriction from factory.

² Generator temperature rise is based on a 40 degree C ambient per NEMA MG1-32. UL 2200 Listed packages may have oversized generators with a different temperature rise and motor starting characteristics.

³ Emissions data measurement procedures are consistent with those described in EPA CFR 40 Part 89, Subpart D & E and ISO8178-1 for measuring HC, CO, PM, NOx. Data shown is based on steady state operating conditions of 77°F, 28.42 in HG and number 2 diesel fuel with 35° API and LHV of 18,390 btu/lb. The nominal emissions data shown is subject to instrumentation, measurement, facility and engine to engine variations. Emissions data is based on 100% load and thus cannot be used to compare to EPA regulations which use values based on a weighted cycle.

PERFORMANCE DATA[DM8263]

Performance Number: DM8263

Change Level: 03

SALES MODEL:	3516C	COMBUSTION:	DI
ENGINE POWER (BHP):	2,937	ENGINE SPEED (RPM):	1,800
GEN POWER WITH FAN (EKW):	2,000.0	HERTZ:	60
COMPRESSION RATIO:	14.7	FAN POWER (HP):	114.0
APPLICATION:	PACKAGED GENSET	ASPIRATION:	TA
RATING LEVEL:	STANDBY	AFTERCOOLER TYPE:	ATAAC
PUMP QUANTITY:	2	AFTERCOOLER CIRCUIT TYPE:	JW+OC, ATAAC
FUEL TYPE:	DIESEL	INLET MANIFOLD AIR TEMP (F):	122
MANIFOLD TYPE:	DRY	JACKET WATER TEMP (F):	210.2
GOVERNOR TYPE:	ADEM3	TURBO CONFIGURATION:	PARALLEL
ELECTRONICS TYPE:	ADEM3	TURBO QUANTITY:	4
CAMSHAFT TYPE:	STANDARD	TURBOCHARGER MODEL:	GTA5518BN-56T-1.12
IGNITION TYPE:	CI	CERTIFICATION YEAR:	2006
INJECTOR TYPE:	EUI	CRANKCASE BLOWBY RATE (FT3/HR):	2,937.9
FUEL INJECTOR:	2664387	FUEL RATE (RATED RPM) NO LOAD (GAL/HR):	13.7
REF EXH STACK DIAMETER (IN):	12	PISTON SPD @ RATED ENG SPD (FT/MIN):	2,244.1
MAX OPERATING ALTITUDE (FT):	3,117		

General Performance Data

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	BRAKE MEAN EFF PRES (BMEP)	BRAKE SPEC FUEL CONSUMPTN (BSFC)	VOL FUEL CONSUMPTN (VFC)	INLET MFLD PRES	INLET MFLD TEMP	EXH MFLD TEMP	EXH MFLD PRES	ENGINE OUTLET TEMP
EKW	%	BHP	PSI	LB/BHP-HR	GAL/HR	IN-HG	DEG F	DEG F	IN-HG	DEG F
2,000.0	100	2,937	307	0.329	138.0	78.3	121.2	1,118.5	71.5	752.1
1,800.0	90	2,641	276	0.331	124.9	73.1	119.6	1,067.5	65.7	716.0
1,600.0	80	2,353	246	0.337	113.1	68.0	118.2	1,027.0	60.0	693.3
1,500.0	75	2,212	231	0.340	107.5	65.2	117.5	1,008.1	57.2	684.6
1,400.0	70	2,071	216	0.344	101.8	62.3	116.8	989.4	54.4	676.9
1,200.0	60	1,795	188	0.352	90.1	55.5	115.4	952.0	48.0	662.8
1,000.0	50	1,521	159	0.357	77.5	46.5	113.7	913.4	40.1	654.0
800.0	40	1,250	131	0.357	63.8	34.8	111.8	863.8	30.3	655.0
600.0	30	977	102	0.365	50.9	24.2	110.6	803.8	22.0	650.0
500.0	25	839	88	0.374	44.8	19.7	110.2	767.0	18.7	641.7
400.0	20	699	73	0.388	38.8	15.7	109.8	724.6	15.7	629.0
200.0	10	411	43	0.450	26.4	9.0	109.1	596.9	10.9	552.8

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	COMPRESSOR OUTLET PRES	COMPRESSOR OUTLET TEMP	WET INLET AIR VOL FLOW RATE	ENGINE OUTLET WET EXH GAS VOL FLOW RATE	WET INLET AIR MASS FLOW RATE	WET EXH GAS MASS FLOW RATE	WET EXH VOL FLOW RATE (32 DEG F AND 29.98 IN HG)	DRY EXH VOL FLOW RATE (32 DEG F AND 29.98 IN HG)
EKW	%	BHP	IN-HG	DEG F	CFM	CFM	LB/HR	LB/HR	FT3/MIN	FT3/MIN
2,000.0	100	2,937	83	454.3	6,548.9	15,292.8	28,512.8	29,478.4	6,205.0	5,738.7
1,800.0	90	2,641	77	428.8	6,318.7	14,243.0	27,390.5	28,264.7	5,956.5	5,533.7
1,600.0	80	2,353	72	404.5	6,073.3	13,331.0	26,220.6	27,012.9	5,685.0	5,301.6
1,500.0	75	2,212	69	392.7	5,932.2	12,897.9	25,568.0	26,319.7	5,542.0	5,176.6
1,400.0	70	2,071	66	380.9	5,777.2	12,448.0	24,862.1	25,573.8	5,384.8	5,037.5
1,200.0	60	1,795	59	353.9	5,397.2	11,422.5	23,141.0	23,771.1	5,003.4	4,694.0
1,000.0	50	1,521	50	318.8	4,857.3	10,138.7	20,731.5	21,274.5	4,476.2	4,208.4
800.0	40	1,250	38	271.1	4,090.0	8,488.8	17,357.1	17,803.6	3,744.5	3,524.2
600.0	30	977	27	225.0	3,394.1	6,989.6	14,328.5	14,684.4	3,097.0	2,920.6
500.0	25	839	22	204.1	3,103.5	6,328.1	13,075.2	13,388.4	2,825.1	2,668.8
400.0	20	699	18	184.1	2,840.4	5,696.0	11,947.2	12,218.4	2,572.5	2,435.7
200.0	10	411	11	148.5	2,409.4	4,478.2	10,105.7	10,290.7	2,174.6	2,076.8

PERFORMANCE DATA[DM8263]

Heat Rejection Data

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	REJECTION TO JACKET WATER	REJECTION TO ATMOSPHERE	REJECTION TO EXH	EXHUAUST RECOVERY TO 350F	FROM OIL COOLER	FROM AFTERCOOLER	WORK ENERGY	LOW HEAT VALUE ENERGY	HIGH HEAT VALUE ENERGY
EKW	%	BHP	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN
2,000.0	100	2,937	43,150	7,564	101,696	49,615	15,778	38,240	124,558	296,234	315,563
1,800.0	90	2,641	40,179	7,175	92,069	43,106	14,280	34,105	111,977	268,102	285,596
1,600.0	80	2,353	37,427	6,907	84,225	38,510	12,931	30,201	99,774	242,774	258,615
1,500.0	75	2,212	36,092	6,791	80,632	36,523	12,286	28,303	93,784	230,664	245,715
1,400.0	70	2,071	34,737	6,671	77,064	34,629	11,640	26,432	87,835	218,548	232,809
1,200.0	60	1,795	31,877	6,341	69,432	30,722	10,302	22,179	76,103	193,426	206,048
1,000.0	50	1,521	28,631	6,026	60,835	26,675	8,865	17,129	64,508	166,434	177,294
800.0	40	1,250	24,910	5,810	50,784	22,387	7,288	11,280	53,005	136,837	145,766
600.0	30	977	21,252	5,496	41,420	18,139	5,820	6,677	41,431	109,268	116,397
500.0	25	839	19,405	5,303	37,082	16,055	5,124	4,986	35,574	96,210	102,488
400.0	20	699	17,492	5,098	32,738	13,986	4,431	3,593	29,634	83,193	88,622
200.0	10	411	13,286	4,670	23,481	8,473	3,022	1,516	17,448	56,745	60,447

PERFORMANCE DATA[DM8263]

Emissions Data

RATED SPEED POTENTIAL SITE VARIATION: 1800 RPM

GENSET POWER WITH FAN	EKW	2,000.0	1,500.0	1,000.0	500.0	200.0
ENGINE POWER	BHP	2,937	2,212	1,521	839	411
PERCENT LOAD	%	100	75	50	25	10
TOTAL NOX (AS NO2)	G/HR	19,098	10,213	5,798	4,218	2,932
TOTAL CO	G/HR	1,564	847	905	1,772	1,794
TOTAL HC	G/HR	423	513	512	409	443
PART MATTER	G/HR	103.2	99.5	123.9	256.7	203.1
TOTAL NOX (AS NO2)	(CORR 5% O2) MG/NM3	3,299.4	2,320.1	1,852.8	2,379.4	2,855.8
TOTAL CO	(CORR 5% O2) MG/NM3	257.0	181.1	277.5	896.4	1,715.8
TOTAL HC	(CORR 5% O2) MG/NM3	60.1	93.7	132.1	194.2	379.5
PART MATTER	(CORR 5% O2) MG/NM3	14.4	18.5	35.1	120.0	161.3
TOTAL NOX (AS NO2)	(CORR 5% O2) PPM	1,607	1,130	902	1,159	1,391
TOTAL CO	(CORR 5% O2) PPM	206	145	222	717	1,373
TOTAL HC	(CORR 5% O2) PPM	112	175	247	363	708
TOTAL NOX (AS NO2)	G/HP-HR	6.54	4.64	3.82	5.04	7.13
TOTAL CO	G/HP-HR	0.54	0.38	0.60	2.12	4.36
TOTAL HC	G/HP-HR	0.15	0.23	0.34	0.49	1.08
PART MATTER	G/HP-HR	0.04	0.05	0.08	0.31	0.49
TOTAL NOX (AS NO2)	LB/HR	42.10	22.52	12.78	9.30	6.46
TOTAL CO	LB/HR	3.45	1.87	2.00	3.91	3.95
TOTAL HC	LB/HR	0.93	1.13	1.13	0.90	0.98
PART MATTER	LB/HR	0.23	0.22	0.27	0.57	0.45

RATED SPEED NOMINAL DATA: 1800 RPM

GENSET POWER WITH FAN	EKW	2,000.0	1,500.0	1,000.0	500.0	200.0
ENGINE POWER	BHP	2,937	2,212	1,521	839	411
PERCENT LOAD	%	100	75	50	25	10
TOTAL NOX (AS NO2)	G/HR	15,915	8,511	4,832	3,515	2,443
TOTAL CO	G/HR	869	471	503	984	997
TOTAL HC	G/HR	318	385	385	308	333
TOTAL CO2	KG/HR	1,383	1,068	762	430	250
PART MATTER	G/HR	73.7	71.1	88.5	183.4	145.1
TOTAL NOX (AS NO2)	(CORR 5% O2) MG/NM3	2,749.5	1,933.4	1,544.0	1,982.8	2,379.8
TOTAL CO	(CORR 5% O2) MG/NM3	142.8	100.6	154.2	498.0	953.2
TOTAL HC	(CORR 5% O2) MG/NM3	45.2	70.4	99.3	146.0	285.3
PART MATTER	(CORR 5% O2) MG/NM3	10.3	13.2	25.1	85.7	115.2
TOTAL NOX (AS NO2)	(CORR 5% O2) PPM	1,339	942	752	966	1,159
TOTAL CO	(CORR 5% O2) PPM	114	80	123	398	763
TOTAL HC	(CORR 5% O2) PPM	84	131	185	273	533
TOTAL NOX (AS NO2)	G/HP-HR	5.45	3.87	3.19	4.20	5.94
TOTAL CO	G/HP-HR	0.30	0.21	0.33	1.18	2.42
TOTAL HC	G/HP-HR	0.11	0.18	0.25	0.37	0.81
PART MATTER	G/HP-HR	0.03	0.03	0.06	0.22	0.35
TOTAL NOX (AS NO2)	LB/HR	35.09	18.76	10.65	7.75	5.39
TOTAL CO	LB/HR	1.92	1.04	1.11	2.17	2.20
TOTAL HC	LB/HR	0.70	0.85	0.85	0.68	0.73
TOTAL CO2	LB/HR	3,049	2,356	1,681	947	551
PART MATTER	LB/HR	0.16	0.16	0.20	0.40	0.32
OXYGEN IN EXH	%	10.8	12.3	13.3	14.2	15.8
DRY SMOKE OPACITY	%	0.3	0.5	1.2	3.7	3.0
BOSCH SMOKE NUMBER		0.15	0.21	0.43	1.25	1.12

MIT CUP Second Century Upgrade Project
Black Start Load List

Equip Tag No.	Location	Description	Electrical						FULL LOAD AMPS (NORMAL OPS)	CONNECTED kVA (NORMAL OPS)	BLACK START / EMERG kVA
			Stand-by Equip.	Power HP	Power kW	Volts	Hz	VFD			
CTG-200			StandBy	HP	kW	Volts	Hz	VFD			
BC-201	B42C-LV-03	Battery Charger	N	-	5.5	120	60	N			
D-201	B42C-LV-03	Generator Ventilation Air Damper	N	-	0.1	120	60	N			
FN-201	B42C-LV-03	CTG Supply Ventilation Air Fan	N	75	56.0	480	60	N	96	79.8	79.8
FN-202	B42C-LV-03	CTG Supply Ventilation Air Fan	Y	75	56.0	480	60	N	0	0.0	
FN-203	B42C-LV-03	CTG Exhaust Ventilation Air Fan	N	75	56.0	480	60	N	96	79.8	79.8
FN-204	B42C-LV-03	CTG Exhaust Ventilation Air Fan	Y	75	56.0	480	60	N	0	0.0	
GTSM-201	B42C-LV-03	Engine Starter Motor	N	200	149.2	480	60	Y	240	199.5	199.5
EC-201	B42C-LV-03	Engine On-line Water Wash Vessel	N	10	8.4	480	60	N	14	11.6	
WIP-201	B42C-LV-03	Water injection pump #1	N	5	4.2	480	60	N	7.6	6.3	6.3
-	B42C-LV-03	Starter Motor Space Heater	N	-	0.2	120	60	N			
LOP-201	B42C-LV-03	Backup Lube Oil pump	N	2.5	2.1	120	DC	N			
-	B42C-LV-03	Lube Oil heater	N	-	20.0	480	60	N	28.9	24.0	24.0
PLP-201	B42C-LV-03	Pre/Post Lube Oil pump	N	7.5	6.3	480	60	N	11	9.1	9.1
-	B42C-LV-03	Generator Space Heater	N	-	3.0	120	60	N			
JOP-201	B42C-LV-03	Jacking Oil pump	N	5	4.2	480	60	N	7.6	6.3	6.3
LFP-201	B42C-LV-03	Liquid Fuel Booster Pump 1	N	20	16.8	480	60	N	27	22.4	
-	B42C-LV-03	Enclosure Lights	N	-	1.0	120	60	N			
CTG-300			StandBy	HP	kW	Volts	Hz	VFD			
BC-301	B42C-LV-03	Battery Charger	N	-	5.5	120	60	N			
D-301	B42C-LV-03	Generator Venilation Air Damper/Actuator	N	-	0.1	120	60	N			
FN-301	B42C-LV-03	CTG Supply Ventilation Air Fan	N	75	56.0	480	60	N	96	79.8	
FN-302	B42C-LV-03	CTG Supply Ventilation Air Fan	Y	75	56.0	480	60	N	0	0.0	
FN-303	B42C-LV-03	CTG Exhaust Ventilation Air Fan	N	75	56.0	480	60	N	96	79.8	
FN-304	B42C-LV-03	CTG Exhaust Ventilation Air Fan	Y	75	56.0	480	60	N	0	0.0	
GTSM-301	B42C-LV-03	Engine Starter Motor	N	200	149.2	480	60	Y	0	0.0	
EC-301	B42C-LV-03	Engine On-line Water Wash Vessel	N	10	8.4	480	60	N	14	11.6	
WIP-301	B42C-LV-03	Water injection pump #1	N	5	4.2	480	60	N	7.6	6.3	
-	B42C-LV-03	Starter Motor Space Heater	N	-	0.2	120	60	N			
LOP-301	B42C-LV-03	Backup Lube Oil pump	N	2.5	2.1	120	DC	N			
-	B42C-LV-03	Lube Oil heater	N	-	20.0	480	60	N	28.9	24.0	
PLP-301	B42C-LV-03	Pre/Post Lube Oil pump	N	7.5	6.3	480	60	N	11	9.1	
-	B42C-LV-03	Generator Space Heater	N	-	3.0	120	60	N			
JOP-301	B42C-LV-03	Jacking Oil pump	N	5	4.2	480	60	N	7.6	6.3	
LFP-301	B42C-LV-03	Liquid Fuel Booster Pump 1	N	20	16.8	480	60	N	27	22.4	
-	B42C-LV-03	Enclosure Lights	N	-	1.0	-	-	N			
HRS-200			StandBy	HP	kW	Volts	Hz	VFD			
PAF-201	B42C-LV-03	Purge Air Fan	N	20	16.8	480	60	N	27	22.4	22.4
CEMS-201	TBD	CEMS	N	-	x	120	60	N			
ED-203	B42C-LV-03	Flue Gas Exhaust Damper/Actuator	N	-	2.0	480	60	N	2.9	2.4	2.4
-	TBD	Control panel lighting	N	-	x	120	60	N			
HRS-200 Fuel System			StandBy	HP	kW	Volts	Hz	VFD			
SAB-201	B42C-LV-03	Scanner Air Blower	N	3	2.5	480	60	N	4.8	4.0	
SAB-202	B42C-LV-03	Scanner Air Blower	Y	3	2.5	480	60	N	0	0.0	
HRS-300			StandBy	HP	kW	Volts	Hz	VFD			
PAF-301	B42C-LV-03	Purge Air Fan	N	20	16.8	480	60	N	27	22.4	
CEMS-301	TBD	CEMS	N	-	-	-	-	N			
ED-303	B42C-LV-03	Flue Gas Exhaust Damper/Actuator	N	-	2.0	480	60	N	2.9	2.4	
-	TBD	Control panel lighting	N	-	x	120	60	N			
HRS-300 Fuel System			StandBy	HP	kW	Volts	Hz	VFD			
SAB-301	B42C-LV-03	Scanner Air Blower	N	3	2.5	480	60	N	4.8	4.0	
SAB-302	B42C-LV-03	Scanner Air Blower	Y	3	2.5	480	60	N	0	0.0	
Steam System			StandBy	HP	kW	Volts	Hz	VFD			
Condensate System			StandBy	HP	kW	Volts	Hz	VFD			
Boiler Feedwater - Sheet 1			StandBy	HP	kW	Volts	Hz	VFD			
Treated Water			StandBy	HP	kW	Volts	Hz	VFD			
RO-100	B42C-LV-03	RO EDI Package 1	N	-	1.0	120	60	N			
ROP-101	B42C-LV-03	RO Booster Pump 1	N	2	1.7	480	60	N	3.4	2.8	
Urea			StandBy	HP	kW	Volts	Hz	VFD			
Steam Turbine			StandBy	HP	kW	Volts	Hz	VFD			
Process Cooling Water			StandBy	HP	kW	Volts	Hz	VFD			
PCP-001	B42C-LV-05	Process Cooling Water Pump	N	75	56.0	480	60	N	96	79.8	79.8
PCP-002	B42C-LV-05	Process Cooling Water Pump	N	75	56.0	480	60	N	96	79.8	
PCP-003	B42C-LV-05	Process Cooling Water Pump	Y	75	56.0	480	60	N	96	79.8	
Compressed Air			StandBy	HP	kW	Volts	Hz	VFD			
AC-105	B42C-LV-05	Air Compressor 1 - electric driven	N	250	186.5	480	60	Y	302	251.1	251.1
IAD-105	B42C-LV-05	Dessicant Air Dryer Package	N	-	6.0	460	60	N	8.7	7.2	
Chemical Feed			StandBy	HP	kW	Volts	Hz	VFD			
Blowdown & Steam Drips Sheet 1			StandBy	HP	kW	Volts	Hz	VFD			

MIT CUP Second Century Upgrade Project
Black Start Load List



Equip Tag No.	Location	Description	Electrical						FULL LOAD AMPS (NORMAL OPS)	CONNECTED kVA (NORMAL OPS)	BLACK START / EMERG kVA
			Stand-by Equip.	Power HP	Power kW	Volts	Hz	VFD			
CRP-101	B42C-LV-03	Flashed Condensate Pump 1	N	10	8.4	480	60	N	14	11.6	11.6
CRP-102	B42C-LV-03	Flashed Condensate Pump 2	Y	10	8.4	480	60	N	0	0.0	
Fuel Gas			StandBy	HP	kW	Volts	Hz	VFD			
FGC-101	Roof	Fuel Gas Compressor - One Stage Two Turbines	N	350	261.1	480	60	Y	414	344.2	344.2
Water Sampling			StandBy	HP	kW	Volts	Hz	VFD			
Chilled Water			StandBy	HP	kW	Volts	Hz	VFD			
Glycol System			StandBy	HP	kW	Volts	Hz	VFD			
Hot Water System			StandBy	HP	kW	Volts	Hz	VFD			
HWP-101	TBD	HW Pump 1	N	15	12.6	480	60	Y	21	17.5	21
HWP-102	TBD	HW Pump 2	Y	15	12.6	480	60	Y	21	17.5	
STAND BY/BLACK START			StandBy	HP	kW	Volts	Hz	VFD			
DEG-	B42C-TBD	Starting motor	-	20	16.8	480	60	-	27	22.4	22.4
DEG-	B42C-TBD	Radiator fan no. 1	-	2	1.7	480	60	-	3.4	2.8	2.8
DEG-	B42C-TBD	Radiator fan no. 2	-	2	1.7	480	60	-	3.4	2.8	2.8
DEG-	B42C-TBD	Radiator fan no. 3	-	2	1.7	480	60	-	3.4	2.8	2.8
DEG-	B42C-TBD	Radiator fan no. 4	-	2	1.7	480	60	-	3.4	2.8	2.8
DEG-	B42C-TBD	Enclosure misc. power (lighting, heat etc.)	-	-	15.0	480	60	-	21.7	18.0	18.0
DEG-201	B42C-TBD	Enclosure control panel	-	-	0.5	120	60	-			
DEG-	B42C-TBD	Enclosure fire protection panel	-	-	0.5	120	60	-			
DEG-	B42C-TBD	Block heater (jacket water) and circ pump	-	-	12.0	480	60	-	17.3	14.4	14.4
DFOP-201	B42C-TBD	Fuel Oil Pump	-	0.75	0.6	-	-	-	1.6	1.3	1.3
DFOP-202	B42C-TBD	Fuel Oil Pump	-	0.75	0.6	-	-	-	1.6	1.3	1.3
DFOP-203	B42C-TBD	Fuel Oil Return Pump	-	0.5	0.4	-	-	-	1.1	0.9	0.9
DFOP-204	B42C-TBD	Fuel Oil Return Pump	-	0.5	0.4	-	-	-	1.1	0.9	0.9
Fuel Oil			StandBy	HP	kW	Volts	Hz	VFD			
FOS-100	B42C-LV-02	Fuel Oil Pump Skid - 1	N	-	0.5	120	60	-			
FOSP-101	B42C-LV-02	Fuel Oil Supply Pump 1	N	10	8.4	480	60	-	14	11.6	
FOSP-102	B42C-LV-02	Fuel Oil Supply Pump 2	Y	10	8.4	480	60	-	0	0.0	
FOT-100	B42- TBD	Fuel Oil Pump Skid - Transfer	N	-	0.5	120	60	-			
FOTP-101	B42- TBD	Fuel Oil Transfer Pump 1	N	20	16.8	480	60	-	27	22.4	
FOTP-102	B42- TBD	Fuel Oil Transfer Pump 2	Y	20	16.8	480	60	-	0	0.0	
Control System			StandBy	HP	kW	Volts	Hz	VFD			
HVAC			StandBy	HP	kW	Volts	Hz	VFD			
ERU-1		Offices Elev 18'-4" Mech Room (SF & EF)	N	2	1.6785	480	60	Y	6.8	5.7	
AHU-4		Control Room Area	N	7.5	6.294375	480	60	Y	11	9.1	9.1
AHU-5		Control Room Area	Y	7.5	6.294375	480	60	Y	0	0.0	
BCU-5		Substation & MCC Room #1	N	10	8.3925	480	60	Y	14	11.6	11.6
BCU-6		Substation & MCC Room #2	N	10	8.3925	480	60	Y	14	11.6	11.6
BCU-3		Cogen Electrical Room #1	N	0.5	0.419625	480	60	N	1.1	0.9	0.9
BCU-4		Cogen Electrical Room #2	N	0.5	0.419625	480	60	N	1.1	0.9	0.9
BCU-7		13GAC Bus Electrical Switchgear Room	N	1	0.83925	480	60	N	2.1	1.7	1.7
BCU-8		13GBD Bus Electrical Switchgear Room	N	1	0.83925	480	60	N	2.1	1.7	1.7
BCU-9		13C Bus Electrical Switchgear Room	N	1	0.83925	480	60	N	2.1	1.7	1.7
BCU-10		13D Bus Electrical Switchgear Room	N	1	0.83925	480	60	N	2.1	1.7	1.7
BCU-11		Rack Room 365	N	1	0.83925	480	60	N	2.1	1.7	1.7
BCU-12		Rack Room 365	Y	1	0.83925	480	60	N	2.1	1.7	
BCU-13		Main Reception 106	N	1	0.83925	480	60	N	2.1	1.7	
BCU-14		Multipurpose Room 110	N	1	0.83925	480	60	N	2.1	1.7	
BCU-15		Office Suite 120	N	0.5	0.419625	480	60	N	1.1	0.9	
BCU-16		Office 131, 133, 135	N	0.5	0.419625	480	60	N	1.1	0.9	
BCU-17		Print/File Room 136	N	0.5	0.419625	480	60	N	1.1	0.9	
BCU-18		Electrical Workshop 139	N	1	0.83925	480	60	N	2.1	1.7	
BCU-19		Corridor A 100C	N	1	0.83925	480	60	N	2.1	1.7	
UH-9		42C Receiving/Unloading Area (Steam UH)	N	0.33	0.276953	120	60	N			
UH-10		42C Receiving/Unloading Area (Steam UH)	N	0.33	0.276953	120	60	N			
SF-5		Fuel Oil Tank Room	N	5	4.19625	480	60	Y	7.6	6.3	6.3
SF-6		Receiving/Unloading Area	N	0.75	0.629438	480	60	Y	1.6	1.3	
SF-7		Cogen Plant Room	N	25	20.98125	480	60	Y	34	28.3	28.3
SF-8		Cogen Plant Room	N	25	20.98125	480	60	Y	34	28.3	28.3
SF-9		Cogen Plant Room	N	25	20.98125	480	60	Y	34	28.3	28.3
SF-10		Cogen Plant Room	N	25	20.98125	480	60	Y	34	28.3	28.3
SF-11		Cogen Plant Room	N	25	20.98125	480	60	Y	34	28.3	28.3
SF-12		Cogen Plant Room	N	25	20.98125	480	60	Y	34	28.3	28.3
SF-13B		Battery Room #2	N	0.5	0.419625	480	60	N	1.1	0.9	0.9
SF-14		Electrical Switchgear Rooms	N	1.5	1.258875	480	60	Y	3	2.5	2.5
RF-1		AHU-4 & AHU-5	N	3	2.51775	480	60	Y	4.8	4.0	4.0
EF-3		Fuel Oil Tank Room	N	5	4.19625	480	60	Y	7.6	6.3	6.3
EF-4		Receiving/Unloading Area	N	0.75	0.629438	480	60	Y	1.6	1.3	
EF-5B		Battery Room #2	N	0.5	0.419625	480	60	N	1.1	0.9	0.9

MIT CUP Second Century Upgrade Project
Black Start Load List

Equip Tag No.	Location	Description	Electrical						FULL LOAD AMPS (NORMAL OPS)	CONNECTED kVA (NORMAL OPS)	BLACK START / EMERG kVA
			Stand-by Equip.	Power HP	Power kW	Volts	Hz	VFD			
EF-6		Electrical Switchgear Rooms	N	1.5	1.258875	480	60	Y	3	2.5	2.5
EF-13		Cogen Plant Exhaust	N	15	12.58875	480	60	Y	21	17.5	17.5
EF-14		Cogen Plant Exhaust	N	15	12.58875	480	60	Y	21	17.5	17.5
EF-15		Cogen Plant Exhaust	N	15	12.58875	480	60	Y	21	17.5	17.5
EF-8		Cogen Plant Exhaust	N	15	12.58875	480	60	Y	21	17.5	17.5
EF-9		Cogen Plant Exhaust	N	15	12.58875	480	60	Y	21	17.5	17.5
EF-10		Cogen Plant Exhaust	N	15	12.58875	480	60	Y	21	17.5	17.5
EF-11		Cogen Plant Exhaust	N	15	12.58875	480	60	Y	21	17.5	17.5
EF-12		Cogen Plant Exhaust	N	15	12.58875	480	60	Y	21	17.5	17.5
TF-1		Toilet Exhaust elev 18'-4"	N	0.18	0.151065	115	60	N			
PFP			StandBy	HP	kW	Volts	Hz	VFD			
Fire Protection											
Plumbing											
Electrical Equip											
		General Bldg Lighting	N	--	150.0	277	60		348	167.0	167
									3762.8	3006.0	1750.9
									AMPS	kVA	kVA
										480V SUB(s)	DIESEL GEN

Appendix B – Part 3

Process Flow Diagram



Appendix B – Part 4

RBLC Lookup Printouts

- ◆ Signal Hills Wichita Falls Power LP
- ◆ Maui Electric Company Maalaea Generating Station
- ◆ Lenzing Fibers, Inc.
- ◆ CARB lookup for Los Angeles County Sanitation District

https://cfpub.epa.gov/rblc/index.cfm?action=PermitDetail.PollutantInfo&Facility_ID=26619&Process_ID=105885&Pollutant_ID=229&Permit_Control_Equipment_Id=144338

Last updated on 8/23/2016



Technology Transfer Network

[Clean Air Technology Center](#) | [EPA Environmental Protection Agency](#) | [Technology Transfer Network](#) | [RACT/BACT/LAER Clearinghouse](#) | [Pollutant Information](#) | [Clearinghouse](#) | [RBLC Basic Search](#) | [RBLC Search Results](#) | [Pollutant Information](#)

Pollutant Information

Click on the **Process Information** button to see more information about the process associated with this pollutant.
 Or click on the **Process List** button to return to the list of processes.

[RBLC Home](#) | [New Search](#) | [Search Results](#) | [Facility Information](#) | [Process List](#) | [Process Information](#)

Pollutant Information

[Help](#)

FINAL

RBLC ID: TX-0498

Corporate/Company: SIGNAL HILLS

Facility Name: SIGNAL HILLS WICHITA FALLS POWER LP

Process: TURBINES (3)

Pollutant: Particulate Matter (PM)

CAS Number: PM

Pollutant Group(s): Particulate Matter (PM),

Substance Registry System: Particulate Matter (PM)

Pollution Prevention/Add-on Control Equipment/Both/No Controls Feasible: N

P2/Add-on Description:

Test Method:

Unspecified

[EPA/OAR Methods](#)

[All Other Methods](#)

Percent Efficiency:

0

Compliance Verified:

Unknown

EMISSION LIMITS:

Case-by-Case Basis:

BACT-PSD

Other Applicable Requirements:

Other Factors Influence Decision:

Unknown

Emission Limit 1:

1.0400 LB/H

Emission Limit 2:

4.5700 T/YR

Standard Emission Limit:

0

COST DATA:

Cost Verified?

No

Dollar Year Used in Cost Estimates:

Cost Effectiveness:

0 \$/ton

Incremental Cost Effectiveness:

0 \$/ton

Pollutant Notes:

This document will now print as it appears on screen when you use the File » Print command.

Use View » Refresh to return to original state.



Technology Transfer Network

[Clean Air Technology Center](#) | [EPA Technology Transfer Network](#) | [EPA Technology Center](#) | [RACT/BACT/LAER Clearinghouse](#) | [RBLC Basic Search](#) | [RBLC Search Results](#) | [Pollutant Information](#)

Pollutant Information

Click on the **Process Information** button to see more information about the process associated with this pollutant.
 Or click on the **Process List** button to return to the list of processes.

[RBLC Home](#) | [New Search](#) | [Search Results](#) | [Facility Information](#) | [Process List](#) | [Process Information](#)
[Pollutant Information](#)

[Help](#)

FINAL

RBLC ID: HI-0021

Corporate/Company: MAUI ELECTRIC COMPANY, LTD.

Facility Name: MAALAEA GENERATING STATION

Process: COMBUSTION TURBINE, COMBINED CYCLE (2)

Pollutant: Particulate Matter (PM)

CAS Number: PM

Pollutant Group(s): Particulate Matter (PM),

Substance Registry System: Particulate Matter (PM)

Pollution Prevention/Add-on Control Equipment/Both/No Controls Feasible: P

P2/Add-on Description: GOOD COMBUSTION DESIGN AND OPERATION.

Test Method:

Unspecified

[EPA/OAR Methods](#)

[All Other Methods](#)

Percent Efficiency:

0

Compliance Verified:

Unknown

EMISSION LIMITS:

Case-by-Case Basis:

BACT-PSD

Other Applicable Requirements:

Other Factors Influence Decision:

Unknown

Emission Limit 1:

0.0450 GR/DSCF @ 12% CO2 3 HR AVERAGE

Emission Limit 2:

19.7000 LB/H 3 HR AVERAGE

Standard Emission Limit:

0

COST DATA:

Cost Verified?

No

Dollar Year Used in Cost Estimates:

2005

Cost Effectiveness:

0 \$/ton

Incremental Cost Effectiveness:

0 \$/ton

Pollutant Notes:

https://cfpub.epa.gov/rblc/index.cfm?action=PermitDetail.PollutantInfo&Facility_ID=27807&Process_ID=109776&Pollutant_ID=170&Permit_Control_Equipment_Id=156421

Last updated on 8/23/2016



Technology Transfer Network

Clean Air Technology Center | RACT/BACT/LAER Clearinghouse | Technology Center | RACT/BACT/LAER Clearinghouse | RBLC Basic Search | RBLC Search Results | Pollutant Information

Pollutant Information

Click on the **Process Information** button to see more information about the process associated with this pollutant.
Or click on the **Process List** button to return to the list of processes.

[RBLC Home](#)

[New Search](#)

[Search Results](#)

[Facility Information](#)

[Process List](#)

[Process Information](#)

[Pollutant Information](#)

[Help](#)

FINAL

RBLC ID: AL-0282

Corporate/Company: LENZING FIBERS, INC.

Facility Name: LENZING FIBERS, INC.

Process: Gas Turbine with HRSG

Pollutant: Particulate matter, filterable (FPM)

CAS Number: PM

Pollutant Group(s): Particulate Matter (PM),

Substance Registry System: Particulate matter, filterable (FPM)

Pollution Prevention/Add-on Control Equipment/Both/No Controls Feasible: P

P2/Add-on Description: Good combustion practices.

Test Method:

EPA/OAR Mthd 5

[EPA/OAR Methods](#)

[All Other Methods](#)

Percent Efficiency:

0

Compliance Verified:

Unknown

EMISSION LIMITS:

Case-by-Case Basis:

BACT-PSD

Other Applicable Requirements:

OPERATING PERMIT

Other Factors Influence Decision:

Unknown

Emission Limit 1:

0.0075 LB/MMBTU

Emission Limit 2:

0

Standard Emission Limit:

0

COST DATA:

Cost Verified?

No

Dollar Year Used in Cost Estimates:

Cost Effectiveness:

0 \$/ton

Incremental Cost Effectiveness:

0 \$/ton

Pollutant Notes:



BACT Determination Detail

Category

Source Category:	Gas Turbine: Combined Cycle < 50 MW
SIC Code	4952
NAICS Code	22132

Emission Unit Information

Manufacturer:	Solar
Type:	Combined Cycle
Model:	MARS 90 13000
Equipment Description:	
Capacity / Dimentions	9.9 MW
Fuel Type	Landfill Gas
Multiple Fuel Types	
Operating Schedule (hours/day)/(days/week) /(weeks/year)e	Continuous (24/7/52)
Function of Equipment	

Bact Information

NOx Limit	25
NOx Limit Units	ppmvd@15%O2
NOx Average Time	
NOx Control Method	Add-on
NOx Control Method Desc	water injection
NOx Percent Control Efficiency	
NOx Cost Effectiveness (%/ton)	
NOx Incremental Cost Effectiveness (%/ton)	
NOx Cost Verified (Y/N)	
NOx Dollar Year	
CO Limit	60
CO Limit Units	ppmvd@15%O2
CO Average Time	
<i>CO Control Method</i>	
CO Control Method Desc	
CO Percent Control Efficiency	
CO Cost Effectiveness (%/ton)	
CO Incremental Cost Effectiveness (%/ton)	

CO Cost Verified (Y/N)

CO Dollar Year

VOC Limit 4.5

VOC Limit Units lb/hr as ROG

VOC Average Time

VOC Control Method

VOC Control Method Desc

VOC Percent Control
Efficiency

VOC Cost Effectiveness
(%/ton)

VOC Incremental Cost
Effectiveness (%/ton)

VOC Cost Verified (Y/N)

VOC Dollar Year

PM Limit 5.7

PM Limit Units lb/hr

PM Average Time

PM Control Method

PM Control Method Desc

PM Percent Control
Efficiency

PM Cost Effectiveness
(%/ton)

PM Incremental Cost
Effectiveness (%/ton)

PM Cost Verified (Y/N)

PM Dollar Year

SOx Limit **1.3**

SOx Limit Units **lb/hr**

SOx Average Time

SOx Control Method

SOx Control Method Desc

SOx Percent Control
Efficiency

SOx Cost Effectiveness
(%/ton)

SOx Incremental Cost
Effectiveness (%/ton)

SOx Cost Verified (Y/N)

SOx Dollar Year

Project / Permit Information

Application/Permit No.: 358625

Application Completeness
Date:

New Construction/Modification: Modification

ATC Date: 07-25-2000

PTO Date:

Startup Date: 03-31-2002

Technology Status: BACT Determination

Source Test Available: Yes

Source Test Results:

Facility / District Information

Facility Name: Los Angeles County Sanitation District

Facility Zip Code:

Facility County: Los Angeles

District Name: South Coast AQMD

District Contact: Martin Kay

Contact Phone No.: 909-396-3115

Contact E-Mail: mkay@aqmd.gov

Notes

Notes:

[Report Error In Determination](#)

Appendix B – Part 5

NOx Tracking Sheet

Massachusetts Institute of Technology's 5 Year Rolling NO_x Emissions Increases/Decreases Summary⁽¹⁾

2015-2019

Last Updated 20/25/16

Emission Unit ⁽²⁾	Year Installed	Rated Heat Input (mmBtu/hr)	Current Allowable Operation per Rolling Twelve Month Calendar Period (Hours)	NO _x Emission Factor		NO _x PTE per Rolling Twelve Month Calendar Period (tons) ⁽³⁾	Actual NO _x Emissions per Rolling Twelve Month Calendar Period (tons) ⁽³⁾
NGH-E52	2015	1.50	8760	100	lb/10 ⁶ SCF	N/A	0.066
NGH-NW35	2015	2.10	8760	0.0	lb/MMBTU	N/A	0.000
NGH-NW23	2015	2.00	8760	0.02	lb/MMBTU	N/A	0.000
NGH-W8	2015	0.40	8760	100	lb/10 ⁶ SCF	N/A	0.018
NGH-W86	2016	16.40	8760	100.000	lb/10 ⁶ SCF	N/A	0.718
DG-31	2016	7.41	300	2.245	lb/MMBTU	N/A	0.250
DG-W84/W85	2016	5.12	300	1.948	lb/10 ⁶ SCF	N/A	0.150
NGH-WW15	2016	0.25	8760	100.00	lb/10 ⁶ SCF	N/A	0.011
NGH-W97	2016	1.00	8760	0.02	lb/MMBTU	N/A	0.011
NGH-NW30	2016	3.00	8760	0.02	lb/MMBTU	N/A	0.032
NGH-N51/N52	2017	1.00	8760	0.02	lb/MMBTU	0.105	N/A
DG-12	2018	14.64	300	1.36	lb/MMBTU	2.976	N/A
DG-E53	2018	3.10	300	1.95	lb/MMBTU	0.906	N/A
DG-42-2	2019	19.18	300	1.36	lb/MMBTU	3.898	N/A
CT-42-200	2019	353 (219 + 134)	8760	N/A	lb/10 ⁶ SCF	5.275	N/A
CT-42-300	2019	353 (219 + 134)	8760	N/A	lb/10 ⁶ SCF	5.275	N/A
DG-NW14	2019	5.1	300	1.95	lb/MMBTU	1.496	N/A
DG-300bed dorm	2019	5.1	300	1.95	lb/MMBTU	1.496	N/A
2015-2019 Total NO_x Tons Added						21.428	1.254
Emission Unit	Year Removed	not applicable					NO _x emission reduction
2015-2019 Total NO_x Tons Removed						0.000	
5 YEAR NET NO_x EMISSIONS, CALENDAR YEARS 2015-2019 INCLUSIVE:							22.682
<p>(1) Any net NO_x emissions increase occurring over a period of five consecutive calendar years that equates to 25 or more tons of NO_x shall become subject to the requirements of 310 CMR 7.00: Appendix A.</p>							
<p>(3) The actual NO_x emissions equate to the average of the two most recent complete calendar years of representative actual NO_x emissions data when available. NO_x potential emissions are used if two complete calendar years of representative actual NO_x emissions data are not available.</p>							
<p>*Note that these values are based on future fuel usage estimates</p>							

Massachusetts Institute of Technology's 5 Year Rolling NO_x Emissions Increases/Decreases Summary⁽¹⁾

2016-2020

Last Updated 10/26/16

Emission Unit ⁽²⁾	Year Installed	Rated Heat Input (mmBtu/hr)	Current Allowable Operation per Rolling Twelve Month Calendar Period (Hours)	NO _x Emission Factor		NO _x PTE per Rolling Twelve Month Calendar Period (tons) ⁽³⁾	Actual NO _x Emissions per Rolling Twelve Month Calendar Period (tons) ⁽³⁾
NGH-W86	2016	16.40	8760	100	lb/10 ⁶ SCF	N/A	0.718
DG-31	2016	7.41	300	2.2	lb/MMBTU	N/A	0.250
DG-W84/W85	2016	5.12	300	1.95	lb/10 ⁶ SCF	N/A	0.150
NGH-WW15	2016	0.25	8760	100	lb/10 ⁶ SCF	N/A	0.011
NGH-W97	2016	1.00	8760	0.024	lb/MMBTU	N/A	0.011
NGH-NW30	2016	3.00	8760	0.024	lb/MMBTU	N/A	0.032
NGH-N51/N52	2017	1.00	8760	0.024	lb/MMBTU	0.105	N/A
DG-12	2018	14.64	300	1.36	lb/MMBTU	2.976	N/A
DG-E53	2018	3.10	300	1.95	lb/MMBTU	0.906	N/A
DG-42-2	2019	19.18	300	1.36	lb/MMBTU	3.898	N/A
CT-42-200	2019	353 (219 + 134)	8760	N/A	lb/10 ⁶ SCF	5.275	N/A
CT-42-300	2019	353 (219 + 134)	8760	N/A	lb/10 ⁶ SCF	5.275	N/A
DG-NW14	2019	5.12	300	1.95	lb/MMBTU	1.496	N/A
DG-300bed dorm	2019	5.12	300	1.95	lb/MMBTU	1.496	N/A
CT-42-200	2020	353 (219 + 134)	8760	N/A	lb/10 ⁶ SCF	5.275	N/A
CT-42-300	2020	353 (219 + 134)	8760	N/A	lb/10 ⁶ SCF	5.275	N/A
DG-(new 600 bed)	2020	7.5	300	1.95	lb/MMBTU	2.192	N/A
DG-26	2020	6.0	300	1.95	lb/MMBTU	1.753	N/A
DG-(site 4)-1	2020	5.0	300	1.95	lb/MMBTU	1.461	N/A
DG-(site 4)-2	2020	5.0	300	1.95	lb/MMBTU	1.461	N/A
DG-(site 4)-3	2020	5.0	300	1.95	lb/MMBTU	1.461	N/A
DG-(site 4)-4	2020	5.0	300	1.95	lb/MMBTU	1.461	N/A
DG-54	2020	5.0	300	1.95	lb/MMBTU	1.461	N/A
DG-W51	2020	3.5	300	1.95	lb/MMBTU	1.023	N/A
DG-W15	2020	3.0	300	1.95	lb/MMBTU	0.877	N/A
DG-MET	2020	2.5	300	1.95	lb/MMBTU	0.731	N/A
DG-Music	2020	2.5	300	1.95	lb/MMBTU	0.731	N/A
DG-W71	2020	2.0	300	1.95	lb/MMBTU	0.584	N/A
DG-E2	2020	1.0	300	1.95	lb/MMBTU	0.292	N/A
2016-2020 Total NO_x Tons Added						47.466	1.170
Emission Unit	Year Removed	not applicable					NO_x emission reduction
CT-42-1	2020						(42.000)
2015-2019 Total NO_x Tons Removed							(42.000)
5 YEAR NET NO_x EMISSIONS, CALENDAR YEARS 2016-2020 INCLUSIVE:							6.636
<p>(1) Any net NO_x emissions increase occurring over a period of five consecutive calendar years that equates to 25 or more tons of NO_x shall become subject to the requirements of 310 CMR 7.00: Appendix A.</p>							
<p>(3) The actual NO_x emissions equate to the average of the two most recent complete calendar years of representative actual NO_x emissions data when available. NO_x potential emissions are used if two complete calendar years of representative actual NO_x emissions data are not available.</p>							
<p>*Note that these values are based on future fuel usage estimates</p>							

Appendix C

Supporting Calculations

Table C-1: MIT turbine & duct burner model cases per turbine
Operating Scenario I - Single New Turbine and Single Old Turbine

Relevant Sample Calculations (located at end of Appendix C): C-1, C-2, C-3, C-4, & C-5

Epsilon 8/2016 with RGV input data from Solar and Deltak 02/2016

Epsilon Case No.	1	2	3	4	5	6	7	8	9	10	11	12	13	14
Ambient Temp (F)	50	0	60	0	60	0	60	0	60	0	60	0	60	0
% Load	100	100	75	75	50	50	40	40	100	100	75	75	65	65
Turbine Fuel	NG	NG	NG	NG	NG	NG	NG	NG	ULSD	ULSD	ULSD	ULSD	ULSD	ULSD
Duct Burner Fuel	NG	NG	NG	NG	OFF	OFF	OFF	OFF	NG	NG	NG	NG	OFF	OFF
Turbine Fuel Input (MMBtu/hr, LHV)	197.79	202.01	155.95	161.61	121.83	125.39	108.81	110.85	198.91	215.10	162.68	171.97	148.43	156.35
Duct Burner Fuel Input (MMBtu/hr, LHV)	112.4	120.5	106	135.2	0	0	0	0	113.9	122.3	107.3	136.6	0.0	0.0
Turbine Fuel Input (MMBtu/hr, HHV)	219.01	223.69	172.68	178.95	134.90	138.84	120.49	122.74	212.04	229.30	173.42	183.32	158.23	166.67
Duct Burner Fuel Input (MMBtu/hr, HHV)	124.46	133.43	117.37	149.71	0.00	0.00	0.00	0.00	126.12	135.42	118.81	151.26	0.00	0.00
CTG Exhaust Temp. (F)	858	761	836	697	824	684	820	681	848	748	822	687	818	679
Stack Exit Temp. (F)	180	180	180	180	180	180	180	180	225	225	225	225	225	225
CTG outlet Flow Rate (ft3/min)	307,178	308,161	263,390	267,889	224,135	225,408	209,832	210,552	310,536	321,675	271,978	279,660	253,558	259,813
Stack Flow Rate (ft3/min)	149,161	161,526	130,069	148,184	111,718	126,102	104,916	118,101	162,628	182,407	145,324	167,016	135,906	156,253
Turbines operating	1	1	1	1	1	1	1	1	1	1	1	1	1	1
Stack Emissions - Turbine Contribution														
PM	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.04 lb/MMBtu	0.04 lb/MMBtu	0.04 lb/MMBtu	0.04 lb/MMBtu	0.04 lb/MMBtu
Stack Emissions - Duct Burner Contribution														
PM	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu
Stack Emissions - Turbine Contribution														
PM (lb/hr)	4.38	4.47	3.45	3.58	2.70	2.78	2.41	2.45	8.48	9.17	6.94	7.33	6.33	6.67
Stack Emissions - Duct Burner Contribution														
PM (lb/hr)	2.49	2.67	2.35	2.99	0.00	0.00	0.00	0.00	2.52	2.71	2.38	3.03	0.00	0.00
Stack Emissions - Total														
PM (lb/hr)	6.87	7.14	5.80	6.57	2.70	2.78	2.41	2.45	11.00	11.88	9.31	10.36	6.33	6.67
Stack Characteristics														
Effective Stack Diameter (ft)	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0
Area (ft2)	38.5	38.5	38.5	38.5	38.5	38.5	38.5	38.5	38.5	38.5	38.5	38.5	38.5	38.5
Exit Velocity (ft/sec)	64.6	70.0	56.3	64.2	48.4	54.6	45.4	51.1	70.4	79.0	62.9	72.3	58.9	67.7
Exit Velocity (m/sec)	19.7	21.3	17.2	19.6	14.7	16.6	13.8	15.6	21.5	24.1	19.2	22.0	17.9	20.6

Table C-2: MIT turbine & duct burner model cases per turbine

Operating Scenario II - Both New Turbines

Relevant Sample Calculations (located at end of Appendix C): C-1, C-2, C-3, C-4, C-5, & C-6

Epsilon 8/2016 with RGV input data from Solar and Deltak 02/2016

Epsilon Case Number	2.a	2.b	2.c	2.d	2.e	2.f	2.g	2.h	2.i	2.j	2.k	2.l	2.m	2.n	
Ambient Temp (F)	50	0	60	0	60	0	60	0	60	0	60	0	60	0	
% Load	100	100	75	75	50	50	40	40	100	100	75	75	65	65	
Turbine Fuel	NG	NG	NG	NG	NG	NG	NG	NG	ULSD	ULSD	ULSD	ULSD	ULSD	ULSD	
Duct Burner Fuel	NG	NG	NG	NG	OFF	OFF	OFF	OFF	NG	NG	NG	NG	OFF	OFF	
Turbine Fuel Input (MMBtu/hr, LHV)	197.79	202.01	155.95	161.61	121.83	125.39	108.81	110.85	198.91	215.1	162.68	171.97	148.43	156.35	
Duct Burner Fuel Input (MMBtu/hr, LHV)	112.4	120.5	106	135.2	0	0	0	0	113.9	122.3	107.3	136.6	0	0	
Turbine Fuel Input (MMBtu/hr, HHV)	219.0	223.7	172.7	179.0	134.9	138.8	120.5	122.7	212.0	229.3	173.4	183.3	158.2	166.7	
Duct Burner Fuel Input (MMBtu/hr, HHV)	124.5	133.4	117.4	149.7	0.0	0.0	0.0	0.0	126.1	135.4	118.8	151.3	0.0	0.0	
Stack Exit Temp. (F)	180.0	180.0	180.0	180.0	180.0	180.0	180.0	180.0	225.0	225.0	225.0	225.0	225.0	225.0	
Stack Flow Rate (ft3/min) (both turbines)	298,321.6	323,051.7	219,591.2	228,912.3	193,872.0	201,542.0	223,436.8	252,204.8	189,949.0	209,832.0	236,202.1	269,110.2	284,584.4	325,255.6	
Turbines operating	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	
Stack Emissions - Turbine Contribution (per Turbine)															
PM	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.04 lb/MMBtu	0.04 lb/MMBtu	0.04 lb/MMBtu	0.04 lb/MMBtu	0.04 lb/MMBtu	0.04 lb/MMBtu
Stack Emissions - Duct Burner Contribution (per duct Burner)															
PM	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu	0.02 lb/MMBtu
Stack Emissions - Turbine Contribution (per Turbine)															
PM (lb/hr)	4.4	4.5	3.5	3.6	2.7	2.8	2.4	2.5	8.5	9.2	6.9	7.3	6.3	6.7	
Stack Emissions - Duct Burner Contribution (per Turbine)															
PM (lb/hr)	2.5	2.7	2.3	3.0	0.0	0.0	0.0	0.0	2.5	2.7	2.4	3.0	0.0	0.0	
Stack Emissions - Total (from both Turbines)															
PM (lb/hr)	13.74	14.28	11.60	13.15	5.40	5.55	4.82	4.91	22.01	23.76	18.63	20.72	12.66	13.33	
Stack Characteristics															
Effective Stack Diameter (ft)	9.9	9.9	9.9	9.9	9.9	9.9	9.9	9.9	9.9	9.9	9.9	9.9	9.9	9.9	
Area (ft2)	77.0	77.0	77.0	77.0	77.0	77.0	77.0	77.0	77.0	77.0	77.0	77.0	77.0	77.0	
Exit Velocity (ft/sec)	64.6	70.0	47.5	49.6	42.0	43.6	48.4	54.6	41.1	45.4	51.1	58.3	61.6	70.4	
Exit Velocity (m/sec)	19.7	21.3	14.5	15.1	12.8	13.3	14.8	16.6	12.5	13.9	15.6	17.8	18.8	21.5	

Table C-3: Annual Average MIT turbine & duct burner model cases

Relevant Sample Calculations (located at end of Appendix C): C-4, C-5, C-6, & C-7

Epsilon 8/2016

New Case Number	Op. Scen. I Annual	Op. Scen. II Annual
General Information		
Old Case Number	7A	7A
Ambient Temp (F)	60	60
% Load	75	75
Turbine Fuel	NG	NG
Duct Burner Fuel	NG	NG
HRSG EXHAUST		
Stack Exit Temp. (F)	180	180
Stack Flow Rate (ft ³ /min)	130,069	219,591
Turbines operating	1	2
Max hours operating ULSD	168	168
Stack Emissions - Total		
PM (lb/hr) ¹	6.97	13.93
Stack Characteristics		
Effective Stack Diameter (ft)	7.0	9.9
Area (ft ²)	38.5	77.0
Exit Velocity (ft/sec)	56.3	47.5
Exit Velocity (m/sec)	17.2	14.5

Notes:

[1] Based on 168 hours ULSD at 100% load with a 0°F ambient temperature and remaining hours on natural gas at 100% load with a 50°F ambient temperature

Table C-4: Short Term Emissions from Other Combustion Sources

Relevant Sample Calculations (located at end of Appendix C): C-4, C-8

Epsilon 8/2016

Emissions Unit	Boiler 3, 4, 5		Boilers 7&9		Turbine #1	Generator	Cold Start Engine
	Full Load	Minimum Load	Full Load (Boiler 7&9)	Full Load (Boiler 9 Only)	Full Load	Full Load	Full Load
Case							
Exit Temperature (F)	315	270	393	315	270	963	752.1
Exit Velocity (m/s)	5.91	0.73	17.68	8.06	35.79	61.94	24.72
Exhaust Flow (ACFM)	110,532	13,653	82,665	37,686	199,149	17,191	15,287
Stack Height (Ft)	177	177	115	115	120	63.75	96.5
Stack Diameter (ft)	11	11	5.5	5.5	6	1.34	2.00
Short-Term Emission Rate							
PM10 (lb/hr)	20.77	2.56	6.59	3.58	13.94	0.76	0.400
PM2.5 (lb/hr)	20.77	2.56	6.59	3.58	13.94	0.76	0.400

Table C-4a: Boilers 3, 4, and 5 Heat Inputs

MMBtu/hr	Full Load ¹	Minimum ²
Boiler 3	116.2	
Boiler 4	116.2	
Boiler 5	145.2	
Total	377.6	46.5

[1] Based on permitted maximum heat rating for Boilers 3, 4, and 5

[2] Based on only Boiler 3 or 4 operating at 40% load

Table C-4b: Boilers 3, 4, and 5 Emission Factors

Op Permit (Lb/MMBtu)	Boiler 3 - Oil	Boiler 4 - Oil	Boiler 5 - Oil
PM10	0.055	0.055	0.055
PM2.5	0.055	0.055	0.055

Table C-5: 2 MW Cold-Start Engine Emission Calculations & Model Inputs ¹

Relevant Sample Calculations (located at end of Appendix C): C-9, C-10, & C-11

Epsilon 8/2016

752.1	F engine outlet temperature
752.1	F stack temperature (assumed no temperature loss)

6,205	ft ³ /min wet exhaust volume at 32F
15,287	ft ³ /min wet exhaust volume at stack temperature, converted from above

24	inches stack diameter from prior design
81.10	feet/second exhaust velocity

0.4	pounds/hour PM (max across loads, nominal data)
-----	---

0.139	MMBtu/gal estimated heat content of ULSD
19.182	MMBtu/hr
166	lb CO ₂ /MMBtu emission rate for liquid fuel
3,184	lb/hr CO ₂

[1] Based on sample information for a CAT DM8263 at 100% load

Table C-6: Annual Emissions from Other Combustion Sources
Relevant Sample Calculations (located at end of Appendix C): C-8, C-9, C-11, & C-12

Epsilon 8/2016

Emissions Unit	Boiler 3, 4, 5		Boilers 7&9		Turbine #1	Generator	Cold Start Engine
	Full Load	Minimum Load	Full Load (Boiler 7&9)	Full Load (Boiler 9 Only)	Full Load	Full Load	Full Load
Exit Temperature (F)	315	270	393	315	270	963	752.1
Exit Velocity (m/s)	5.91	0.73	17.68	8.06	35.79	61.94	24.72
Exhaust Flow (ACFM)	110,532	13,653	82,665	37,686	199,149	17,191	15,287
Stack Height (Ft)	177	177	115	115	120	63.75	96.5
Stack Diameter (ft)	11	11	5.5	5.5	6	1.34	2.33
Emission Rate							
PM10 (lb/hr)	11.51	1.42	1.01	0.56	4.98	0.0260	0.014
PM2.5 (lb/hr)	11.51	1.42	1.01	0.56	4.98	0.0260	0.014
Emission Factors							
PM10 (lb/MMBtu)	See Below		0.01	0.03			
PM2.5 (lb/MMBtu)			0.01	0.03			

Table C-6a: Boilers 3, 4, and 5 Heat Inputs

MMBtu/hr	Full Load ¹	Minimum ²
Boiler 3	116.2	46.5
Boiler 4	116.2	
Boiler 5	145.2	
Total	377.6	46.5

[1] Based on permitted maximum heat rating for Boilers 3, 4, and 5

[2] Based on only Boiler 3 or 4 operating at 40% load

Table C-6b: Boilers 3, 4, and 5 Emission Factors

Op Permit (Lb/MMBtu)	Boiler 3 - Gas	Boiler 4 - Gas	Boiler 5 - Gas
PM10	0.03	0.03	0.03
PM2.5	0.03	0.03	0.03

Table C-6c: Boiler Emission Rate Calculations

	B7 - gas	B9 - gas	B7 & 9 - gas	Boiler 3,4,5 NG	Boiler 3,4,5 ULSD+NG	Boiler 3,4,5 NG	Boiler 3,4,5 ULSD+NG
MMBtu/hr	99.70	125.80	225.50	MAX LOAD		MIN LOAD	
Hours Max	3,600	3,600					
PM10 lb/MMBtu	0.0100	0.0100					
PM2.5 lb/MMBtu	0.0100	0.0100					
PM10 lb/hr	0.41	0.52	0.93	11.328	11.509	1.394	1.417
PM2.5 lb/hr	0.41	0.52	0.93	11.328	11.509	1.394	1.417

Table C-6d: Boiler and Turbine Emission Rate Calculations

	B7 NG+ULSD	B9 NG+ULSD	B7 & 9 NG+ULSD	Turbine 1 - NG	Turbine 1 - NG + ULSD
MMBtu/hr	99.70	125.80	225.50	293.70	293.70
Hours Max	3,600	3,600		8,760	8,760
Hours ULSD	168	168		168	168
PM10 lb/hr	0.45	0.56	1.01	4.80	4.98
PM2.5 lb/hr	0.45	0.56	1.01	4.80	4.98

Table C-7: MIT PSD Increment Calculations

Epsilon 8/2016

INCREMENT EXPANDING																			
Source	Max 24-hr Fuel Use (Gallons)	Date	Max 24-hr Gas Use (SCF)	Date	MMBtu/hr	lb/MMBtu (Gas)	lb/MMBtu (Oil)	Short-Term Gas	Short-term Oil	Short-Term PM25 Lb/hr	2013 NG Usage	2014 NG Gas Usage	2013 FO Usage	2014 FO Fuel Usage	Avg NG Use	Avg. FO Use	Total MMBtu NG	Total MMBtu Oil	Annual PM25 Lb/hr
Boiler 3	13,213.65	12/31/2013	1,754,043	12/8/2014	116.2	0.0076	0.055	0.555	4.300	4.3	1.31E+08	9.81E+07	831,357	512,566	1.15E+08	6.72E+05	1.15E+05	9.54E+04	0.7
Boiler 4	19,948.17	2/6/2015	1,742,543	12/25/2013	116.2	0.0076	0.055	0.552	6.491	6.5	1.46E+08	9.23E+07	751,592	816,364	1.19E+08	7.84E+05	1.19E+05	1.11E+05	0.8
Boiler 5	17,284.04	2/6/2015	1,894,732	12/8/2014	145.2	0.0076	0.055	0.600	5.625	5.6	1.09E+08	1.25E+08	687,890	1,279,725	1.17E+08	9.84E+05	1.17E+05	1.40E+05	1.0
Existing CT	43,976.00	1/24/2014	6,192,320	12/13/2013	229.0	0.007	0.040	1.806	10.114	10.1	1.55E+09	1.63E+09	783,368	600,400	1.59E+09	6.92E+05	1.59E+06	9.82E+04	1.7
Existing DB	-	-	1,190,100	4/2/2013	64.7	0.005	0.055	0.248	-	0.2	2.52E+08	2.34E+08	-	-	2.43E+08	-	2.43E+05	-	0.14
Boiler 7	9,162.62	2/24/2015	1,202,035	2/16/2015	99.7	0.010	0.030	0.501	1.581	1.6	7.70E+05	1.20E+07	342.6	21759.0	6.39E+06	1.11E+04	6.39E+03	1.57E+03	0.013
Boiler 9	10,209.70	2/24/2015	1,580,329	3/23/2015	100.0	0.010	0.030	0.658	1.761	1.8	6.84E+06	1.74E+07	4765.20	53813.50	1.21E+07	2.93E+04	1.21E+04	4.16E+03	0.028
Cooling Tower 1 per cell (2)										0.026									0.026
Cooling Tower 2 per cell (2)										0.026									0.026
Cooling Tower 3 per cell (2)										0.047									0.047
Cooling Tower 4 per cell (2)										0.041									0.041
Cooling Tower 5										0.017									0.017
Cooling Tower 6										0.017									0.017

Table C-8: MIT PSD Increment Calculations

Epsilon 8/2016

Source	Hrs/Yr Gas	Hrs/Yr Oil	NG Limit (lb/MMBtu)	Oil Limit (lb/MMBtu)	MMBtu/hr Gas	MMBtu/hr Oil	Short Term (lb/hr)	Annual (lb/hr)
Boiler 3		168	0.0076	0.055	116.2	116.2	0.56	0.30
Boiler 4		168	0.0076	0.055	116.2	116.2	0.55	0.32
Boiler 5		168	0.0076	0.055	145.2	145.2	0.60	0.38
Boiler 7	3432	168	0.01	0.03	99.7	99.7	0.50	0.4
Boiler 9	3432	168	0.01	0.03	125.8	119.2	0.66	0.6
CT1	8592	168	0.02	0.04	Based on the Results of the Load Analysis			
CT2	8592	168	0.02	0.04				
DB1	8760	0	0.02					
DB2	8760	0	0.02					
New Engine							0.400	0.014
Cooling Tower 11 per cell							0.035	0.035
Cooling Tower 12 per cell							0.035	0.035
Cooling Tower 13 per cell							0.035	0.035

Table C-9: MIT CHP Evaluation - Emissions Estimates for CO2

Relevant Sample Calculations (located at end of Appendix C): C-1

Epsilon 8/2016

	Nat. Gas	ULSD
CT Heat Input (MMBtu/hr LHV)	197.8	198.9
HHV/LHV conversion	1.109	1.066
CT Heat Input (MMBtu/hr HHV)	219	212
Duct Burner Heat Input (MMBtu/hr LHV)	121	121
Duct Burner Heat Input (MMBtu/hr HHV)	134	134
EPA F-Factor for natural gas, dscf/MMBtu	8,710	9,190

<u>Turbine Emissions</u>			
CO2e, lb/MMBtu	119	166	Consistency with recent applications
CO2e, lb/hr	26,103	35,198	

<u>Duct Burner Emissions</u>			
CO2e, lb/MMBtu	119		Consistency with recent applications
CO2e, lb/hr	15,968		

Table C-10: Potential to Emit Calculations (Tons per year)

Relevant Sample Calculations (located at end of Appendix C): C-1, C-2, C-3, C-10, C-13, & C-14

Epsilon 11/2016

Cold Start Engine		
300	hours/year	
	Engine Emissions (lb/hr)	Ton/year
CO	2.2	0.33
NOx	35.09	5.3
PM10/PM2.5	0.4	0.06
SO2	0.029	0.004
VOC	1.13	0.17
CO2e	3,184	480

Turbines				
219.00	MMBtu/hr HHV firing gas (from 50°F Case)			
212.00	MMBtu/hr HHV firing ULSD (from 60°F Case)			
124.98	MMBtu/hr HHV duct burner firing gas			
2	turbines			
8,760	hours/year Maximum			
168	hours/year ULSD			
4,380	hours/year duct burner (full load equivalent - estimate for calculating annual proposed emission limits)			
	Turbine lb/MMBtu gas (per turbine)	Turbine lb/MMBtu ULSD (per turbine)	DB lb/MMBtu (per unit)	Ton/year
CO	0.0045	0.017	0.011	15.1
NOx	0.0074	0.035	0.011	21.1
PM10/PM2.5	0.02	0.040	0.020	50.0
SO2	0.0029	0.0016	0.0029	7.0
VOC	0.0022	0.0095	0.03	20.9
CO2e	119	166	119	294,970
NH3	0.0027	0.0029	0.0027	6.7

Project Potential Emissions, tons/year			
	Turbines	Cold Start Engine	Total
CO	15.1	0.33	15.4
NOx	21.1	5.3	26.4
PM10/PM2.5	50.0	0.06	50.1
SO2	7.0	0.004	7.0
H2SO4 ¹	5.4	N/A	5.4
VOC	20.9	0.17	21.0
CO2e	294,970	480	295,450
NH3	6.7	0	6.7

1 Sulfuric acid mist emissions are a function of sulfur in the natural gas and ULSD, and oxidation in the catalysts, neither of which can be controlled by MIT. Again, limits for a project of this type would typically never be considered beyond documenting that the PSD modification threshold (7 ton/year) is not exceeded. For purposes of this calculation, potential SO2 emissions (7.0 tons/year for the project) and a conservative assumption of 50% conversion of sulfur dioxide to sulfuric acid mist yields potential emissions of 5.4 tons per year (7.0 tons X 50% conversion X 98/64 (molecular weight ratio of H2SO4 to SO2)). This calculation double-counts the sulfur in the system (assuming it is all emitted as SO2, and also assuming half of it is emitted as H2SO4)

Table C-11: Cold Start Engine Diesel Particulate Filter Unit BACT Cost Analysis

Engine Rating (kW)	2000
PM Emission Flow Rate (lb/hr)	0.4
PM Emission Flow Rate (tpy)	0.06

Fixed Costs		
Description	Cost	Comment
Primary Control Device & Auxiliary Equipment 450 kW EDR	\$ 44,000.00	Quote from Rypos for 450 kW Emergency Diesel Generator from Exelon West Medway Application No.: CE-15-016
Equipment Cost Scaling Factor	2.45	Scaling Factor from Equation in Plant Design and Economics for Chemical Engineers, 3rd ed., p. 166. based on engine capacity
Primary Control Device & Auxiliary Equipment 2MW Cold-Start Engine	\$ 107,682.01	product of scaling factor and Rypos Quote for 450 kW Emergency Diesel Generator
Instrumentation/Controls		included in primary control device estimate
Construction	\$ 16,959.92	15% factor on TEC
Installation	\$ 33,919.83	30% factor on TEC (includes foundation, erection and handling, electrical, piping, insulation, and painting)
Sales Tax	\$ 5,384.10	5% factor on TEC (includes freight as well)
Freight Charges		included in tax
Testing and startup	\$ 3,391.98	3% factor on TEC
Supervision	\$ 11,306.61	10% factor on TEC
Total Equipment Cost (TEC)	\$ 113,066.11	sum of Primary control device and auxiliary equipment cost, instrumentation, taxes, and freight
Total Capital Investment (TCI)	\$ 178,644.46	

Annual Cost Factors		
Description	Value	Comment
Operating Factor (hr/yr)	300	based on emergency unit operations
Operating labor rate (\$/hr):	\$ 25.60	
Operating labor factor (hr/sh):	0.25	
Annual interest rate (fraction): [i]	0.1	based on MassDEP Guidance on AQ BACT form
Control system life (years): [n]	10	based on MassDEP Guidance on AQ BACT form
Capital recovery factor:	0.1627	$(i*(1+i)^n) / ((1+i)^n - 1)$
Taxes, insurance, admin. factor:	0.04	per Table 2.10 of EPA Air Pollution Control Cost Manual (http://www.epa.gov/ttn/catc1/dir1/c_allchs.pdf)
Pressure drop (in. w.c.):		
Electricity cost (\$/kWh)		

Annual Costs		
Description	Value	Comment
Operating labor	\$ 240.00	300 hr/yr divided by 8 hr/shift times 0.25 hours per shift times 25.60 \$/hr
maintenance labor	\$ 240.00	300 hr/yr divided by 8 hr/shift times 0.25 hours per shift times 25.60 \$/hr
Subtotal raw labor	\$ 480.00	
Labor overhead	\$ 288.00	60% of operating and maintenance labor
Labor with overhead	\$ 768.00	
Maintenance materials	\$ 240.00	same as operating and maintenance labor
Property Taxes	\$ 1,786.44	1% of TCI per Table 2.10 of EPA Air Pollution Control Cost Manual
Insurance	\$ 1,786.44	1% of TCI per Table 2.10 of EPA Air Pollution Control Cost Manual
Fees	\$ 3,572.89	2% of TCI per Table 2.10 of EPA Air Pollution Control Cost Manual
Total Annual Operating Costs	\$ 8,153.78	
Electricity (kWh)		assume 0 to be conservative
Total Annual Energy Costs	\$ -	kWh * \$/kWh
Total Annual Cost	\$ 8,153.78	
Capital Recovery	\$ 29,073.56	capital recovery factor times TCI

Removal Cost Effectiveness		
Cost for Cost Effectiveness	\$ 37,227.34	capital recovery plus total annual cost
Uncontrolled Emissions (tpy)	0.0600	PM Flow
Removal %	85%	
Removed Emissions (tpy)	0.051	Removal % times uncontrolled emissions
Cost Effectiveness (\$/ton removed)	\$ 729,947.87	

Table C-12: CTG ULSD Usage

Epsilon 9/2016

212	average MMBtu/hr per turbine on ULSD
0.14	MMBtu/gal for ULSD
1,600.00	gal/hr ULSD usage of turbine (rounded up to 2 significant figures)
168	hr per 12 mo rolling period
268,800	gal per 12 mo rolling per turbine period
2	turbines
537,600	gal per 12 mo rolling total

Table C-13: MIT-CUP Emission Caps Recordkeeping Past Actual

Epsilon 9/2016

Unit	Beginning & Ending Dates		Fuel Data, annual average		Heat Input, annual average		Emissions (tpy)
			Natural Gas (10 ⁶ cf)	#6 Fuel Oil (gal)	Natural Gas (MMBtu)	#6 Fuel Oil (MMBtu)	PM
Boiler 3	1/1/2013	12/1/2014	114.8	671,962	114,777	100,794	3.21
Boiler 4	1/1/2013	12/1/2014	119.3	783,978	119,335	117,597	3.69
Boiler 5	1/1/2013	12/1/2014	117.2	983,808	117,224	147,571	4.51
Total	1/1/2013	12/1/2014	351.3	2,439,747	351,335	365,962	11.4

Table C-13a: MIT-CUP Projected Actual

Unit	Heat Input (MMBtu/hr)	Hours of ULSD firing	Fuel Data for Boilers 3,4,5, annual average		Heat Input for Boilers 3,4,5, annual average		Boilers (tpy)
			Natural Gas (10 ⁶ cf)	Fuel Oil (gal)	Natural Gas (MMBtu)	Fuel Oil (MMBtu)	PM
Boiler 3	116.2	48	210	39,840	209,993.42	5,578	1.0
Boiler 4	116.2	48	231	39,840	231,353.91	5,578	1.0
Boiler 5	145.2	48	258	49,783	257,825.16	6,970	1.2
Total	377.6	48	699	129,463	699,172.49	18,125	3.2

Table C-13b: Emission Factors Used In Emission Caps Calculations (from Permits/AP-42/Proposed)

Pollutant	Boilers 3, 4 and 5			
	Natural Gas		#6 Fuel Oil	
	Emission Factor	Units	Emission Factor	Units
PM	7.6	lb/10 ⁶ cf	7.82	lb/1000 gal
	0.0076	lb/MMBtu	0.055	lb/MMBtu

Table C-13c: Boiler 3,4,& 5 Fuel Usage

	2013 Natural Gas (MMSCF)	2013 Fuel Oil (gal)	2014 Natural Gas (MMSCF)	2014 Fuel Oil (gal)
Boiler 3	131.46	831,357	98.09	512,566
Boiler 4	146.34	751,592	92.33	816,364
Boiler 5	109.30	687,890	125.15	1,279,725
Total	387.10	2,270,839	315.57	2,608,655

Table C-14: MIT - GE LM2500 vs Solar Titan 250 GHG Emissions Analysis

Epsilon 11/2016

CTG Model	Total Generated Electric	Current Marginal Emission Factor for the ISO -NE Grid	GHG displaced from Grid Electricity
	<i>MWh/yr</i>	<i>lb/MWh</i>	<i>tons/yr</i>
Solar Titan 250	273,964	941	128,900
GE LM2500	234,421	941	110,295

CTG Model	Steam Generated by CTG & HRSG	CHP Fuel Specific Emission Factor	Average Thermal Efficiency of Facility Conventional Thermal Systems	GHG Displaced From Conventional Useful Heat System
	<i>MMBtu/yr</i>	<i>lb/MMBtu</i>	%	<i>tons/yr</i>
Solar Titan 250	1,446,663	117	80%	105,787
GE LM2500	1,463,185	117	80%	106,995

CTG Model	Total CTG Gas Usage	Total HRSG Gas Usage	CHP Fuel Specific Emission Factor	Site (CHP) Gross GHG Emissions
	<i>MMBtu/yr</i>	<i>MMBtu/yr</i>	<i>lb/MMBtu</i>	<i>tons/yr</i>
Solar Titan 250	2,537,725	324,375	117	167,433
GE LM2500	2,353,174	337,896	117	157,428

CTG Model	GHG displaced from Grid Electricity	GHG Displaced From Conventional Useful Heat System	Total GHG Displaced	Site (CHP) Gross GHG Emissions	Net GHG Reduction	
	<i>tons/yr</i>	<i>tons/yr</i>	<i>tons/yr</i>	<i>tons/yr</i>	<i>tons/yr</i>	%
Solar Titan 250	128,900	105,787	234,687	167,433	67,254	29%
GE LM2500	110,295	106,995	217,290	157,428	59,863	28%

[1] All MMBtu/yr and MWh/yr values based on Projected 2023 MIT loads as modeled

[2] The 117 lb/MMBtu factor is used instead of the actual 119 lb/MMBtu factor for consistency with the MEPA GHG analysis

Table C-15: MIT - Cooling Tower PM Emission Rate for PSD Applicability

Epsilon 12/2016

Unit	Drift Eliminator	Non-Chromium Inhibitor	Recirculation Rate	TDS Concentration	Drift Flowrate	Drift Rate	Solids in Drift	Max Operating Time	Annual Potential Emissions
			gallons/minute	PPM	%	gallons/minute	lb/hr	hr/yr	tons/yr
Cooling Tower 11	Yes	Yes	13,500	2,064	0.0005%	0.0675	0.0698	8,760	0.306
Cooling Tower 12	Yes	Yes	13,500	2,064	0.0005%	0.0675	0.0698	8,760	0.306
Cooling Tower 13	Yes	Yes	13,500	2,064	0.0005%	0.0675	0.0698	8,760	0.306
Total	–	–	–	–	–	–	–	–	0.92

NOTE: As an unrelated project, MIT has recently installed three new cooling towers (towers 11, 12, and 13). The cooling tower replacements do not rely on the proposed project and vice-versa; the replacement cooling towers are not required for the proposed project to operate, and the proposed project does not need to be constructed for MIT to gain full use of the replacement cooling towers. Replacement of the cooling towers did not trigger Massachusetts plan approval thresholds (potential emissions less than one ton per year). The projects were funded and constructed separately. Based on a pre-application meeting with MassDEP on July 29, 2014, the changes to the cooling towers are addressed in the air quality dispersion modeling analysis for this project. These calculations provide the basis for the model inputs, and provide for conservative inclusion in the PSD applicability review.

Emissions are calculated consistent with EPA AP-42 Section 13.4.2, which states "a *conservatively high* PM-10 emission factor can be obtained by (a) multiplying the total liquid drift factor by the total dissolved solids (TDS) fraction in the circulating water and (b) assuming that, once the water evaporates, all remaining solid particles are within the PM-10 size range." (emphasis in original)

Sample Calculations

Sample Calculation C-1: ppm to lb/hr from the turbine using CO from Epsilon Case 1

Value	Name	Units	Notes
2.00	Starting ppmdv @ 15% O ₂	ppmdv @ 15% O ₂	Starting point
20.90	Percent Oxygen in atmospheric air	%	Standard value
15.00	Percent Oxygen basis for ppmdv	%	Given
8,710	F _d Factor for natural gas	dscf/MMBTU	From EPA Method 19 Table 19-1 (40 CFR 60)
1.194E-07	Conversion factor (lb/scf per 1 ppm for NO ₂ reference)	(lb/dscf)/ppm	From EPA Method 20 (40 CFR 60)
28.00	Molecular Weight (MW) of CO	lb/lbmol	Standard value
46.00	Molecular Weight (MW) of NO ₂ (reference compound)	lb/lbmol	Standard value
219.00	Heat input of turbine (natural gas)	MMBTU/hr	Design value of turbine for this operating case
1.04E-03	Conversion factor (lb/MMBTU per 1 ppm) for NO _x	(lb/MMBTU)/ppm	Multiply conversion factor (lb/scf per 1 ppm) by F _d factor
6.33E-04	Conversion factor (lb/MMBTU per 1 ppm) for CO	(lb/MMBTU)/ppm	Multiply conversion factor (lb/MMBTU per 1 ppm) for NO ₂ by ratio of MW
0.0013	lb/MMBTU at 15% O ₂	lb/MMBTU	Multiply ppmdv @ 15% O ₂ by conversion factor (lb/MMBTU per 1 ppm) for CO
3.54	Correction factor for 15% O ₂ to atmospheric 20.9% O ₂	--	20.9% / (20.9%-15%) correction factor from EPA Method 20 EQ 20-6 (40 CFR 60)
0.0045	lb/MMBTU CO	lb/MMBTU	Multiply correction factor for 15% O ₂ by lb/MMBTU at 15% O ₂
0.98	CO emissions from a single CTG	lb/hr	Multiply the lb/MMBTU CO by the heat input of turbine (natural gas) value
General Formula Top To Bottom: $2.00 \text{ ppmvd @ } 15\% \text{ O}_2 \cdot \left(\left(8,710 \frac{\text{dscf}}{\text{MMBTU}} \right) \cdot \left(1.194 \cdot 10^{-7} \frac{\text{lb}}{\text{ppm}} \right) \right) \cdot \frac{20.9\% \text{ O}_2 \text{ air}}{20.9\% \text{ O}_2 \text{ air} - 15\% \text{ O}_2 \text{ reference}} \cdot \frac{28 \frac{\text{lb CO}}{\text{lbmol CO}}}{46 \frac{\text{lb NO}_2}{\text{lbmol NO}_2}} \cdot 219 \frac{\text{MMBTU}}{\text{hr}} = 0.98 \frac{\text{lb}}{\text{hr}}$			

Sample Calculation C-2: Grains per 100 standard cubic foot (SCF) of Sulfur to lb/hr SO2 from Epsilon Case 1

Value	Name	Units	Notes
219.00	Heat Input of turbine (natural gas)	MMBTU/hr	Design value of turbine for this operating case
1.00	Sulfur content of fuel	gr/100scf	Design value of turbine for this operating case
0.01	Sulfur content of fuel	gr/scf	Divide grains of Sulfur per 100 SCF of natural gas by 100 SCF
7,000.00	Conversion factor (grains to pounds)	gr/lb	Standard conversion value
0.001	Conversion factor (SCF to BTU NG)	SCF/BTU	Standard conversion value
1,000,000	Conversion factor (BTU to MMBTU)	BTU/MMBTU	Standard conversion value
64.00	Molecular Weight of Sulfur Dioxide (SO ₂)	lb/lbmol	Standard value
32.00	Molecular Weight of atomic Sulfur	lb/lbmol	Standard value
2.00	Ratio of molecular weight of SO ₂ to Sulfur	--	Divide MW of Sulfur Dioxide by MW of Sulfur
1.43E-06	Sulfur content of fuel	lb/SCF	Divide sulfur content of fuel (gr/scf) by conversion factor (grains to pounds)
1,000.00	Conversion factor (SCF to MMBTU)	SCF/MMBTU	Multiply conversion factor (SCF to BTU NG) by conversion factor (BTU to MMBTU)
0.0014	Emission factor of Atomic Sulfur	lb/MMBTU	Multiply conversion factor (SCF to MMBTU) by Sulfur content of fuel (lb/SCF)
0.0029	Emission factor of Sulfur Dioxide	lb/MMBTU	Multiply emission factor of atomic Sulfur by ratio of molecular weight of SO ₂ to S
6.26E-01	SO₂ emissions from a single CTG	lb/hr	Multiply the lb/MMBTU SO₂ by the heat input of turbine (natural gas) value
General Formula Top To Bottom: $\frac{1 \text{ grain}}{100 \text{ scf}} \cdot \frac{1 \text{ lb}}{7,000 \text{ grains}} \cdot \frac{1 \text{ SCF Natural Gas}}{1,000 \text{ BTU}} \cdot \frac{1,000,000 \text{ BTU}}{1 \text{ MMBTU}} \cdot \frac{64 \frac{\text{lb}}{\text{lbmol}} \text{ SO}_2}{32 \frac{\text{lb}}{\text{lbmol}} \text{ S}} \cdot 219 \frac{\text{MMBTU}}{\text{hr}} = 0.626 \frac{\text{lb}}{\text{hr}} \text{ SO}_2$			

Sample Calculations

Sample Calculation C-3: lb/MMBTU to lb/hr for Particulate Matter from Epsilon Case 1

Value	Name	Units	Notes
0.02	Emission factor for Particulate Matter (PM)	lb/MMBTU	Design value of turbine for this operating case
219.00	Heat input of turbine (natural gas)	MMBTU/hr	Design value of turbine for this operating case
4.38	PM emissions from a single CTG	lb/hr	Multiply the lb/MMBTU PM by the heat input of turbine (natural gas) value

General Formula Top To Bottom: $0.02 \frac{lb}{MMBTU} * 219 \frac{MMBTU}{hr} = 4.38 \frac{lb}{hr} PM$

Sample Calculation C-4: Stack Area Calculation from Epsilon Case 1

Value	Name	Units	Notes
7.00	Stack diameter	feet	Design value
3.14	Pi (π)	--	Standard value
3.50	Stack radius	feet	Diameter of stack divided by 2
38.48	Area of Stack Exit	ft²	Pi multiplied by the square of the stack radius

General Formula Top To Bottom: $\pi * \left(\frac{7 ft}{2}\right)^2 = 38.5 ft^2$

Sample Calculation C-5: Stack Exit Velocity from Epsilon Case 1

Value	Name	Units	Notes
149,161	Stack volumetric exhaust flow	ft ³ /min	Design value based on outlet flow from combustion units and temperature of stack exhaust
38.48	Area of stack exit	ft ²	From Sample Calculation C-4
60.00	Conversion factor (minutes to seconds)	seconds/minute	Standard conversion factor
3,875.87	Stack exit velocity	ft/min	Stack volumetric exhaust flow divided by area of stack exit
64.60	Stack exit velocity	ft/sec	Stack exit velocity (ft/min) divided by conversion factor (minutes to seconds)
3.28	Conversion factor (feet to meters)	ft/m	Standard conversion factor
19.7	Stack exit velocity (metric)	m/sec	Stack exit velocity (ft/s) divided by conversion factor (feet to meters)

General Formula Top To Bottom: $149.161 \frac{ft^3}{minute} * \frac{1}{38.48 ft^2} * \frac{1 minute}{60 seconds} * \frac{1 meter}{3.28 feet} = 19.7 \frac{meters}{second}$

Sample Calculation C-6: Effective Stack Diameter Calculation from Operating Scenario II

Value	Name	Units	Notes
7.00	Diameter of single unit stack	feet	Design value
2.00	Number of unit stacks	--	Design value
3.14	Pi (π)	--	Standard value
3.50	Radius of a single unit stack	feet	Diameter of single unit stack divided by 2
38.48	Area of single stack	ft ²	Calculation shown in Sample Calculation C-4
77.0	Effective stack area	ft ²	Area of a single stack multiplied by number of unit stacks
4.95	Effective stack radius	feet	Divide effective stack area by Pi and then take the square root of that value
9.9	Effective stack diameter	feet	Multiply the effective stack radius by 2

General Formula Top To Bottom: $2 * \sqrt{\frac{\left(\left(\frac{7 ft}{2}\right)^2 * \pi\right) * 2}{\pi}} = 9.9 ft \text{ effective diameter}$

Sample Calculations

Sample Calculation C-7: Annual Average lb/hr PM from Table C-3

Value	Name	Units	Notes
8,760	Total hours in a year	hr/yr	Standard value
168	Hours of ULSD firing	hr/yr	Project design value
8,592	Hours of natural gas firing	hr/yr	Obtained by subtracting hours of ULSD firing from 8,760 hours per year
11.88	ULSD emission rate of PM (from Epsilon Case 10)	lb/hr	Based on 100% load firing ULSD with a 0 °F ambient temperature
6.87	Natural gas emission rate of PM (from Epsilon Case 1)	lb/hr	Based on 100% load firing natural gas with a 50 °F ambient temperature
0.019	Fraction of hours firing USLD	--	Obtained by dividing hours of ULSD firing by total hours in a year
0.981	Fraction of hours firing natural gas	--	Obtained by dividing hours of natural gas firing by total hours in a year
0.23	Weighted contribution of ULSD firing to annual average	lb/hr	Obtained by multiplying the ULSD lb/hr emission rate by the fraction of hours firing ULSD
6.74	Weighted contribution of NG firing to annual average	lb/hr	Obtained by multiplying the NG lb/hr emission rate by the fraction of hours firing NG
6.97	Annual average PM emissions from single unit	lb/hr	Obtained by adding the weighted emission contributions of USLD and NG firing

General Formula Top To Bottom:
$$\frac{11.88 \frac{lb}{hr} * 168 \frac{hours\ of\ ULSD\ firing}{year}}{8,760\ hours\ per\ year} + \frac{6.87 \frac{lb}{hr} * ((8,760 - 168) \frac{hours\ of\ NG\ firing}{year})}{8,760\ hours\ per\ year} = 6.97 \frac{lb}{hr} PM$$

Sample Calculation C-8: Boiler Exhaust Flow for Boiler 3, 4, and 5 Firing Full Load from Table C-4

Value	Name	Units	Notes
5.91	Exit velocity	m/s	Known value
11	Stack diameter	ft	Known value
3.14	Pi (π)	--	Standard value
3.28	Conversion factor (feet to meters)	ft/m	Standard conversion factor
60.00	Conversion factor (minutes to seconds)	seconds/minute	Standard conversion factor
5.50	Stack radius	ft	Stack diameter divided by 2
95.0	Stack area	ft ²	Pi multiplied by the square of the radius
1,163.09	Stack velocity	ft/min	Exit velocity multiplied by the conversion factors for meters to feet and seconds to minutes
110,532	Exhaust flow	ACFM	Multiply the stack velocity by stack area to obtain volumetric flow

General Formula Top To Bottom:
$$5.91 \frac{m}{s} * 3.28 \frac{ft}{m} * 60 \frac{seconds}{minute} * \left(\pi * \left(\frac{11\ ft}{2} \right)^2 \right) = 110,532\ ACFM$$

Sample Calculation C-9: Converted Exhaust Volume from Cold-Start Engine

Value	Name	Units	Notes
6,205	Exhaust parameter	ft ³ /min	Spec. sheet - wet exhaust volume at 32F
32	Reference temperature of exhaust parameter	°F	Reference value
752.1	Exhaust temperature	°F	Stack temperature
492.0	Spec sheet value absolute temperature	°R	Spec sheet value temperature converted to Rankine (add 460)
1,212.1	Exhaust absolute temperature	°R	Stack temperature converted to Rankine (add 460)
2.46	Absolute temperature ratio (exhaust/spec sheet)	--	Exhaust absolute temperature divided by spec sheet value absolute temperature
15,287	Wet stack exhaust volume	ft³/min	Multiply exhaust parameter by temperature ratio

General Formula Top To Bottom:
$$6,205 \frac{ft^3}{minute} * \frac{(32 + 460)^\circ R}{(752.1 + 460)^\circ R} = 15,287 \frac{ft^3}{minute}$$

Sample Calculations

Sample Calculation C-10: ULSD Sulfur Content to lb/hr SO₂ (cold start engine)

Value	Name	Units	Notes
138	Volumetric fuel usage of engine	gal/hr	Design value
7	Density of ULSD (estimated)	lb/gal	Standard value
0.0015%	Sulfur content of ULSD	wt%	Standard value
64.0	Molecular Weight (MW) of Sulfur Dioxide (SO ₂)	lb/lbmol	Standard value
32.0	Molecular Weight (MW) of atomic Sulfur	lb/lbmol	Standard value
966.0	Mass fuel usage of engine	lb/hr	Multiply volumetric fuel usage of engine by density of ULSD
2.0	Ratio of SO ₂ to Sulfur	lb SO ₂ /lb S	Divide MW of Sulfur Dioxide by MW of Sulfur
0.014	Mass flow of Sulfur	lb S/hr	Multiply % sulfur in fuel by mass fuel usage of engine
0.029	Mass flow of Sulfur Dioxide in exhaust	lb/hr SO₂	Multiply mass flow of Sulfur by ratio of SO₂ to Sulfur (assumes 100% conversion)
General Formula Top To Bottom: $138 \frac{\text{gal ULSD}}{\text{hr}} * 7 \frac{\text{lb ULSD}}{\text{gal ULSD}} * 0.000015 \frac{\text{lb S}}{\text{lb ULSD}} * \frac{64 \text{ lb SO}_2}{32 \text{ lb S}} = 0.029 \frac{\text{lb}}{\text{hr}} \text{SO}_2$			

Sample Calculation C-11: Annual Exhaust Emissions from Cold Start Engine (using CO as example)

Value	Name	Units	Notes
2.2	Nominal short term emissions from engine	lb/hr	Nominal data
300	Hours of engine operation	hr/yr	Design limit / regulatory limit
8,760	Hours per calendar year	hr/yr	Standard value
0.0342	Operational ratio	--	Hours of engine operation divided by total hours per calendar year
0.075	Annual exhaust emissions from engine	lb/hr	Operational ratio of engine multiplied by short term emissions from engine
General Formula Top To Bottom: $2.2 \frac{\text{lb CO}}{\text{hr}} * \frac{300 \text{ hours of engine operation per year}}{8,760 \text{ hours per calendar year}} = 0.075 \frac{\text{lb}}{\text{hr}} \text{CO annual}$			

Sample Calculations

Sample Calculation C-12: Annual Exhaust Emissions from Boilers 7 & 9 (using NOx as example)

Value	Name	Units	Notes
99.7	Heat input of Boiler 7 on natural gas	MMBTU/hr	Design value
125.8	Heat input of Boiler 9 on natural gas	MMBTU/hr	Design value
0.011	NOx emission factor for Boiler 7 firing natural gas	lb/MMBTU	Design value
0.011	NOx emission factor for Boiler 9 firing natural gas	lb/MMBTU	Design value
3,600	Total Hours of operation	hr/yr	Permit value
168	Hours of operation on ULSD	hr/yr	Permit value
3,432	Hours of operation on natural gas	hr/yr	Subtract hours of operation ULSD from total hours of operation
8,760	Conversion factor from hours to year	hr/yr	Standard conversion factor
1.10	Short term hourly emissions of NOx from Boiler 7 firing natural gas	lb/hr	Multiply heat input for Boiler 7 by NOx emission factor for Boiler 7 firing natural gas
1.38	Short term hourly emissions of NOx from Boiler 9 firing natural gas	lb/hr	Multiply heat input for Boiler 9 by NOx emission factor for Boiler 9 firing natural gas
4.67	Short term hourly emissions of NOx from Boiler 7 firing ULSD	lb/hr	From short term limitations page of excel (Table C-4)
11.92	Short term hourly emissions of NOx from Boiler 9 firing ULSD	lb/hr	From short term limitations page of excel (Table C-4) (subtract Boiler 9 value from Boiler 7&9 value)
3,763.9	Annual emissions of NOx from Boiler 7 firing natural gas	lb/yr	Multiply short term hourly NOx emissions from Boiler 7 on natural gas by hours of operation on natural gas
4,749.2	Annual emissions of NOx from Boiler 9 firing natural gas	lb/yr	Multiply short term hourly NOx emissions from Boiler 9 on natural gas by hours of operation on natural gas
784.6	Annual emissions of NOx from Boiler 7 firing ULSD	lb/yr	Multiply short term hourly NOx emissions from Boiler 7 on ULSD by hours of operation on ULSD
2,002.6	Annual emissions of NOx from Boiler 9 firing ULSD	lb/yr	Multiply short term hourly NOx emissions from Boiler 9 on ULSD by hours of operation on ULSD
4,548.4	Annual NOx emissions from Boiler 7	lb/yr	Add annual NOx emissions from natural gas firing and annual NOx emissions from ULSD firing for Boiler 7
6,751.8	Annual NOx emissions from Boiler 9	lb/yr	Add annual NOx emissions from natural gas firing and annual NOx emissions from ULSD firing for Boiler 9
0.52	Annual average hourly NOx emissions from Boiler 7	lb/hr	Divide annual NOx emissions from Boiler 7 by total hours per year (8,760)
0.77	Annual average hourly NOx emissions from Boiler 9	lb/hr	Divide annual NOx emissions from Boiler 9 by total hours per year (8,760)
1.29	Total annual average hourly NOx emissions from Boilers 7 & 9	lb/hr	Add annual average hourly NOx emissions from Boiler 7 and Boiler 9

General Formula Top To Bottom:
$$\frac{\left(\left(99.7 \frac{\text{MMBTU}}{\text{hr}} \right) * \left(0.011 \frac{\text{lb}}{\text{MMBTU}} \right) * \frac{(3,600 - 168) \text{hr}}{\text{yr}} \right) + \left(\left(4.67 \frac{\text{lb}}{\text{hr}} \right) * 168 \frac{\text{hr}}{\text{yr}} \right)}{8,760 \frac{\text{hr}}{\text{yr}}} + \frac{\left(\left(125.8 \frac{\text{MMBTU}}{\text{hr}} \right) * \left(0.011 \frac{\text{lb}}{\text{MMBTU}} \right) * \frac{(3,600 - 168) \text{hr}}{\text{yr}} \right) + \left(\left(11.92 \frac{\text{lb}}{\text{hr}} \right) * 168 \frac{\text{hr}}{\text{yr}} \right)}{8,760 \frac{\text{hr}}{\text{yr}}} = 1.29 \frac{\text{lb}}{\text{hr}} \text{ NOx}$$

Sample Calculation C-13: Ton per Year Emissions from Cold-Start Engine (Using CO as an Example)

Value	Name	Units	Notes
2.2	Nominal short term emissions from engine	lb/hr	Nominal data
300	Hours of engine operation	hr/yr	Design limit / regulatory limit
2,000	Conversion factor (pound to ton)	lb/ton	Standard conversion factor
660	Annual CO emissions from engine (Pounds)	lb/yr	Multiply short term emissions limit by hours of engine operation per year
0.330	Annual CO emissions from engine (Tons)	tons/yr	Divide annual CO emissions from engine (pounds) by the pound to ton factor

General Formula Top To Bottom:
$$2.2 \frac{\text{lb CO}}{\text{hr}} * 300 \frac{\text{hr}}{\text{yr}} * \frac{1 \text{ ton}}{2,000 \text{ lb}} = 0.33 \frac{\text{ton}}{\text{yr}}$$

Sample Calculations

Sample Calculation C-14: Ton per Year Emissions from Turbines (Using NOx as an Example)

Value	Name	Units	Notes
219.00	Turbine heat input (natural gas)	MMBTU/hr	Design value
212.00	Turbine heat input (ULSD)	MMBTU/hr	Design value
124.98	Duct Burner heat input (natural gas)	MMBTU/hr	Design value
2.00	Number of Turbine/Duct Burner units	--	Design value
2,000.00	Conversion factor from lb to ton	lb/ton	Standard conversion factor
8,760.00	Total hours per year of turbine operation	hr/yr	Design value
168.00	Hours per year of turbine operation on ULSD	hr/yr	Design value
4,380.00	Hours/year duct burner (estimate for calculating annual proposed emission limits)	hr/yr	Design value
8,592.00	Hours per year of turbine operation on natural gas	hr/yr	Hours per year operation on ULSD subtracted from total hours per year of turbine operation
2.00	Volumetric emissions of NOx from CTG on natural gas	ppmdv @ 15% O ₂	Design value
9.00	Volumetric emissions of NOx from CTG on ULSD	ppmdv @ 15% O ₂	Design value
0.0074	NOx emissions factor from CTG on natural gas	lb/MMBTU	Converted from volumetric emissions using methods from Sample Calculation C-1
0.035	NOx emissions factor from CTG on ULSD	lb/MMBTU	Converted from volumetric emissions using methods from Sample Calculation C-1
0.011	NOx emissions factor from Duct Burner on natural gas	lb/MMBTU	Design value
1.61	NOx short term emission rate from CTG firing natural gas	lb/hr	Multiply NOx emissions factor from CTG on NG by Turbine heat input (firing NG)
7.42	NOx short term emission rate from CTG firing ULSD	lb/hr	Multiply NOx emissions factor from CTG on ULSD by Turbine heat input (firing ULSD)
1.37	NOx short term emission rate from Duct Burner firing natural gas	lb/hr	Multiply NOx emissions factor from DB on NG by DB heat input (firing NG)
13,863.9	Annual NOx emissions contribution from CTG on NG	lb/yr	Multiply NOx emission rate from CTG firing NG (lb/hr) by hr/yr operation of CTG on NG
1,246.0	Annual NOx emissions contribution from CTG on ULSD	lb/yr	Multiply NOx emission rate from CTG firing ULSD (lb/hr) by hr/yr operation of CTG on ULSD
6,021.5	Annual NOx emissions contribution from DB on NG	lb/yr	Multiply NOx emission rate from DB firing NG (lb/hr) by hr/yr operation of DB on NG
21,131.4	Annual NOx emissions contribution from single unit	lb/yr	Add up annual emissions from CTG firing NG, CTG firing ULSD, and DB firing NG
42,262.8	Annual NOx emissions contribution from both units	lb/yr	Multiply annual NOx emissions contribution from single unit by number of units
21.1	Total annual NOx emissions from Turbines and Duct Burners	ton/yr	Divide annual NOx emissions contribution from both units by the conversion factor from pounds to tons

General Formula Top To Bottom:
$$\frac{(219 \frac{MMBTU}{hr} * 0.0074 \frac{lb}{MMBTU} * \frac{(8,760 - 168)hr}{yr})}{2000 \frac{lb}{ton}} + \frac{(212 \frac{MMBTU}{hr} * 0.035 \frac{lb}{MMBTU} * \frac{168 hr}{yr})}{2000 \frac{lb}{ton}} + \frac{(124.98 \frac{MMBTU}{hr} * 0.011 \frac{lb}{MMBTU} * \frac{4,380 hr}{yr})}{2000 \frac{lb}{ton}} = 21.1 \frac{ton}{yr} NOx$$

Appendix D

Technical Information

Technical Information

Facility Name: Massachusetts Institute of Technology

Street Address: 59 Vassar St., Building 42C, Cambridge MA 02139

Standard Industrial Classification (SIC) Code: 4931/8221

North American Industry Classification System (NAICS) Code: 611310

Contact Person: Ken Packard, kpackard@MIT.EDU, 617-253-4790

Responsible Official: Louis DiBerardinis, Director, EHS Office

Application Preparer: A.J. Jablonowski, Epsilon Associates,
ajablonowski@epsilonassociates.com, 978-641-6202

Type of Project: Combined Heat and Power CTG Installation

Project Description: Two nominal 22 MW Combustion Turbine Generators (CTGs) with supplemental duct fired (134 MMBtu/hr) Heat Recovery Steam Generators (HRSGs), and one 2 MW IC engine.

Pollution Control Equipment: Selective Catalytic Reduction (~90% NO_x Control); Oxidation Catalyst (~92% CO Control) on CTG/HRSGs.

Exhaust Parameters: CTG/HRSG (separate flues): Steel, 167 ft AGL 7 ft diameter, 180-225 °F exhaust at 45-70 ft/s

Cold-Start Engine: Steel, 93.5 ft AGL, 2.0 ft diameter, 752.1 °F exhaust at 81.1 ft/s